

VENTILATION AUDIT REPORT

SCHOOL:	Dungog Public School (1792)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Upper Hunter
LOCAL GOVERNMENT AREA:	Dungog

1792 - Dungog Public School
Site Plan (12483)












1:643

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (53.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0011 - Home Base - (53.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0012 - Home Base - (67.22 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0014 - Withdrawal Space - 1hb - (20.97 SQM)	● Student Space (9)	
B00A - R0015 - Practical Activities - 1hb - (10.23 SQM)	● Student Space (4)	
B00A - R0017 - Home Base - (66.65 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0018 - Practical Activities - 1hb - (13.42 SQM)	● Student Space (6)	
B00A - R0020 - Withdrawal Space - 1hb - (7.11 SQM)	● Student Space (3)	
B00A - R0022 - Practical Activities - M - 1hb - (23.44 SQM)	● Student Space (10)	
B00A - R0023 - Home Base - M - (59.13 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0025 - Practical Activities - 1hb - (45.75 SQM)	● Student Space (21)	
B00A - R0026 - Movement - (103.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Staff Room Annexe - (14.63 SQM)	● Office (3)	
B00C - R0006 - Movement - (40.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - M - (52.95 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0008 - Special Programs Room - (52.76 SQM)	● Student Space (24)	
B00C - R0009 - Home Base - (53.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0010 - Home Base - (52.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0013 - Movement - (12.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (5.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (7.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (9.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Movement - (10.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Reading Area - (85.61 SQM)	● Student Space (39)	
B00D - R0019 - Reading Area - (80.53 SQM)	● Student Space (37)	
B00E - R0001 - Home Base - (52.47 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0004 - Practical Activities - 1hb - (20.95 SQM)	● Student Space (9)	
B00E - R0005 - Withdrawal Space - 1hb - (11.82 SQM)	● Student Space (5)	
B00E - R0008 - Movement - (33.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (59.8 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Movement - (9.86 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Home Base - (51.96 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0011 - Home Base - (52.18 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0001 - Movement - (25.86 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (20.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (43.53 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Communal Space - (138.13 SQM)	● Student Space (64)	
B00J - R0011 - Movement - (10.79 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Movement - (10.84 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Raised Platform - (36.69 SQM)	Not Applicable	Circulation or storage space.
B00J - R0026 - Canteen - (28.22 SQM)	Not Applicable	Circulation or storage space.
B00J - R0027 - Movement - (18.04 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Staff Room Annexe - (17.15 SQM)	● Office (4)	
B00K - R0002 - Staff Room - (54.55 SQM)	● Office (13)	
B00K - R0003 - Interview - (11.93 SQM)	● Office (2)	
B00K - R0004 - Entry Vestibule - (16.49 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Movement - (13.81 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Movement - (20.66 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Deputy Principal - (13.64 SQM)	● Office (3)	
B00K - R0008 - Deputy Principal - (14.39 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0013 - Principal - (16.79 SQM)	 Office (4)	
B00K - R0015 - Duplicating Workroom - (18.34 SQM)	 Office (4)	
B00K - R0016 - Clerical Office - (14.56 SQM)	 Office (3)	
B00K - R0017 - Sick Bay - (9.96 SQM)	 Student Space (4)	
B00K - R0021 - Movement - (18.89 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Practical Activities - 1hb - (19.02 SQM)	 Student Space (8)	
B00L - R0003 - Home Base - (60.49 SQM) - Teaching Space: 1	 Student Space (28)	
B00L - R0005 - Withdrawal Space - 2hb - (11.65 SQM)	 Student Space (5)	
B00L - R0006 - Practical Activities - 1hb - (19.02 SQM)	 Student Space (8)	
B00L - R0007 - Home Base - (60.49 SQM) - Teaching Space: 1	 Student Space (28)	