

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Dunoon Public School (1797)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lismore</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lismore</b>

1797 - Dunoon Public School  
Site Plan (10343)



1:813

Printed: 11-Sep-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Duplicating Workroom - (7.25 SQM)	Office (1)	
B00A - R0004 - Principal - (10.36 SQM)	Office (2)	
B00A - R0009 - Staff Room - (27.3 SQM)	Office (6)	
B00A - R0011 - Withdrawal Space - 1hb - (13.7 SQM)	Student Space (6)	
B00A - R0012 - Practical Activities - 1hb - (9.94 SQM)	Student Space (4)	
B00A - R0014 - Clerical Office - (16.24 SQM)	Office (4)	
B00A - R0016 - Entry Vestibule - (6.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Sick Bay - (6.87 SQM)	Student Space (3)	
B00A - R0018 - Home Base - (61.67 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0014 - Home Base - (66.57 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0017 - Practical Activities - 1hb - (13.18 SQM)	Student Space (6)	
B00B - R0020 - Home Base - (63.57 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0022 - Practical Activities - 1hb - (12.92 SQM)	Student Space (5)	
B00C - R0015 - Practical Activities - 1hb - (17.99 SQM)	Student Space (8)	
B00C - R0016 - Home Base - (74.87 SQM) - Teaching Space: 1	Student Space (34)	
B00C - R0020 - Home Base - (75.17 SQM) - Teaching Space: 1	Student Space (34)	
B00C - R0022 - Practical Activities - 1hb - (18.41 SQM)	Student Space (8)	
B00E - R0002 - Canteen - (20.13 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Special Programs Room - (92.04 SQM)	Student Space (42)	