

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Dural Public School (1799)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Castle Hill</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>The Hills</b>

1799 - Dural Public School  
Site Plan (11713)



1:1,014

Printed: 13-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Sick Bay - (13.78 SQM)	● Student Space (6)	
B00A - R0004 - Deputy Principal - (12.64 SQM)	● Office (3)	
B00A - R0005 - Staff Room Annexe - (12.11 SQM)	● Office (3)	
B00A - R0006 - Principal - (20.59 SQM)	● Office (5)	
B00A - R0008 - Clerical Office - (12.96 SQM)	● Office (3)	
B00A - R0009 - Duplicating Workroom - (13.7 SQM)	● Office (3)	
B00A - R0010 - Sick Bay - (8.12 SQM)	● Student Space (3)	
B00A - R0011 - Interview - (12.22 SQM)	● Office (3)	
B00A - R0012 - Staff Room - (46.19 SQM)	● Office (11)	
B00A - R0017 - Entry Vestibule - (17.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (46.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (30.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Entry Vestibule - (8.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Reading Area - (178.99 SQM)	● Student Space (83)	
B00A - R1012 - Movement - (12.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Raised Platform - (20.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Canteen - (25.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (15.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (50.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (19.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Home Base - (66.95 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0015 - Practical Activities - 1hb - (17.16 SQM)	● Student Space (7)	
B00B - R0017 - Special Programs Room - (47.5 SQM)	● Student Space (22)	
B00C - R0003 - Practical Activities - 1hb - (17.93 SQM)	● Student Space (8)	
B00C - R0004 - Home Base - (51.48 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0005 - Home Base - (56.93 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0006 - Practical Activities - 1hb - (12.48 SQM)	● Student Space (5)	
B00C - R0007 - Movement - (66.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Practical Activities - 1hb - (12.48 SQM)	● Student Space (5)	
B00C - R1004 - Home Base - (56.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1005 - Home Base - (56.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1006 - Practical Activities - 1hb - (12.48 SQM)	● Student Space (5)	
B00C - R1007 - Movement - (66.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Practical Activities - 1hb - (12.48 SQM)	● Student Space (5)	
B00D - R0004 - Home Base - (56.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0005 - Home Base - (56.32 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0006 - Practical Activities - 1hb - (12.48 SQM)	● Student Space (5)	
B00D - R0007 - Movement - (44.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - Withdrawal Space - 1hb - (13.54 SQM)	● Student Space (6)	
B00D - R1004 - Practical Activities - 1hb - (12.48 SQM)	● Student Space (5)	
B00D - R1005 - Home Base - (56.32 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1006 - Home Base - (56.48 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1007 - Practical Activities - 1hb - (12.48 SQM)	● Student Space (5)	
B00D - R1008 - Movement - (44.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Practical Activities - 1hb - (18.05 SQM)	● Student Space (8)	
B00E - R0002 - Home Base - (52.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0003 - Home Base - (84.94 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0004 - Practical Activities - 1hb - (11.38 SQM)	● Student Space (5)	
B00E - R0009 - Movement - (57.63 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0003 - Movement - (8.39 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Withdrawal Space - 1hb - (19.75 SQM)	● Student Space (9)	
B00F - R0006 - Home Base - (88.06 SQM) - Teaching Space: 1	● Student Space (40)	
B00F - R0007 - Home Base - (57.01 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0002 - Movement - (10.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Home Base - (57.35 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0002 - Special Programs Room - (38.99 SQM)	● Student Space (18)	
B00H - R0003 - Special Programs Room - (41.75 SQM)	● Student Space (19)	
B00I - R0005 - Home Base - (56.59 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0006 - Home Base - (56.59 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0001 - Communal Space - (203.79 SQM)	● Student Space (94)	
B00M - R0003 - Raised Platform - (60.83 SQM)	Not Applicable	Circulation or storage space.
B00M - R0004 - Movement - (12.57 SQM)	Not Applicable	Circulation or storage space.
B00M - R0005 - Movement - (5.71 SQM)	Not Applicable	Circulation or storage space.
OS 602 11796 - OS 602 11796 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	