

VENTILATION AUDIT REPORT

SCHOOL:	Duval High School (8492)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Armidale

8492 - Duval High School
Site Plan (12487)
























Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Computer Learning Space - (92.02 SQM)	Student Space (42)	
B001 - R0002 - Darkroom Space - (44.7 SQM)	Office (11)	
B001 - R0004 - Growing/Breeding - (9.64 SQM)	Not Applicable	Circulation or storage space.
B001 - R0005 - Computer Learning Space - (92.03 SQM)	Student Space (42)	
B001 - R0007 - Staff Study - (51.15 SQM)	Office (12)	
B001 - R0015 - Clerical Office - (15.84 SQM)	Office (3)	
B001 - R0018 - Staff Study - (16.06 SQM)	Office (4)	
B001 - R0019 - Main Area - (218.48 SQM)	Not Applicable	Circulation or storage space.
B001 - R0030 - General Learning Space - (56.71 SQM)	Student Space (26)	
B001 - R0033 - Movement - (10.36 SQM)	Not Applicable	Circulation or storage space.
B001 - R0034 - Movement - (10.35 SQM)	Not Applicable	Circulation or storage space.
B001 - R0035 - General Learning Space - (57.24 SQM)	Student Space (26)	
B001 - R0038 - Laboratory L.S. - (92.04 SQM)	Student Space (42)	
B001 - R0039 - Preparation - (56.65 SQM)	Not Applicable	Circulation or storage space.
B001 - R0041 - Laboratory L.S. - (90.51 SQM)	Student Space (41)	
B001 - R0042 - Entry - (13.96 SQM)	Not Applicable	Circulation or storage space.
B001 - R0044 - Main Area - (64.64 SQM)	Not Applicable	Circulation or storage space.
B001 - R0046 - Staff Study - (33.62 SQM)	Office (8)	
B001 - R0047 - Performance Workspace - (116.49 SQM)	Student Space (54)	
B001 - R0053 - Movement - (442.42 SQM)	Not Applicable	Circulation or storage space.
B001 - R1001 - Laboratory L.S. - (91.52 SQM)	Student Space (42)	
B001 - R1002 - Preparation - (48.54 SQM)	Not Applicable	Circulation or storage space.
B001 - R1003 - Growing/Breeding - (10.17 SQM)	Not Applicable	Circulation or storage space.
B001 - R1004 - Laboratory L.S. - (92.31 SQM)	Student Space (42)	
B001 - R1006 - Staff Study - (51.08 SQM)	Office (12)	
B001 - R1014 - Workroom - (15.98 SQM)	Office (3)	
B001 - R1015 - Workroom - (15.93 SQM)	Office (3)	
B001 - R1016 - Workroom - (16.34 SQM)	Office (4)	
B001 - R1026 - General Learning Space - (57.17 SQM)	Student Space (26)	
B001 - R1027 - General Learning Space - (56.13 SQM)	Student Space (26)	
B001 - R1030 - General Learning Space - (56.14 SQM)	Student Space (26)	
B001 - R1031 - General Learning Space - (57.18 SQM)	Student Space (26)	
B001 - R1032 - Laboratory L.S. - (91.67 SQM)	Student Space (42)	
B001 - R1034 - Preparation - (56.44 SQM)	Not Applicable	Circulation or storage space.
B001 - R1035 - Laboratory L.S. - (92.12 SQM)	Student Space (42)	
B001 - R1038 - Interview - (33.7 SQM)	Office (8)	
B001 - R1039 - Movement - (54.3 SQM)	Not Applicable	Circulation or storage space.
B001 - R1040 - Movement - (65.78 SQM)	Not Applicable	Circulation or storage space.
B001 - R1041 - Movement - (253.25 SQM)	Not Applicable	Circulation or storage space.
B001 - R1042 - Movement - (10.01 SQM)	Not Applicable	Circulation or storage space.
B001 - R1043 - Movement - (10.02 SQM)	Not Applicable	Circulation or storage space.
B001 - R1044 - Study Space - (173.28 SQM)	Not Applicable	Circulation or storage space.
B001 - R1046 - General Learning Space - (116.46 SQM)	Student Space (54)	
B002 - R0002 - Canteen - (73.2 SQM)	Not Applicable	Circulation or storage space.
B002 - R0005 - Movement - (23.99 SQM)	Not Applicable	Circulation or storage space.
B002 - R0012 - Movement - (7.02 SQM)	Not Applicable	Circulation or storage space.
B002 - R0014 - Principal - (35.71 SQM)	Office (8)	
B002 - R0017 - Clerical Office - (17.44 SQM)	Office (4)	
B002 - R0019 - Public Entry - (22.4 SQM)	Not Applicable	Circulation or storage space.
B002 - R0020 - Clinic - Girls - (12.62 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B002 - R0021 - Clerical Office - (48.88 SQM)	Office (12)	
B002 - R0025 - Movement - (328.78 SQM)	Not Applicable	Circulation or storage space.
B002 - R1001 - Movement - (13.27 SQM)	Not Applicable	Circulation or storage space.
B002 - R1002 - Movement - (14.62 SQM)	Not Applicable	Circulation or storage space.
B002 - R1003 - Ancillary Staff - (27.7 SQM)	Office (6)	
B002 - R1004 - Commonroom - (243.14 SQM)	Office (60)	
B002 - R1006 - Clinic - Girls - (6 SQM)	Office (1)	
B002 - R1014 - Staff Study - (16.32 SQM)	Office (4)	
B002 - R1015 - Clinic - Boys - (12.24 SQM)	Office (3)	
B002 - R1016 - Seminar - (13.8 SQM)	Office (3)	
B002 - R1017 - Seminar - (12.84 SQM)	Office (3)	
B002 - R1020 - Staff Study - (16.15 SQM)	Office (4)	
B002 - R1027 - Duplicating Workroom - (15.13 SQM)	Office (3)	
B002 - R1029 - General Learning Space - (25.83 SQM)	Student Space (11)	
B002 - R1031 - Duplicating Workroom - (28.63 SQM)	Office (7)	
B002 - R1032 - Movement - (90.92 SQM)	Not Applicable	Circulation or storage space.
B003 - M0004 - Music Learning Space - (89.54 SQM)	Student Space (41)	
B003 - M0006 - Music Learning Space - (34.72 SQM)	Student Space (16)	
B003 - M0007 - Staff Study - (77.67 SQM)	Office (19)	
B003 - M0008 - Movement - (10.68 SQM)	Not Applicable	Circulation or storage space.
B003 - M0009 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B003 - R0007 - Staff Study - (9.04 SQM)	Office (2)	
B003 - R0016 - Staff Study - (10.46 SQM)	Office (2)	
B003 - R0023 - Multi-Purpose Space - (108.39 SQM)	Student Space (50)	
B003 - R0024 - Movement - (129.37 SQM)	Not Applicable	Circulation or storage space.
B003 - R0025 - Gymnasium - (460.09 SQM)	Student Space (213)	
B003 - R0029 - Movement - (10.43 SQM)	Not Applicable	Circulation or storage space.
B003 - R0030 - Movement - (159.71 SQM)	Not Applicable	Circulation or storage space.
B003 - R0031 - Fitness Laboratory - (49.85 SQM)	Student Space (23)	
B004 - R0001 - Design L.S. - (66.01 SQM)	Student Space (30)	
B004 - R0003 - Design L.S. - (66.23 SQM)	Student Space (30)	
B004 - R0006 - Food Technology L.S. - (94.32 SQM)	Student Space (43)	
B004 - R0008 - Food Technology L.S. - (93.1 SQM)	Student Space (43)	
B004 - R0013 - Design L.S. - (65.75 SQM)	Student Space (30)	
B004 - R0017 - General Learning Space - (66.4 SQM)	Student Space (30)	
B004 - R0021 - Staff Study - (34.65 SQM)	Office (8)	
B004 - R0035 - Staff Study - (31.96 SQM)	Office (7)	
B004 - R0037 - Movement - (28.13 SQM)	Not Applicable	Circulation or storage space.
B004 - R0038 - Movement - (122.53 SQM)	Not Applicable	Circulation or storage space.
B004 - R0039 - Art Learning Space - (104.44 SQM)	Student Space (48)	
B004 - R0040 - Art Learning Space - (85.39 SQM)	Student Space (39)	
B004 - R0041 - Art Entry/Display - (14.19 SQM)	Not Applicable	Circulation or storage space.
B004 - R0042 - Art Learning Space - (40.48 SQM)	Student Space (18)	
B004 - R0044 - Movement - (66.94 SQM)	Not Applicable	Circulation or storage space.
B004 - R0045 - Workshop - (176.71 SQM)	Student Space (81)	
B004 - R0048 - Welding Area - (8.56 SQM)	Not Applicable	Circulation or storage space.
B004 - R0049 - Welding Area - (11.45 SQM)	Not Applicable	Circulation or storage space.
B004 - R0050 - Welding Area - (6.19 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B004 - R0051 - Workshop Area - (152.43 SQM)	 Student Space (70)	
B004 - R0052 - Movement - (17.44 SQM)	Not Applicable	Circulation or storage space.
B004 - R0053 - Food Technology L.S. - (36.51 SQM)	 Student Space (16)	
B004 - R0054 - Food Technology L.S. - (10.05 SQM)	 Student Space (4)	
B004 - R0055 - Food Technology L.S. - (11.9 SQM)	 Student Space (5)	
B004 - R0057 - Movement - (6.56 SQM)	Not Applicable	Circulation or storage space.
B005 - R0008 - Duplicating Workroom - (13.95 SQM)	 Office (3)	
B005 - R0010 - General Learning Space - (51.65 SQM)	 Student Space (23)	
B005 - R0011 - General Learning Space - (51.65 SQM)	 Student Space (23)	
B005 - R0013 - Movement - (10.17 SQM)	Not Applicable	Circulation or storage space.
B005 - R0014 - Staff Study - (25.5 SQM)	 Office (6)	
B005 - R0017 - Serviced Learning Space - (52.82 SQM)	 Student Space (24)	
B005 - R0018 - Movement - (9.6 SQM)	Not Applicable	Circulation or storage space.
B005 - R0019 - General Learning Space - (52.23 SQM)	 Student Space (24)	
B005 - R0020 - General Learning Space - (52.22 SQM)	 Student Space (24)	
B005 - R0023 - General Assistants - (22.29 SQM)	 Office (5)	
B005 - R0026 - Movement - (240.45 SQM)	Not Applicable	Circulation or storage space.
B005 - R0029 - Staff Study - (25.5 SQM)	 Office (6)	
B005 - R1004 - General Learning Space - (52.29 SQM)	 Student Space (24)	
B005 - R1005 - General Learning Space - (52.37 SQM)	 Student Space (24)	
B005 - R1006 - General Learning Space - (52.58 SQM)	 Student Space (24)	
B005 - R1007 - Staff Study - (52.62 SQM)	 Office (13)	
B005 - R1008 - Movement - (9.52 SQM)	Not Applicable	Circulation or storage space.
B005 - R1009 - Movement - (9.52 SQM)	Not Applicable	Circulation or storage space.
B005 - R1011 - General Learning Space - (51.5 SQM)	 Student Space (23)	
B005 - R1012 - General Learning Space - (51.5 SQM)	 Student Space (23)	
B005 - R1014 - General Learning Space - (26.47 SQM)	 Student Space (12)	
B005 - R1018 - Movement - (241.16 SQM)	Not Applicable	Circulation or storage space.
B006 - R0003 - Movement - (27.78 SQM)	Not Applicable	Circulation or storage space.
OS 601 10638 - OS 601 10638 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	