

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Eagle Vale High School (8569)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Campbelltown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Campbelltown</b>

8569 - Eagle Vale High School  
Site Plan (10347)



1:1,362

Printed: 24-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Food Technology L.S. - (105.21 SQM) - Teaching Space: 1	● Student Space (48)	
B00A - R0002 - Preparation - (23.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Food Technology L.S. - (105.37 SQM) - Teaching Space: 1	● Student Space (48)	
B00A - R0005 - Design L.S. - (73.71 SQM) - Teaching Space: 1	● Student Space (34)	
B00A - R0006 - Design L.S. - (73.72 SQM) - Teaching Space: 1	● Student Space (34)	
B00A - R0008 - Staff Study - (29.35 SQM)	● Office (7)	
B00A - R0012 - Movement - (105.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Music Learning Space - (66.28 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1008 - Movement - (50.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Staff Study - (29.48 SQM)	● Office (7)	
B00A - R1011 - Practice/Seminar - (6.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Practice/Seminar - (6.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - Performance Workshop - (20.15 SQM)	● Student Space (9)	
B00A - R1018 - Performance Workshop - (106.87 SQM)	● Student Space (49)	
B00B - R0011 - Movement - (81.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (81.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (81.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (81.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (35.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Movement - (34.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - Staff Study - (39.08 SQM)	● Office (9)	
B00B - R1012 - Laboratory L.S. - (79.76 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1013 - Preparation - Science - (32.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - Laboratory L.S. - (79.68 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R1015 - Laboratory L.S. - (81.29 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1016 - Preparation - Science - (32.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R1017 - Laboratory L.S. - (81.11 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1018 - Laboratory L.S. - (81.12 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1019 - Preparation - Science - (32.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R1020 - Laboratory L.S. - (81.2 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1021 - Movement - (122.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (63.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0059 - General Learning Space - (36.55 SQM) - Teaching Space: 1	● Student Space (16)	
B00C - R0060 - General Learning Space - (36.48 SQM) - Teaching Space: 1	● Student Space (16)	
B00C - R0061 - General Learning Space - (47.69 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0062 - General Learning Space - (46.94 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0063 - General Learning Space - (47.61 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0064 - Movement - (118.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R0066 - Movement - (17.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0074 - Audio Visual Workroom - (41.74 SQM)	● Student Space (19)	
B00C - R0076 - Movement - (347.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0078 - General Learning Space - (48.09 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0079 - General Learning Space - (46.8 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0080 - General Learning Space - (47.69 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0081 - Special Learning Space - (36.48 SQM) - Teaching Space: 1	● Student Space (16)	
B00C - R0082 - Special Learning Space - (36.55 SQM) - Teaching Space: 1	● Student Space (16)	
B00C - R0088 - Movement - (18.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0093 - Main Entry - (30.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R0094 - Main Area - (285 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0095 - Tiered Learning Area - (6.84 SQM)	Student Space (3)	
B00C - R0096 - Tiered Learning Area - (6.84 SQM)	Student Space (3)	
B00C - R0097 - Staff Study - (38.23 SQM)	Office (9)	
B00C - R0109 - Darkroom Space - (9.38 SQM)	Office (2)	
B00C - R0111 - Dark Room - (16.41 SQM)	Office (4)	
B00C - R0114 - Staff Study - (38.31 SQM)	Office (9)	
B00C - R0116 - Movement - (112.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R1021 - Movement - (287 SQM)	Not Applicable	Circulation or storage space.
B00C - R1026 - General Learning Space - (43.35 SQM) - Teaching Space: 1	Student Space (20)	
B00C - R1029 - General Learning Space - (47.69 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1030 - General Learning Space - (47.71 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1031 - General Learning Space - (46.66 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1032 - General Learning Space - (47.87 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1033 - Administration - Executive - (27.82 SQM)	Office (6)	
B00C - R1035 - General Learning Space - (46.59 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1036 - General Learning Space - (49.2 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1038 - Leading Teacher - (12.25 SQM)	Office (3)	
B00C - R1041 - Performance Workshop - (76.78 SQM)	Student Space (35)	
B00C - R1043 - General Learning Space - (49.34 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1044 - General Learning Space - (46.59 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1045 - General Learning Space - (43.17 SQM) - Teaching Space: 1	Student Space (20)	
B00C - R1046 - General Learning Space - (47.62 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1047 - Computer Learning Space - (47.89 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1048 - General Learning Space - (46.74 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1049 - General Learning Space - (47.69 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1050 - Movement - (94.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R1062 - Movement - (94.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Clinic - Girls - (13.46 SQM)	Office (3)	
B00D - R0006 - Deputy Principal Office - (19.58 SQM)	Office (4)	
B00D - R0008 - Administration - Clerical - (46.25 SQM)	Office (11)	
B00D - R0010 - Deputy Principal Office - (15.47 SQM)	Office (3)	
B00D - R0013 - Clinic - Boys - (13.52 SQM)	Office (3)	
B00D - R0014 - Principal Office - (15.37 SQM)	Office (3)	
B00D - R0015 - Principal Office - (14.43 SQM)	Office (3)	
B00D - R0016 - Public Reception - (22.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (62.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R1019 - Movement - (11.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R1020 - Ancillary Staff - (21.18 SQM)	Office (5)	
B00D - R1022 - Commonroom - (95.97 SQM)	Office (23)	
B00D - R1023 - Staff Kitchen - (7.17 SQM)	Office (1)	
B00E - R0005 - Wood Technology Bay - (32.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Movement - (71.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0033 - Materials Learning Space - Type 1 - (85.65 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0035 - Materials Learning Space - Type 1 - (88.58 SQM) - Teaching Space: 1	Student Space (41)	
B00E - R0049 - Materials Workshop - Type 3 - (211.09 SQM)	Student Space (97)	
B00E - R0050 - Materials Workshop - Type 2 - (26.05 SQM)	Student Space (12)	
B00E - R1005 - Computer Learning Space - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1007 - Movement - (6.92 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1010 - Interview/Office - Type 1 - (11.31 SQM)	Office (2)	
B00E - R1011 - General Learning Space - (57.55 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1013 - Staff Study - (27.34 SQM)	Office (6)	
B00F - R0015 - Art Learning Space - (59.03 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0017 - Art Learning Space - (60.18 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0019 - Movement - (101.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0061 - General Assistants - (7.03 SQM)	Office (1)	
B00F - R0063 - Art Learning Space - (50.78 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R1001 - Art Learning Space - (61.2 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R1002 - Multi Media Workshop - (60.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R1004 - Movement - (49.5 SQM)	Not Applicable	Circulation or storage space.
B00F - R1006 - Staff Study - (19.77 SQM)	Office (4)	
B00G - R0034 - General Assistants - (9.67 SQM)	Office (2)	
B00G - R0035 - Student Canteen - (62.17 SQM)	Not Applicable	Circulation or storage space.
B00G - R0061 - Movement - (85.98 SQM)	Not Applicable	Circulation or storage space.
B00G - R8001 - Movement - (10.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R8008 - Movement - (10.56 SQM)	Not Applicable	Circulation or storage space.
B00G - R9022 - Movement - (24.65 SQM)	Not Applicable	Circulation or storage space.
B00G - R9027 - Multi-Purpose Space - (533.29 SQM)	Student Space (247)	
B00G - R9033 - Stage - (95.1 SQM)	Not Applicable	Circulation or storage space.
B00G - R9034 - Movement - (8.49 SQM)	Not Applicable	Circulation or storage space.
B00G - R9036 - Movement - (13.3 SQM)	Not Applicable	Circulation or storage space.
B00G - R9038 - Staff Kitchen - (19.26 SQM)	Office (4)	
B00G - R9040 - Movement - (8.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R9042 - Movement - (11.67 SQM)	Not Applicable	Circulation or storage space.
B00G - R9044 - Staff Study - (21.25 SQM)	Office (5)	
B00G - R9046 - Movement - (17.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Growing/Breeding - (7.48 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Movement - (6.88 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Movement - (58.95 SQM)	Not Applicable	Circulation or storage space.
B00J - R0031 - General Learning Space - (46.29 SQM) - Teaching Space: 1	Student Space (21)	
B00J - R0040 - General Learning Space - (45.93 SQM) - Teaching Space: 1	Student Space (21)	
B00J - R0041 - General Learning Space - (46.11 SQM) - Teaching Space: 1	Student Space (21)	
B00J - R0043 - Seminar - Type 1 - (14.88 SQM)	Office (3)	
B00J - R0044 - Computer Learning Space - (46.64 SQM) - Teaching Space: 1	Student Space (21)	
B00J - R0046 - General Learning Space - (40.24 SQM) - Teaching Space: 1	Student Space (18)	
B00J - R0048 - General Learning Space - (40.18 SQM) - Teaching Space: 1	Student Space (18)	
B00J - R0049 - Staff Study - (36.9 SQM)	Office (9)	
B00J - R0051 - Movement - (107.92 SQM)	Not Applicable	Circulation or storage space.
B00J - R0052 - Movement - (49.38 SQM)	Not Applicable	Circulation or storage space.
B00J - R1009 - Movement - (17.85 SQM)	Not Applicable	Circulation or storage space.
B00J - R1010 - General Learning Space - (41.5 SQM) - Teaching Space: 1	Student Space (19)	
B00J - R1011 - General Learning Space - (41.51 SQM) - Teaching Space: 1	Student Space (19)	
B00J - R1044 - Staff Study - (26.38 SQM)	Office (6)	
B00J - R1046 - Staff Study - (26.3 SQM)	Office (6)	