


VENTILATION AUDIT REPORT

SCHOOL:	East Hills Girls Technology High School (8187)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	East Hills
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

8187 - East Hills Girls Technology High School
Site Plan (11865)



1:1,581





















Printed: 17-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B002 - R0005 - Multi-Purpose Space - (348.89 SQM)	 Student Space (161)	
B002 - R0008 - Movement - (12.51 SQM)	Not Applicable	Circulation or storage space.
B003 - R0001 - General Learning Space - (53.53 SQM) - Teaching Space: 1	 Student Space (24)	
B003 - R0002 - General Learning Space - (53.67 SQM) - Teaching Space: 1	 Student Space (24)	
B003 - R0003 - Design L.S. - (66.93 SQM) - Teaching Space: 1	 Student Space (31)	
B003 - R0006 - General Learning Space - (66.95 SQM) - Teaching Space: 1	 Student Space (31)	
B003 - R0009 - General Learning Space - (66.75 SQM) - Teaching Space: 1	 Student Space (30)	
B003 - R0016 - Staff Study - (57.76 SQM)	 Office (14)	
B003 - R0017 - Tea Room - (9.7 SQM)	Not Applicable	Circulation or storage space.
B004 - R0004 - General Learning Space - (53.31 SQM) - Teaching Space: 1	 Student Space (24)	
B004 - R0005 - General Learning Space - (53.45 SQM) - Teaching Space: 1	 Student Space (24)	
B004 - R0008 - General Learning Space - (53.53 SQM) - Teaching Space: 1	 Student Space (24)	
B004 - R0009 - General Learning Space - (53.6 SQM) - Teaching Space: 1	 Student Space (24)	
B004 - R0012 - Staff Study - (19.82 SQM)	 Office (4)	
B004 - R0014 - Staff Study - (29.34 SQM)	 Office (7)	
B005 - R0003 - General Learning Space - (53.46 SQM) - Teaching Space: 1	 Student Space (24)	
B005 - R0007 - Preparation - Science - (22.33 SQM)	Not Applicable	Circulation or storage space.
B005 - R0011 - Laboratory L.S. - (89.18 SQM) - Teaching Space: 1	 Student Space (41)	
B005 - R0012 - General Learning Space - (50.67 SQM) - Teaching Space: 1	 Student Space (23)	
B005 - R0013 - Science Laboratory - (43.92 SQM)	 Student Space (20)	
B006 - R0003 - General Learning Space - (53.38 SQM) - Teaching Space: 1	 Student Space (24)	
B006 - R0004 - General Learning Space - (53.31 SQM) - Teaching Space: 1	 Student Space (24)	
B006 - R0005 - Staff Study - (11.03 SQM)	 Office (2)	
B006 - R0006 - Staff Study - (10.77 SQM)	 Office (2)	
B006 - R0007 - General Learning Space - (53.38 SQM) - Teaching Space: 1	 Student Space (24)	
B006 - R0008 - General Learning Space - (53.38 SQM) - Teaching Space: 1	 Student Space (24)	
B006 - R0009 - Staff Study - (22.16 SQM)	 Office (5)	
B007 - R0001 - General Assistants - (15.6 SQM)	 Office (3)	
B007 - R0003 - Computer Learning Space - (53.75 SQM) - Teaching Space: 1	 Student Space (24)	
B007 - R0004 - General Learning Space - (53.53 SQM) - Teaching Space: 1	 Student Space (24)	
B007 - R0005 - General Learning Space - (54.04 SQM) - Teaching Space: 1	 Student Space (25)	
B007 - R0006 - General Learning Space - (53.97 SQM) - Teaching Space: 1	 Student Space (25)	
B007 - R0009 - Staff Study - (37.59 SQM)	 Office (9)	
B007 - R0010 - Tea Room - (6.89 SQM)	Not Applicable	Circulation or storage space.
B007 - R0011 - General Assistants - (21.72 SQM)	 Office (5)	
B008 - R0001 - Dark Room - (8.59 SQM)	 Office (2)	
B008 - R0003 - Art Learning Space - (73.1 SQM) - Teaching Space: 1	 Student Space (33)	
B008 - R0007 - Art Learning Space - (73.45 SQM) - Teaching Space: 1	 Student Space (34)	
B008 - R0010 - Staff Lounge - (12.69 SQM)	 Office (3)	
B008 - R0013 - Dark Room - (7.04 SQM)	 Office (1)	
B008 - R0014 - Staff Study - (9.86 SQM)	 Office (2)	
B008 - R0018 - Art Learning Space - (72.93 SQM) - Teaching Space: 1	 Student Space (33)	
B008 - R0019 - Staff Study - (15.51 SQM)	 Office (3)	
B009 - R0002 - Staff Study - (9.03 SQM)	 Office (2)	
B009 - R0005 - Kitchen - Type 1 - (84.71 SQM)	 Student Space (39)	
B009 - R0006 - Design/Technology L.S. - (44.8 SQM) - Teaching Space: 1	 Student Space (20)	
B009 - R0007 - Materials Technology L.S. - (53.38 SQM) - Teaching Space: 1	 Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B009 - R0008 - Food Technology L.S. - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
B009 - R0009 - Preparation - Materials - (22.2 SQM)	Not Applicable	Circulation or storage space.
B009 - R0011 - Staff Study - (33.31 SQM)	● Office (8)	
B010 - R0001 - Music Learning Space - (76.41 SQM) - Teaching Space: 1	● Student Space (35)	
B010 - R0002 - Computer Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B010 - R0004 - General Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B010 - R0006 - Staff Study - (11.06 SQM)	● Office (2)	
B010 - R0010 - Staff Study - (50.22 SQM)	● Office (12)	
B011 - R0002 - Student Canteen - (38.44 SQM)	Not Applicable	Circulation or storage space.
B012 - M1001 - Senior Seminar - (37.32 SQM)	● Office (9)	
B012 - M1003 - Study Space - (67.19 SQM)	Not Applicable	Circulation or storage space.
B012 - M1004 - Study Space - (15.32 SQM)	Not Applicable	Circulation or storage space.
B012 - R0001 - Computer Learning Space - (91.23 SQM) - Teaching Space: 1	● Student Space (42)	
B012 - R0002 - Laboratory L.S. - (91.13 SQM) - Teaching Space: 1	● Student Space (42)	
B012 - R0003 - Preparation - Science - (44.55 SQM)	Not Applicable	Circulation or storage space.
B012 - R0005 - Laboratory L.S. - (91.22 SQM) - Teaching Space: 1	● Student Space (42)	
B012 - R0008 - Laboratory L.S. - (91.23 SQM) - Teaching Space: 1	● Student Space (42)	
B012 - R0011 - Movement - (40.54 SQM)	Not Applicable	Circulation or storage space.
B012 - R0020 - Staff Study - (41.88 SQM)	● Office (10)	
B012 - R0021 - Tea Room - (6.51 SQM)	Not Applicable	Circulation or storage space.
B012 - R1002 - Seminar - (70.32 SQM)	● Office (17)	
B012 - R1008 - Senior Study - (11.23 SQM)	● Office (2)	
B012 - R1009 - Senior Study - (13.27 SQM)	● Office (3)	
B012 - R1010 - Audio Visual Workroom - (27.63 SQM)	● Student Space (12)	
B012 - R1027 - Main Entry - (33.82 SQM)	Not Applicable	Circulation or storage space.
B012 - R1028 - Main Area - (256.79 SQM)	Not Applicable	Circulation or storage space.
B012 - R1032 - Tea Room - (6.79 SQM)	Not Applicable	Circulation or storage space.
B014 - R0003 - Computer Learning Space - (62.78 SQM) - Teaching Space: 1	● Student Space (29)	
B014 - R0004 - Computer Learning Space - (62.94 SQM) - Teaching Space: 1	● Student Space (29)	
B014 - R0005 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B014 - R0006 - Staff Study - (21.1 SQM)	● Office (5)	
B014 - R0007 - Staff Kitchen - (9.4 SQM)	● Office (2)	
B015 - R0001 - Multi-Purpose Space - (628.6 SQM)	● Student Space (291)	
B016 - R0001 - Performance Workshop - (98.63 SQM)	● Student Space (45)	
B016 - R0002 - Practice/Seminar - (21.45 SQM)	Not Applicable	Circulation or storage space.
B016 - R0004 - General Learning Space - Type 1 - (60.07 SQM) - Teaching Space: 1	● Student Space (27)	
B016 - R0005 - General Learning Space - Type 1 - (60.14 SQM) - Teaching Space: 1	● Student Space (27)	
B016 - R0006 - General Learning Space - Type 1 - (60.23 SQM) - Teaching Space: 1	● Student Space (27)	
B016 - R0007 - General Learning Space - Type 1 - (60.4 SQM) - Teaching Space: 1	● Student Space (28)	
B016 - R0008 - General Learning Space - Type 9 - (60.38 SQM) - Teaching Space: 1	● Student Space (28)	
B016 - R0009 - General Learning Space - Type 8 - (62.58 SQM) - Teaching Space: 1	● Student Space (29)	
B016 - R0011 - Materials Workshop - Type 2 - (119.83 SQM)	● Student Space (55)	
B016 - R0013 - Outdoor Workshop - (90.95 SQM)	Not Applicable	Circulation or storage space.
B016 - R0014 - Welding/Hot Metals Area - (12.44 SQM)	Not Applicable	Circulation or storage space.
B017 - R0001 - Public Reception - (25.47 SQM)	Not Applicable	Circulation or storage space.
B017 - R0002 - Visitors Office - (12.8 SQM)	● Office (3)	
B017 - R0003 - Interview/Meeting - (26.28 SQM)	● Office (6)	
B017 - R0004 - Movement - (29.72 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B017 - R0005 - Principal Office - (18.39 SQM)	 Office (4)	
B017 - R0007 - Staff Lounge - (71.85 SQM)	 Office (17)	
B017 - R0010 - Staff Kitchen - (18.1 SQM)	 Office (4)	
B017 - R0015 - Administration - Executive - (21.7 SQM)	 Office (5)	
B017 - R0017 - Administration - Clerical - (48.34 SQM)	 Office (12)	
B017 - R0018 - Movement - (15.14 SQM)	Not Applicable	Circulation or storage space.
B017 - R0019 - Deputy Principal Office - (12.47 SQM)	 Office (3)	
B017 - R0020 - Deputy Principal Office - (12.58 SQM)	 Office (3)	
B017 - R0021 - Interview/Office - Type 2 - (12.69 SQM)	 Office (3)	
B017 - R0022 - Student Reception - (33.69 SQM)	Not Applicable	Circulation or storage space.
B017 - R0025 - Clinic - Girls - (12.39 SQM)	 Office (3)	
B017 - R0026 - Interview/Office - Type 1 - (12.7 SQM)	 Office (3)	
B017 - R0027 - Deputy Principal Office - (12.87 SQM)	 Office (3)	
OS 600 17420 - OS 600 17420 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 17421 - OS 600 17421 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 11197 - OS 601 11197 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11397 - OS 601 11397 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11684 - OS 601 11684 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11687 - OS 601 11687 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14826 - OS 601 14826 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 16279 - OS 601 16279 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 17815 - OS 601 17815 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	