

VENTILATION AUDIT REPORT

SCHOOL:	East Hills Public School (3924)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	East Hills
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

3924 - East Hills Public School
Site Plan (11865)



1:1,581

Printed: 08-Aug-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Withdrawal Space - 1hb - (21.6 SQM)	● Student Space (10)	
B00A - R0004 - Home Base - (86.72 SQM) - Teaching Space: 1	● Student Space (40)	
B00B - R0002 - Principal - (7.78 SQM)	● Office (1)	
B00B - R0003 - Principal - (15.35 SQM)	● Office (3)	
B00B - R0006 - Clerical Office - (21.51 SQM)	● Office (5)	
B00B - R0007 - Movement - (12.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Staff Room - (57.02 SQM)	● Office (14)	
B00B - R0010 - Sick Bay - (6.29 SQM)	● Student Space (2)	
B00B - R0011 - Staff Room - (57.03 SQM)	● Office (14)	
B00B - R0016 - Study Annexe - (7.4 SQM)	● Office (1)	
B00B - R0017 - Staff Room - (56.97 SQM)	● Office (14)	
B00B - R0018 - Staff Kitchen - (27.98 SQM)	● Office (6)	
B00B - R0019 - Clerical/Printing - (18.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Deputy Principal - (9.58 SQM)	● Office (2)	
B00B - R0021 - Entry Vestibule - (9.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Principal - (28.8 SQM)	● Office (7)	
B00C - R0002 - Movement - (7.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (66.21 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R0010 - Home Base - (67.99 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0002 - Communal Space - (83.23 SQM)	● Student Space (38)	
B00D - R0003 - Movement - (9.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Deputy Principal - (11.61 SQM)	● Office (2)	
B00D - R0011 - Home Base - (53.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0016 - Movement - (27.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Movement - (62.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Reading Area - (36.95 SQM)	● Student Space (17)	
B00D - R0028 - Reading Area - (52.83 SQM)	● Student Space (24)	
B00D - R0032 - Raised Platform - (17.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (13.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Canteen - (17.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Special Programs Room - (18.54 SQM)	● Student Space (8)	
B00F - R0006 - Movement - (7.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Home Base - (94.24 SQM) - Teaching Space: 1	● Student Space (43)	
B00F - R0010 - Home Base - (67.71 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0012 - Practical Activities - 1hb - (14.53 SQM)	● Student Space (6)	
B00F - R0015 - Practical Activities - (16.35 SQM)	● Student Space (7)	
B00G - R0003 - Home Base - (54.32 SQM) - Teaching Space: 1	● Student Space (25)	
B00G - R0004 - Home Base - (54.47 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R0002 - Withdrawal Space - 1hb - (54.02 SQM)	● Student Space (25)	
B00H - R0003 - Home Base - (54.18 SQM) - Teaching Space: 1	● Student Space (25)	
B00I - R0001 - Withdrawal Space - 1hb - (53.37 SQM)	● Student Space (24)	
B00I - R0002 - Home Base - (53.37 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0004 - Home Base - (85.55 SQM) - Teaching Space: 1	● Student Space (39)	