


VENTILATION AUDIT REPORT

SCHOOL:	Eastern Creek Public School (1808)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mount Druitt
LOCAL GOVERNMENT AREA:	Blacktown

1808 - Eastern Creek Public School
Site Plan (13143)



1:1,022

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (41.03 SQM)	Office (10)	
B00A - R0004 - Clerical Office - (12.84 SQM)	Office (3)	
B00A - R0005 - Clerical Office - (20.18 SQM)	Office (5)	
B00A - R0006 - Principal - (17 SQM)	Office (4)	
B00A - R0007 - Interview - (11.65 SQM)	Office (2)	
B00A - R0008 - Sick Bay - (8.08 SQM)	Student Space (3)	
B00A - R0013 - Movement - (40.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (22.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Entry Vestibule - (5.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Home Base - Pre - (37.97 SQM) - Teaching Space: 1	Student Space (17)	
B00B - R0016 - Practical Activities - Pre - (37.94 SQM)	Student Space (17)	
B00C - R0001 - Home Base - (57.03 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0007 - Movement - (9.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (57.05 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0002 - Home Base - (57.36 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0005 - Movement - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (56.97 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0009 - Home Base - (56.97 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0001 - Interview - (10.85 SQM)	Office (2)	
B00E - R0002 - Deputy Principal - (16.14 SQM)	Office (4)	
B00E - R0009 - Home Base - (64.89 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0010 - Home Base - (64.71 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0015 - Movement - (14.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Special Programs Room - (86.35 SQM)	Student Space (40)	
B00F - R0002 - Movement - (5.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Withdrawal Space - 1hb - (22.31 SQM)	Student Space (10)	
B00F - R0007 - Home Base - (57.12 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0001 - Movement - (14.09 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (13.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Withdrawal Space - 1hb - (6.6 SQM)	Student Space (3)	
B00G - R0004 - Home Base - (59.12 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0007 - Practical Activities - 1hb - (37.61 SQM)	Student Space (17)	
B00G - R0008 - Movement - (38.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Home Base - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0001 - Movement - (24.22 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Movement - (17.94 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Canteen - (18.43 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Reading Area - (167.32 SQM)	Student Space (77)	
B00M - R0001 - Communal Space - (134.95 SQM)	Student Space (62)	
B00M - R0011 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00M - R0014 - Raised Platform - (70.8 SQM)	Not Applicable	Circulation or storage space.
B00M - R0015 - Movement - (23.24 SQM)	Not Applicable	Circulation or storage space.
B00M - R0016 - Movement - (5.45 SQM)	Not Applicable	Circulation or storage space.
NS 100 15697 - NS 100 15697 - Learning Unit - Single Primary/PAA - (76 SQM)	Student Space (35)	
OS 602 13983 - OS 602 13983 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14868 - OS 602 14868 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	