

VENTILATION AUDIT REPORT

SCHOOL:	Eastwood Heights Public School (4041)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Ryde
LOCAL GOVERNMENT AREA:	Ryde

4041 - Eastwood Heights Public School
Site Plan (12492)















1:917

Printed: 22-May-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0008 - Special Programs Room - (36.54 SQM)	● Student Space (16)	
B00B - R0011 - Reading Area - (140.92 SQM)	● Student Space (65)	
B00B - R0012 - Special Programs Room - (49.31 SQM)	● Student Space (22)	
B00C - R0001 - Home Base - (56.73 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0002 - Movement - (7.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base - (56.97 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0018 - Home Base - (80.65 SQM) - Teaching Space: 1	● Student Space (37)	
B00D - R0020 - Staff Room Annexe - (9.57 SQM)	● Office (2)	
B00D - R0021 - Staff Room Annexe - (12.89 SQM)	● Office (3)	
B00D - R0024 - Special Programs Room - (19.88 SQM)	● Student Space (9)	
B00D - R0027 - Movement - (23.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0033 - Entry Vestibule - (28.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0034 - Clerical Office - (37.92 SQM)	● Office (9)	
B00D - R0035 - Duplicating Workroom - (26.41 SQM)	● Office (6)	
B00D - R0037 - Movement - (6.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R0038 - Entry Vestibule - (10.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R0039 - Interview - (13.06 SQM)	● Office (3)	
B00D - R0040 - Sick Bay - (11.27 SQM)	● Student Space (5)	
B00D - R0041 - Movement - (21.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R0042 - Principal - (17.15 SQM)	● Office (4)	
B00D - R0043 - Deputy Principal - (13.39 SQM)	● Office (3)	
B00D - R0047 - Interview - (18.21 SQM)	● Office (4)	
B00D - R0048 - Entry Vestibule - (14.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0050 - Staff Room - (39.19 SQM)	● Office (9)	
B00D - R0051 - Staff Room Annexe - (26.68 SQM)	● Office (6)	
B00E - R0005 - Movement - (5.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Home Base - (66.81 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0008 - Home Base - (66.54 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0010 - Movement - (11.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Home Base - (66.54 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0013 - Entry Vestibule - (12.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Special Programs Room - (17.67 SQM)	● Student Space (8)	
B00E - R0025 - Home Base - (80.32 SQM) - Teaching Space: 1	● Student Space (37)	
B00F - R0002 - Home Base - (56.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0006 - Home Base - (56.62 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R0002 - Canteen - (26.47 SQM)	Not Applicable	Circulation or storage space.
B00K - R0012 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Raised Platform - (57.27 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Movement - (24.22 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Communal Space - (146.02 SQM)	● Student Space (67)	
B00M - R0002 - Practical Activities - 1hb - (19.27 SQM)	● Student Space (8)	
B00M - R0003 - Home Base - (60.6 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0004 - Withdrawal Space - 2hb - (10.82 SQM)	● Student Space (5)	
B00M - R0005 - Home Base - (60.06 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0006 - Practical Activities - 1hb - (19.14 SQM)	● Student Space (8)	
B00M - R1002 - Practical Activities - 1hb - (19.76 SQM)	● Student Space (9)	
B00M - R1003 - Home Base - (59.98 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R1004 - Withdrawal Space - 2hb - (11.68 SQM)	● Student Space (5)	
B00M - R1005 - Home Base - (59.67 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R1006 - Practical Activities - 1hb - (19.9 SQM)	 Student Space (9)	
B00N - R0002 - Practical Activities - 1hb - (18.9 SQM)	 Student Space (8)	
B00N - R0004 - Home Base - (60.86 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R0005 - Withdrawal Space - 2hb - (11.51 SQM)	 Student Space (5)	
B00N - R0006 - Home Base - (60.64 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R0008 - Practical Activities - 1hb - (18.86 SQM)	 Student Space (8)	
OS 602 13039 - OS 602 13039 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13914 - OS 602 13914 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14889 - OS 602 14889 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 18329 - OS 602 18329 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 15523 - OS 606 15523 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19574 - OS 606 19574 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	