

VENTILATION AUDIT REPORT

| | |
|-------------------------------|--------------------------------------|
| SCHOOL: | Eastwood Public School (7416) |
| AMU REGION: | Northern Sydney |
| STATE ELECTORATE: | Ryde |
| LOCAL GOVERNMENT AREA: | Ryde |

7416 - Eastwood Public School
Site Plan (12491)



1.711



Printed: 20-Jul-2021

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0003 - Special Programs Room - (15.27 SQM) | Student Space (7) | |
| B00A - R0006 - Withdrawal Space - 1hb - (18.95 SQM) | Student Space (8) | |
| B00A - R0007 - Practical Activities - 1hb - (58.9 SQM) | Student Space (27) | |
| B00A - R0008 - Practical Activities - 1hb - (18.93 SQM) | Student Space (8) | |
| B00A - R0016 - Home Base - (66.31 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00A - R0017 - Home Base - (46.78 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R0018 - Home Base - (46.26 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R0019 - Home Base - (46.78 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R0021 - Movement - (115.61 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1003 - Movement - (7.72 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1005 - Practical Activities - 1hb - (54.08 SQM) | Student Space (25) | |
| B00A - R1006 - Special Programs Room - (20.25 SQM) | Student Space (9) | |
| B00A - R1007 - Movement - (9.37 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1010 - Home Base - (48.58 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00A - R1011 - Home Base - (47.84 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00A - R1012 - Home Base - (47.57 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00A - R1013 - Home Base - (69.24 SQM) - Teaching Space: 1 | Student Space (32) | |
| B00A - R1014 - Movement - (64.34 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0008 - Practical Activities - 1hb - (47.69 SQM) | Student Space (22) | |
| B00B - R0009 - Home Base - (48.34 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0010 - Home Base - (47.69 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0011 - Home Base - (47.82 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0017 - Movement - (75.86 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1001 - Withdrawal Space - 1hb - (15.15 SQM) | Student Space (7) | |
| B00B - R1002 - Home Base - (48.33 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R1003 - Home Base - (48.33 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R1004 - Home Base - (48.33 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R1005 - Practical Activities - 1hb - (48.33 SQM) | Student Space (22) | |
| B00B - R1006 - Special Programs Room - (15.41 SQM) | Student Space (7) | |
| B00B - R1007 - Movement - (96.51 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0001 - Movement - (15.05 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0002 - Reading Area - (171.4 SQM) | Student Space (79) | |
| B00C - R0005 - Movement - (7.66 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0006 - Reading Area - (48.72 SQM) | Student Space (22) | |
| B00C - R0007 - Home Base - (48.45 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00C - R0008 - Home Base - (49.25 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00C - R0009 - Home Base - (48.45 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00C - R0010 - Practical Activities - 1hb - (47.64 SQM) | Student Space (22) | |
| B00C - R0013 - Movement - (11.01 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0017 - Clerical Office - (16.64 SQM) | Office (4) | |
| B00C - R0018 - Movement - (11.01 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0022 - Movement - (72.01 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R1001 - Practical Activities - 1hb - (48.57 SQM) | Student Space (22) | |
| B00C - R1002 - Home Base - (48.7 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00C - R1003 - Home Base - (48.71 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00C - R1004 - Home Base - (47.91 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00C - R1005 - Home Base - (48.31 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00C - R1007 - Movement - (7.93 SQM) | Not Applicable | Circulation or storage space. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00C - R1010 - Movement - (6.98 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R1011 - Movement - (89.94 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0006 - Movement - (7.43 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0001 - Movement - (25.61 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0002 - Home Base - (47.05 SQM) | ● Student Space (21) | |
| B00F - R0003 - Home Base - (47.05 SQM) | ● Student Space (21) | |
| B00I - R0006 - Movement - (15.67 SQM) | Not Applicable | Circulation or storage space. |
| B00M - R0001 - Entry Vestibule - (18.72 SQM) | Not Applicable | Circulation or storage space. |
| B00M - R0002 - Clerical Office - (18.55 SQM) | ● Office (4) | |
| B00M - R0003 - Sick Bay - (8.81 SQM) | ● Student Space (4) | |
| B00M - R0006 - Duplicating Workroom - (33.39 SQM) | ● Office (8) | |
| B00M - R0010 - Staff Room Annexe - (24.48 SQM) | ● Office (6) | |
| B00M - R0011 - Staff Room - (60.97 SQM) | ● Office (15) | |
| B00M - R0014 - Deputy Principal - (12.92 SQM) | ● Office (3) | |
| B00M - R0015 - Deputy Principal - (12.92 SQM) | ● Office (3) | |
| B00M - R0016 - Principal - (16.91 SQM) | ● Office (4) | |
| B00M - R0017 - Interview - (12.92 SQM) | ● Office (3) | |
| B00M - R0018 - Movement - (47.64 SQM) | Not Applicable | Circulation or storage space. |
| B00N - R0005 - Raised Platform - (47.73 SQM) | Not Applicable | Circulation or storage space. |
| B00N - R0012 - Canteen - (43.9 SQM) | Not Applicable | Circulation or storage space. |
| B00N - R0014 - Communal Space - (366.89 SQM) | ● Student Space (170) | |
| B00N - R0018 - Movement - (258.91 SQM) | Not Applicable | Circulation or storage space. |
| B00O - R0001 - Movement - (24.11 SQM) | Not Applicable | Circulation or storage space. |
| B00O - R0002 - Home Base - (46.36 SQM) - Teaching Space: 1 | ● Student Space (21) | |
| B00Q - R0003 - Practical Activities - (20.99 SQM) | ● Student Space (9) | |
| B00Q - R0004 - Withdrawal Space - 1hb - (9.11 SQM) | ● Student Space (4) | |
| B00Q - R0006 - Home Base - (57.7 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00Q - R0007 - Practical Activities - (18.95 SQM) | ● Student Space (8) | |
| B00Q - R0009 - Home Base - (60.3 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00Q - R0010 - Withdrawal Space - 2hb - (11.57 SQM) | ● Student Space (5) | |
| B00Q - R0011 - Home Base - (60.58 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00Q - R0012 - Practical Activities - (18.82 SQM) | ● Student Space (8) | |
| B00Q - R1002 - Practical Activities - (20.85 SQM) | ● Student Space (9) | |
| B00Q - R1003 - Withdrawal Space - 1hb - (9.11 SQM) | ● Student Space (4) | |
| B00Q - R1005 - Home Base - (57.4 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00Q - R1006 - Practical Activities - (19.02 SQM) | ● Student Space (8) | |
| B00Q - R1008 - Home Base - (60.59 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00Q - R1009 - Withdrawal Space - 2hb - (11.63 SQM) | ● Student Space (5) | |
| B00Q - R1010 - Home Base - (60.81 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00Q - R1011 - Practical Activities - (18.92 SQM) | ● Student Space (8) | |
| OS 601 10780 - OS 601 10780 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (35) | |
| OS 601 11878 - OS 601 11878 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (35) | |
| OS 602 10381 - OS 602 10381 - Learning Unit - Standard With P.A.A. - (76 SQM) | ● Student Space (35) | |
| OS 602 12762 - OS 602 12762 - Learning Unit - Standard With P.A.A. - (76 SQM) | ● Student Space (35) | |
| OS 603 13377 - OS 603 13377 - Learning Unit - Standard With P.A.A. A/C - (76 SQM) | ● Student Space (35) | |
| OS 606 11777 - OS 606 11777 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | ● Student Space (35) | |
| OS 606 16783 - OS 606 16783 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | ● Student Space (35) | |
| OS 606 16801 - OS 606 16801 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | ● Student Space (35) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|--|---------|
| OS 606 19057 - OS 606 19057 - Learning Unit - Standard With P.A.A A/C - (76 SQM) |  Student Space (35) | |
| OS 751 17402 - OS 751 17402 - Learning Unit - ESL - (76 SQM) |  Student Space (35) | |