

VENTILATION AUDIT REPORT

SCHOOL:	Ebenezer Public School (1813)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Hawkesbury
LOCAL GOVERNMENT AREA:	Hawkesbury






















1813 - Ebenezer Public School
Site Plan (12493)



Printed: 03-Aug-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Staff Room - (26.62 SQM)	 Office (6)	
B00A - R0004 - Entry Vestibule - (13.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Clerical Office - (8.74 SQM)	 Office (2)	
B00A - R0008 - Duplicating Workroom - (12.07 SQM)	 Office (3)	
B00A - R0010 - Principal - (16.49 SQM)	 Office (4)	
B00A - R0012 - Home Base - (62.11 SQM) - Teaching Space: 1	 Student Space (28)	
B00A - R0013 - Practical Activities - 1hb - (42.65 SQM)	 Student Space (19)	
B00A - R0014 - Withdrawal Space - 1hb - (12.54 SQM)	 Student Space (5)	
B00A - R0015 - Home Base - (61.38 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R0001 - Movement - (23.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Practical Activities - 1hb - (18.36 SQM)	 Student Space (8)	
B00B - R0003 - Home Base - (51.72 SQM) - Teaching Space: 1	 Student Space (23)	
B00B - R0005 - Withdrawal Space - 1hb - (10.26 SQM)	 Student Space (4)	
B00E - R0001 - Withdrawal Space - 1hb - (30.48 SQM)	 Student Space (14)	
B00H - R0001 - Movement - (34.56 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities - 1hb - (15.95 SQM)	 Student Space (7)	
B00H - R0003 - Home Base - (61.65 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0005 - Movement - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Withdrawal Space - 1hb - (11.89 SQM)	 Student Space (5)	
B00H - R0007 - Movement - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Home Base - (61.65 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0010 - Practical Activities - 1hb - (15.89 SQM)	 Student Space (7)	
B00J - R0001 - Movement - (31.19 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Reading Area - (91.95 SQM)	 Student Space (42)	
B00K - R0002 - Communal Space - (148.34 SQM)	 Student Space (68)	
OS 606 14651 - OS 606 14651 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19035 - OS 606 19035 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	