

VENTILATION AUDIT REPORT

SCHOOL:	Edensor Park Public School (4583)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Cabramatta
LOCAL GOVERNMENT AREA:	Fairfield

4583 - Edensor Park Public School
Site Plan (10354)



1:1,102

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Staff Room Annexe - (12.46 SQM)	Office (3)	
B00A - R0004 - Staff Room - (59.13 SQM)	Office (14)	
B00A - R0005 - Staff Room Annexe - (27.26 SQM)	Office (6)	
B00A - R0008 - Sick Bay - (8.5 SQM)	Student Space (3)	
B00A - R0009 - Clerical Office - (16.99 SQM)	Office (4)	
B00A - R0010 - Duplicating Workroom - (32.33 SQM)	Office (8)	
B00A - R0011 - Entry Vestibule - (23.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Principal - (19.46 SQM)	Office (4)	
B00A - R0018 - Interview - (12.9 SQM)	Office (3)	
B00A - R0019 - Staff Room Annexe - (13.02 SQM)	Office (3)	
B00A - R0020 - Movement - (34.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (28.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Entry Vestibule - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (52.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (60.91 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0005 - Practical Activities - 1hb - (19.24 SQM)	Student Space (8)	
B00B - R0006 - Withdrawal Space - 1hb - (5.71 SQM)	Student Space (2)	
B00B - R0008 - Movement - (5.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Home Base - (61.31 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0012 - Withdrawal Space - 1hb - (12.2 SQM)	Student Space (5)	
B00B - R0013 - Movement - (13.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Home Base - (60.84 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0017 - Practical Activities - 1hb - (18.33 SQM)	Student Space (8)	
B00B - R0018 - Practical Activities - 1hb - (18.32 SQM)	Student Space (8)	
B00B - R0019 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Home Base - (59.66 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0023 - Withdrawal Space - 1hb - (12.13 SQM)	Student Space (5)	
B00B - R0024 - Home Base - (60.04 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0026 - Practical Activities - 1hb - (34.88 SQM)	Student Space (16)	
B00B - R0030 - Home Base - (60.12 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0032 - Withdrawal Space - 1hb - (12.17 SQM)	Student Space (5)	
B00B - R0033 - Movement - (13.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Home Base - (60.12 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0035 - Practical Activities - 1hb - (34.8 SQM)	Student Space (16)	
B00B - R0039 - Movement - (188.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0040 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (59.89 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0005 - Withdrawal Space - 1hb - (12.1 SQM)	Student Space (5)	
B00C - R0007 - Home Base - (59.89 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0010 - Practical Activities - 1hb - (35.09 SQM)	Student Space (16)	
B00C - R0014 - Home Base - (59.89 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0015 - Withdrawal Space - 1hb - (12.13 SQM)	Student Space (5)	
B00C - R0016 - Home Base - (59.97 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0019 - Practical Activities - 1hb - (34.88 SQM)	Student Space (16)	
B00C - R0023 - Home Base - (61.07 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0024 - Withdrawal Space - 1hb - (12.13 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0025 - Home Base - (60.92 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0028 - Practical Activities - 1hb - (18.13 SQM)	● Student Space (8)	
B00C - R0029 - Practical Activities - 1hb - (17.55 SQM)	● Student Space (8)	
B00C - R0033 - Home Base - (60.92 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0035 - Withdrawal Space - 1hb - (5.76 SQM)	● Student Space (2)	
B00C - R0036 - Practical Activities - 1hb - (19.31 SQM)	● Student Space (8)	
B00C - R0043 - Movement - (231.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Reading Area - (33.99 SQM)	● Student Space (15)	
B00D - R0005 - Reading Area - (183 SQM)	● Student Space (84)	
B00D - R0008 - Special Programs Room - (42.62 SQM)	● Student Space (19)	
B00D - R0013 - Movement - (126.13 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Canteen - (43.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (39.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Communal Space - (199.51 SQM)	● Student Space (92)	
B00F - R0002 - Raised Platform - (38.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (9.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (5.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Movement - (5.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0023 - Movement - (107.7 SQM)	Not Applicable	Circulation or storage space.