

# VENTILATION AUDIT REPORT













<b>SCHOOL:</b>	<b>Edgware School (5737)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Canterbury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canterbury-Bankstown</b>

5737 - Edgware School  
Site Plan (13081)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (5.73 SQM)	 Office (1)	
B00A - R0002 - Staff Room Annexe - (8.12 SQM)	 Office (2)	
B00A - R0003 - Home Base - (48.17 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0004 - Home Base - (47.61 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0005 - Staff Room - (47.55 SQM)	 Office (11)	
B00A - R0006 - Movement - (53.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Canteen - (9.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (11.36 SQM)	 Student Space (5)	
B00B - R0002 - Home Base - (34.35 SQM) - Teaching Space: 1	 Student Space (15)	
B00E - R0001 - Movement - (12.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (16.34 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Home Base - (53.12 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R0001 - Communal Space - (87.66 SQM)	 Student Space (40)	
B00I - R0002 - Home Base - (60.48 SQM) - Teaching Space: 1	 Student Space (28)	
OS 505 13639 - OS 505 13639 - Admin Staff/Principal/Secure Store - (76 SQM)	 Office (19)	
OS 601 14830 - OS 601 14830 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	