

VENTILATION AUDIT REPORT





























SCHOOL:	Edgeworth Heights Public School (4155)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Cessnock
LOCAL GOVERNMENT AREA:	Lake Macquarie











4155 - Edgeworth Heights Public School
Site Plan (11745)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (30.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Staff Room Annexe - (13.54 SQM)	 Office (3)	
B00A - R0003 - Interview - (13.51 SQM)	 Office (3)	
B00A - R0005 - Movement - (19.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Staff Room Annexe - (13.23 SQM)	 Office (3)	
B00A - R0008 - Principal - (17.43 SQM)	 Office (4)	
B00A - R0010 - Entry Vestibule - (10.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Clerical Office - (17.64 SQM)	 Office (4)	
B00A - R0012 - Duplicating Workroom - (22.37 SQM)	 Office (5)	
B00A - R0014 - Sick Bay - (9.02 SQM)	 Student Space (4)	
B00B - R0001 - Movement - (15.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (7.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (59.9 SQM) - Teaching Space: 1	 Student Space (27)	
B00D - R0004 - Practical Activities - 1hb - (21.12 SQM)	 Student Space (9)	
B00D - R0005 - Home Base - (59.98 SQM) - Teaching Space: 1	 Student Space (27)	
B00D - R0007 - Withdrawal Space - 1hb - (16.3 SQM)	 Student Space (7)	
B00D - R0008 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (28.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (52.23 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R0003 - Practical Activities - 1hb - (21.8 SQM)	 Student Space (10)	
B00E - R0004 - Home Base - (52.08 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R0005 - Withdrawal Space - 1hb - (14.78 SQM)	 Student Space (6)	
B00E - R0009 - Movement - (7.55 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (6.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Home Base - (53.4 SQM) - Teaching Space: 1	 Student Space (24)	
B00F - R0003 - Practical Activities - 1hb - (24.22 SQM)	 Student Space (11)	
B00F - R0004 - Home Base - (53.4 SQM) - Teaching Space: 1	 Student Space (24)	
B00F - R0005 - Withdrawal Space - 1hb - (14.62 SQM)	 Student Space (6)	
B00F - R0009 - Movement - (6.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (53.19 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R0003 - Movement - (81.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Home Base - (53.34 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R0006 - Withdrawal Space - 1hb - (30.39 SQM)	 Student Space (14)	
B00G - R0007 - Home Base - (53.47 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R0008 - Home Base - (53.41 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R0009 - Reading Area - (53.18 SQM)	 Student Space (24)	
B00G - R0010 - Reading Area - (88.26 SQM)	 Student Space (40)	
B00H - R0001 - Movement - (19.06 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Communal Space - (143.77 SQM)	 Student Space (66)	
B00I - R0003 - Movement - (5.59 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Raised Platform - (62.18 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Movement - (11.28 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Movement - (13.54 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Staff Room Annexe - (18.92 SQM)	 Office (4)	
B00J - R0002 - Staff Room - (47.61 SQM)	 Office (11)	
B00J - R0005 - Movement - (16.58 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Special Programs Room - Type 1 - (31.69 SQM)	 Student Space (14)	
B00K - R0001 - Home Base - (79.72 SQM)	 Student Space (36)	
B00K - R0004 - Withdrawal Space - 2hb - (16.66 SQM)	 Student Space (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0005 - Home Base - (79.72 SQM)	 Student Space (36)	
B00K - R0007 - Home Base - (61.87 SQM) - Teaching Space: 1	 Student Space (28)	
B00K - R0008 - Practical Activities - (17.58 SQM)	 Student Space (8)	
B00K - R0009 - Home Base - (61.87 SQM) - Teaching Space: 1	 Student Space (28)	
B00K - R0010 - Practical Activities - (17.58 SQM)	 Student Space (8)	
B00L - R0002 - Canteen - (51.79 SQM)	Not Applicable	Circulation or storage space.
OS 602 11837 - OS 602 11837 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13045 - OS 602 13045 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13260 - OS 602 13260 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14864 - OS 602 14864 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 15626 - OS 603 15626 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	