

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Eglinton Public School (1823)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Bathurst</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bathurst</b>

1823 - Eglinton Public School  
Site Plan (10961)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (47.2 SQM)	Office (11)	
B00A - R0002 - Staff Room Annexe - (19.36 SQM)	Office (4)	
B00A - R0006 - Principal - (17.35 SQM)	Office (4)	
B00A - R0009 - Sick Bay - (10.01 SQM)	Student Space (4)	
B00A - R0011 - Duplicating Workroom - (20.88 SQM)	Office (5)	
B00A - R0013 - Movement - (28.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Entry Vestibule - (14.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Deputy Principal - (13.44 SQM)	Office (3)	
B00A - R0017 - Deputy Principal - (13.47 SQM)	Office (3)	
B00A - R0018 - Interview - (13.47 SQM)	Office (3)	
B00A - R0019 - Clerical Office - (18.05 SQM)	Office (4)	
B00B - R0001 - Practical Activities - 1hb - (18.64 SQM)	Student Space (8)	
B00B - R0002 - Home Base - (62.26 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0004 - Withdrawal Space - 1hb - (6.02 SQM)	Student Space (2)	
B00B - R0008 - Practical Activities - 1hb - (18.68 SQM)	Student Space (8)	
B00B - R0009 - Home Base - (62.43 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0011 - Withdrawal Space - 1hb - (6.02 SQM)	Student Space (2)	
B00C - R0001 - Practical Activities - 1hb - (18.44 SQM)	Student Space (8)	
B00C - R0002 - Home Base - (62.59 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R0004 - Withdrawal Space - 1hb - (6.05 SQM)	Student Space (2)	
B00C - R0007 - Practical Activities - 1hb - (18.51 SQM)	Student Space (8)	
B00C - R0008 - Home Base - (62.43 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0010 - Withdrawal Space - 1hb - (6.01 SQM)	Student Space (2)	
B00D - R0001 - Practical Activities - 1hb - (18.46 SQM)	Student Space (8)	
B00D - R0002 - Home Base - (62.89 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0004 - Withdrawal Space - 1hb - (6.03 SQM)	Student Space (2)	
B00D - R0008 - Practical Activities - 1hb - (18.61 SQM)	Student Space (8)	
B00D - R0009 - Home Base - (62.5 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0011 - Withdrawal Space - 1hb - (6.01 SQM)	Student Space (2)	
B00E - R0001 - Practical Activities - 1hb - (18.61 SQM)	Student Space (8)	
B00E - R0002 - Home Base - (62.34 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0004 - Withdrawal Space - 1hb - (5.99 SQM)	Student Space (2)	
B00E - R0007 - Practical Activities - 1hb - (18.59 SQM)	Student Space (8)	
B00E - R0008 - Home Base - (62.42 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0010 - Withdrawal Space - 1hb - (6.07 SQM)	Student Space (2)	
B00F - R0004 - Movement - (5.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Practical Activities - 1hb - (25.86 SQM)	Student Space (11)	
B00F - R0006 - Home Base - (74.3 SQM) - Teaching Space: 1	Student Space (34)	
B00F - R0008 - Withdrawal Space - 1hb - (8.34 SQM)	Student Space (3)	
B00F - R0009 - Practical Activities - 1hb - (25.86 SQM)	Student Space (11)	
B00F - R0010 - Home Base - (74.25 SQM) - Teaching Space: 1	Student Space (34)	
B00F - R0012 - Withdrawal Space - 1hb - (8.37 SQM)	Student Space (3)	
B00G - R0001 - Reading Area - (165.66 SQM)	Student Space (76)	
B00G - R0002 - Special Programs Room - (33.94 SQM)	Student Space (15)	
B00H - R0005 - Canteen - (27.71 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Communal Space - (135.36 SQM)	Student Space (62)	
B00H - R0008 - Raised Platform - (53.29 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0014 - Movement - (5.73 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Special Programs Room - (73.49 SQM)	● Student Space (34)	
B00M - R0004 - Practical Activities - 1hb - (19.75 SQM)	● Student Space (9)	
B00M - R0006 - Home Base - (60.76 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0007 - Withdrawal Space - 2hb - (11.8 SQM)	● Student Space (5)	
B00M - R0008 - Home Base - (60.88 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0010 - Practical Activities - 1hb - (19.88 SQM)	● Student Space (9)	
B00M - R0011 - Practical Activities - 1hb - (19.91 SQM)	● Student Space (9)	
B00M - R0013 - Home Base - (60.97 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0014 - Withdrawal Space - 2hb - (11.79 SQM)	● Student Space (5)	
B00M - R0015 - Home Base - (60.63 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0017 - Practical Activities - 1hb - (19.83 SQM)	● Student Space (9)	
B00N - R0001 - Home Base - (60.64 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0003 - Practical Activities - 1hb - (19.79 SQM)	● Student Space (9)	
B00N - R0004 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00N - R0005 - Practical Activities - 1hb - (19.79 SQM)	● Student Space (9)	
B00N - R0007 - Home Base - (60.64 SQM) - Teaching Space: 1	● Student Space (28)	
OH 060 17050 - OH 060 17050 - OSHC Hub 60 - ( SQM)	● Student Space ( )	
OS 523 15501 - OS 523 15501 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 602 10364 - OS 602 10364 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13436 - OS 602 13436 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10547 - OS 603 10547 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 11682 - OS 603 11682 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 10107 - OS 606 10107 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 11938 - OS 606 11938 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	