

VENTILATION AUDIT REPORT

SCHOOL:	Elanora Heights Public School (4199)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Pittwater
LOCAL GOVERNMENT AREA:	Northern Beaches

4199 - Elanora Heights Public School
Site Plan (10355)



1:1,667

Printed: 18-Sep-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Clerical Office - (11.95 SQM)	Office (2)	
B00A - R0006 - Principal - (22.81 SQM)	Office (5)	
B00A - R0007 - Sick Bay - (7.72 SQM)	Student Space (3)	
B00A - R0008 - Clerical Office - (11.38 SQM)	Office (2)	
B00A - R0009 - Entry Vestibule - (12.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (5.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Deputy Principal - (13.72 SQM)	Office (3)	
B00A - R0012 - Interview - (16.02 SQM)	Office (4)	
B00A - R0013 - Duplicating Workroom - (11.52 SQM)	Office (2)	
B00A - R0014 - Staff Room - (93.99 SQM)	Office (23)	
B00A - R0018 - Staff Room Annexe - (15.2 SQM)	Office (3)	
B00A - R0019 - Movement - (46.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (46.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R9004 - Movement - (11.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R9005 - Seminar/Study - (17.8 SQM)	Office (4)	
B00A - R9006 - Seminar/Study - (17 SQM)	Office (4)	
B00A - R9009 - Reading Area - (266.65 SQM)	Student Space (123)	
B00A - R9010 - Movement - (48.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (57.31 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0007 - Movement - (16.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (8.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Home Base - (56.76 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0012 - Home Base - (56.6 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0017 - Movement - (9.85 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (5.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Home Base - (56.68 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0004 - Movement - (6.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (56.61 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0009 - Home Base - (56.61 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0012 - Interview - (13.99 SQM)	Office (3)	
B00E - R0016 - Movement - (19.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Home Base - (56.61 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0008 - Home Base - (56.8 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0011 - Movement - (6.32 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Home Base - (57.04 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0022 - Special Programs Room - (90.73 SQM)	Student Space (42)	
B00F - R9001 - Special Programs Room - (39.26 SQM)	Student Space (18)	
B00F - R9005 - Special Programs Room - (32.16 SQM)	Student Space (14)	
B00F - R9006 - Reading Area - (70.77 SQM)	Student Space (32)	
B00F - R9008 - Withdrawal Space - 1hb - (56.54 SQM)	Student Space (26)	
B00G - R0002 - Communal Space - (243.24 SQM)	Student Space (112)	
B00G - R0004 - Raised Platform - (60.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Canteen - (45.33 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Movement - (66.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R9003 - Movement - (19.23 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (57.5 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0002 - Practical Activities - 1hb - (22.63 SQM)	Student Space (10)	
B00H - R0005 - Movement - (20.67 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Home Base - (46.72 SQM) - Teaching Space: 1	Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0007 - Practical Activities - 1hb - (19.03 SQM)	● Student Space (8)	
B00H - R0008 - Home Base - (64.7 SQM) - Teaching Space: 1	● Student Space (30)	
B00H - R0010 - Home Base - (64.16 SQM) - Teaching Space: 1	● Student Space (29)	
B00H - R0013 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Home Base - (64.7 SQM) - Teaching Space: 1	● Student Space (30)	
B00H - R0015 - Home Base - (64.43 SQM) - Teaching Space: 1	● Student Space (29)	
B00H - R0017 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Movement - (69.94 SQM)	Not Applicable	Circulation or storage space.
B00H - R9001 - Movement - (50.09 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (5.13 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Movement - (10.87 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Practical Activities - 1hb - (16.16 SQM)	● Student Space (7)	
B00J - R0008 - Home Base - (68.29 SQM) - Teaching Space: 1	● Student Space (31)	
B00J - R0009 - Home Base - (48.86 SQM) - Teaching Space: 1	● Student Space (22)	
B00J - R0010 - Practical Activities - 1hb - (22.24 SQM)	● Student Space (10)	
B00J - R0011 - Movement - (5.08 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (194.4 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Practical Activities - 1hb - (18.86 SQM)	● Student Space (8)	
B00L - R0002 - Home Base - (60.42 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R0004 - Withdrawal Space - 2hb - (11.52 SQM)	● Student Space (5)	
B00L - R0005 - Practical Activities - 1hb - (19.45 SQM)	● Student Space (9)	
B00L - R0006 - Home Base - (60.42 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R0008 - Practical Activities - 1hb - (18.91 SQM)	● Student Space (8)	
B00L - R0009 - Home Base - (60.81 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R0011 - Withdrawal Space - 2hb - (11.48 SQM)	● Student Space (5)	
B00L - R0012 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00L - R0013 - Home Base - (60.44 SQM) - Teaching Space: 1	● Student Space (28)	
OS 602 10690 - OS 602 10690 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12590 - OS 602 12590 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14940 - OS 602 14940 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	