


VENTILATION AUDIT REPORT

SCHOOL:	Elderslie High School (8521)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Camden
LOCAL GOVERNMENT AREA:	Camden

8521 - Elderslie High School
Site Plan (10356)



1:1,533













Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Principal Office - (25.3 SQM)	Office (6)	
B00A - R0007 - Leading Teacher - (13.03 SQM)	Office (3)	
B00A - R0020 - Laboratory L.S. - (91.17 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0021 - Preparation - Science - (48.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Laboratory L.S. - (91.07 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0024 - Staff Study - (32.12 SQM)	Office (8)	
B00A - R0028 - Performance Workshop - (93.17 SQM)	Student Space (43)	
B00A - R0047 - Commonroom - (108.39 SQM)	Office (27)	
B00A - R0048 - Staff Kitchen - (17.5 SQM)	Office (4)	
B00A - R0053 - Public Entry - (7.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Public Reception - (14.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Administration - Clerical - (73.02 SQM)	Office (18)	
B00A - R0058 - Interview/Meeting - (12.04 SQM)	Office (3)	
B00A - R0059 - Student Waiting - (21.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - Interview/Meeting - (14.33 SQM)	Office (3)	
B00A - R0062 - Deputy Principal Office - (12.16 SQM)	Office (3)	
B00A - R0063 - Interview/Meeting - (8.81 SQM)	Office (2)	
B00A - R0064 - Deputy Principal Office - (13.4 SQM)	Office (3)	
B00A - R0065 - Movement - (68.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (52.79 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1002 - General Learning Space - (52.57 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1004 - General Learning Space - (52.33 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1005 - General Learning Space - (52.36 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1007 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1008 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1009 - Staff Study - (33.02 SQM)	Office (8)	
B00A - R1010 - Senior Seminar - (13.07 SQM)	Office (3)	
B00A - R1011 - Computer Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1012 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1017 - Laboratory L.S. - (90.5 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R1018 - Preparation - Science - (46.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Laboratory L.S. - (90.79 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1021 - Staff Study - (23.49 SQM)	Office (5)	
B00B - R0001 - Multi-Purpose Space - (453.65 SQM)	Student Space (210)	
B00B - R0010 - Student Canteen - (46.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Metal Technology Bay - (35.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Art Learning Space - (59.58 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0029 - Art Learning Space - (82.52 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R0030 - Art Learning Space - (81.97 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R0050 - Stage - (98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0051 - Movement - (12.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0053 - Metal Technology L.S. - (70.72 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R0055 - Metal Technology L.S. - (74.16 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0057 - Welding Area - (13.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0058 - Staff Study - (32.53 SQM)	Office (8)	
B00B - R0062 - Dark Room - (16 SQM)	Office (4)	
B00B - R1004 - Music Learning Space - (80.52 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R1006 - Fitness Laboratory - (78.76 SQM)	Student Space (36)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1008 - Food Technology L.S. - (99.22 SQM) - Teaching Space: 1	● Student Space (46)	
B00B - R1009 - Preparation - Materials - (16.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Preparation - Materials - (10.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Food Technology L.S. - (100.41 SQM) - Teaching Space: 1	● Student Space (46)	
B00B - R1017 - Wood Technology Bay - (12.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R1020 - Textiles Technology L.S. - (66.03 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1022 - Textiles Technology L.S. - (65.9 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1028 - Staff Study - (40.21 SQM)	○ Office (10)	
B00B - R1029 - Computer Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1031 - Computer Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1040 - Wood Technology L.S. - (80.15 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1042 - Wood Technology L.S. - (80.91 SQM) - Teaching Space: 1	● Student Space (37)	
B00C - M0001 - Main Area - (79.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Study Space - (8.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Study Space - (12.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Interview/Meeting - (8.83 SQM)	○ Office (2)	
B00C - R0016 - Main Entry - (33.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Main Area - (230.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Senior Study - (95.81 SQM)	○ Office (23)	
B00C - R1004 - Staff Study - (45.34 SQM)	○ Office (11)	
B00D - R0005 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0006 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0008 - Staff Study - (47.28 SQM)	○ Office (11)	
B00D - R0010 - General Learning Space - (50.63 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0011 - General Learning Space - (66.86 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0012 - General Learning Space - (51.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1002 - Interview/Office - Type 1 - (11.85 SQM)	○ Office (2)	
B00D - R1005 - General Learning Space - (51.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1006 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1008 - Staff Study - (31.12 SQM)	○ Office (7)	
B00D - R1012 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1013 - General Learning Space - (65.13 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1014 - General Learning Space - (51.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0004 - Staff Study - (23.54 SQM)	○ Office (5)	
B00E - R0005 - Laboratory L.S. - (88.66 SQM) - Teaching Space: 1	● Student Space (41)	
B00E - R0006 - Preparation - Science - (47.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Laboratory L.S. - (89.94 SQM) - Teaching Space: 1	● Student Space (41)	
B00E - R1001 - Staff Study - (31.82 SQM)	○ Office (7)	
B00E - R1003 - Music Learning Space - (65.05 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1004 - General Learning Space - (65.03 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1005 - General Learning Space - (64.7 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1007 - General Learning Space - (64.5 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R0005 - Growing/Breeding - (19.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Outdoor Learning Area - (56.95 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - General Assistants - (28.64 SQM)	○ Office (7)	
B00G - R0002 - General Assistants - (15.12 SQM)	○ Office (3)	
B00H - R0002 - Staff Study - (73.92 SQM)	○ Office (18)	
B00H - R0004 - General Learning Space - (58.49 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0005 - General Learning Space - (58.55 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0006 - General Learning Space - (59.09 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0007 - General Learning Space - (59.07 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R1002 - General Learning Space - (74.18 SQM) - Teaching Space: 1	 Student Space (34)	
B00H - R1004 - General Learning Space - (58.72 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R1005 - General Learning Space - (58.94 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R1006 - General Learning Space - (59.11 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R1007 - General Learning Space - (59.03 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R0001 - Wood Technology L.S. - (141.46 SQM) - Teaching Space: 1	 Student Space (65)	
B00I - R0004 - Outdoor Learning Area - (48.02 SQM)	Not Applicable	Circulation or storage space.
OS 601 14167 - OS 601 14167 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14543 - OS 601 14543 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 15220 - OS 601 15220 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	