

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Ellison Public School (4568)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Blue Mountains</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blue Mountains</b>

4568 - Ellison Public School  
Site Plan (10362)













1:941

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Interview - (12.74 SQM)	Office (3)	
B00A - R0002 - Entry Vestibule - (14.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Sick Bay - (9.81 SQM)	Student Space (4)	
B00A - R0006 - Movement - (29.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Principal - (17.39 SQM)	Office (4)	
B00A - R0009 - Deputy Principal - (12.73 SQM)	Office (3)	
B00A - R0010 - Deputy Principal - (12.73 SQM)	Office (3)	
B00A - R0012 - Staff Room - (49.63 SQM)	Office (12)	
B00A - R0013 - Staff Room Annexe - (17.5 SQM)	Office (4)	
B00A - R0017 - Clerical Office - (14.13 SQM)	Office (3)	
B00A - R0019 - Duplicating Workroom - (21.63 SQM)	Office (5)	
B00B - R0008 - Communal Space - (135.74 SQM)	Student Space (62)	
B00B - R0012 - Canteen - (26.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Raised Platform - (38.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Reading Area - (76.64 SQM)	Student Space (35)	
B00C - R0002 - Reading Area - (78.34 SQM)	Student Space (36)	
B00C - R0005 - Special Programs Room - (32.95 SQM)	Student Space (15)	
B00D - R0003 - Home Base - (60.35 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0004 - Movement - (16.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Withdrawal Space - 1hb - (12.09 SQM)	Student Space (5)	
B00D - R0006 - Movement - (32.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Home Base - (60.9 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0009 - Practical Activities - 1hb - (39.41 SQM)	Student Space (18)	
B00D - R0013 - Home Base - (60.36 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0014 - Withdrawal Space - 1hb - (12 SQM)	Student Space (5)	
B00D - R0015 - Movement - (16.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Home Base - (60.9 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0018 - Practical Activities - 1hb - (42.24 SQM)	Student Space (19)	
B00D - R9001 - Movement - (16.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R9003 - Movement - (32.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R9005 - Movement - (16.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (6.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (60.32 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0004 - Movement - (16.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Withdrawal Space - 1hb - (11.95 SQM)	Student Space (5)	
B00E - R0006 - Movement - (17.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Home Base - (60.67 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0009 - Practical Activities - 1hb - (44.79 SQM)	Student Space (20)	
B00E - R0011 - Movement - (6 SQM)	Not Applicable	Circulation or storage space.
B00E - R9001 - Movement - (16.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R9003 - Movement - (16.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Home Base - (60.54 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0005 - Movement - (17 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Withdrawal Space - 1hb - (12.23 SQM)	Student Space (5)	
B00F - R0007 - Movement - (32.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (60.54 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0010 - Practical Activities - 1hb - (42.19 SQM)	Student Space (19)	
B00F - R0014 - Home Base - (60.55 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0015 - Withdrawal Space - 1hb - (12.23 SQM)	Student Space (5)	
B00F - R0016 - Movement - (16.94 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0017 - Home Base - (60.54 SQM) - Teaching Space: 1	 Student Space (28)	
B00F - R0019 - Practical Activities - 1hb - (40.06 SQM)	 Student Space (18)	
B00F - R9001 - Movement - (16.68 SQM)	Not Applicable	Circulation or storage space.
B00F - R9002 - Movement - (32.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R9003 - Movement - (16.59 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Practical Activities - 1hb - (18.29 SQM)	 Student Space (8)	
B00H - R0003 - Home Base - (59.77 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0004 - Withdrawal Space - 2hb - (11.18 SQM)	 Student Space (5)	
B00H - R0005 - Home Base - (60 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0007 - Practical Activities - 1hb - (18.32 SQM)	 Student Space (8)	
B00H - R0008 - Home Base - (58.32 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0010 - Withdrawal Space - 1hb - (8.68 SQM)	 Student Space (4)	
B00H - R0011 - Practical Activities - 1hb - (18.67 SQM)	 Student Space (8)	