

VENTILATION AUDIT REPORT

SCHOOL:	Emmaville Central School (1838)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Glen Innes Severn

1838 - Emmaville Central School
Site Plan (12499)




























1:1,132

Printed: 17-Nov-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (17.64 SQM)	 Office (4)	
B00A - R0004 - Principal - (18.22 SQM)	 Office (4)	
B00A - R0005 - Public Entry - (10.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Clerical Office/Workroom - (27.25 SQM)	 Office (6)	
B00A - R0007 - Sick Bay - (5.79 SQM)	 Student Space (2)	
B00A - R0008 - Food Technology L.S. - (64.77 SQM) - Teaching Space: 1	 Student Space (30)	
B00A - R0011 - Preparation - (18.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Laboratory L.S. - (53.61 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0014 - Art Learning Space - (33.82 SQM) - Teaching Space: 1	 Student Space (15)	
B00B - R0001 - Staff Room - (44.05 SQM)	 Office (11)	
B00B - R0003 - General Learning Space - (47.04 SQM) - Teaching Space: 1	 Student Space (21)	
B00B - R0004 - Staff Room Annexe - (11.72 SQM)	 Office (2)	
B00B - R0005 - General Learning Space - (47.03 SQM) - Teaching Space: 1	 Student Space (21)	
B00B - R0006 - Movement - (7.73 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Computer Learning Space - (60.33 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0007 - Reading Area - (46.6 SQM)	 Student Space (21)	
B00E - R0008 - Reading Area - (34.9 SQM)	 Student Space (16)	
B00F - R0001 - Movement - (24.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Multi-Purpose Space - (91.76 SQM)	 Student Space (42)	
B00F - R0008 - Canteen - (15.3 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Staff Room Annexe - (12.13 SQM)	 Office (3)	
B00H - R0002 - Home Base - (47.87 SQM) - Teaching Space: 1	 Student Space (22)	
B00H - R0004 - Home Base - (45.37 SQM) - Teaching Space: 1	 Student Space (21)	
B00H - R0005 - Home Base - (45.56 SQM) - Teaching Space: 1	 Student Space (21)	
B00H - R0006 - Special Programs Room - (45.56 SQM)	 Student Space (21)	
B00H - R0009 - Movement - (62.4 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (11.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Staff Room Annexe - (6.7 SQM)	 Office (1)	
B00H - R0012 - General Learning Space - (44.9 SQM) - Teaching Space: 1	 Student Space (20)	
B00L - R0002 - Reading Area - (61.33 SQM)	 Student Space (28)	
B00M - R0001 - Workshop Area - (220.18 SQM)	 Student Space (102)	
B00O - R0001 - Gymnasium - (68.47 SQM)	 Student Space (31)	
OS 780 10978 - OS 780 10978 - Woodwork/Metalwork/Heat Area/Store - (114 SQM)	Not Applicable	Circulation or storage space.