

VENTILATION AUDIT REPORT

SCHOOL:	Emu Plains Public School (1841)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Penrith
LOCAL GOVERNMENT AREA:	Penrith

1841 - Emu Plains Public School
Site Plan (12503)



1:986

Printed: 23-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (109.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Practical Activities - 1hb - (12.62 SQM)	● Student Space (5)	
B00A - R0003 - Home Base - (52.81 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0004 - Withdrawal Space - 1hb - (12.9 SQM)	● Student Space (5)	
B00A - R0005 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Home Base - (52.81 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0010 - Withdrawal Space - 1hb - (12.83 SQM)	● Student Space (5)	
B00A - R0011 - Practical Activities - 1hb - (12.4 SQM)	● Student Space (5)	
B00B - R0001 - Movement - (194.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Reading Area - (77.11 SQM)	● Student Space (35)	
B00B - R0006 - Reading Area - (156.56 SQM)	● Student Space (72)	
B00B - R0011 - Movement - (13.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Seminar/Study - (10.84 SQM)	● Office (2)	
B00B - R0013 - Seminar/Study - (13.84 SQM)	● Office (3)	
B00C - R0001 - Movement - (225.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Canteen - (40.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Communal Space - (233.72 SQM)	● Student Space (108)	
B00C - R0018 - Raised Platform - (45.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (141.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (12.18 SQM)	● Student Space (5)	
B00D - R0003 - Home Base - (54.19 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0005 - Withdrawal Space - 1hb - (8.18 SQM)	● Student Space (3)	
B00D - R0006 - Movement - (5.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (54.41 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0011 - Withdrawal Space - 1hb - (8.23 SQM)	● Student Space (3)	
B00D - R0013 - Practical Activities - 1hb - (12.18 SQM)	● Student Space (5)	
B00E - R0001 - Movement - (158.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Principal - (20.35 SQM)	● Office (5)	
B00E - R0006 - Deputy Principal - (12.44 SQM)	● Office (3)	
B00E - R0007 - Sick Bay - (8.22 SQM)	● Student Space (3)	
B00E - R0008 - Clerical Office/Workroom - (12.15 SQM)	● Office (3)	
B00E - R0014 - Duplicating Workroom - (10.68 SQM)	● Office (2)	
B00E - R0015 - Clerical Office - (12.49 SQM)	● Office (3)	
B00E - R0016 - Entry Vestibule - (21.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Deputy Principal - (11.84 SQM)	● Office (2)	
B00E - R0018 - Movement - (13.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Staff Room - (45.62 SQM)	● Office (11)	
B00E - R1002 - Staff Kitchen - (8.5 SQM)	● Office (2)	
B00F - R0002 - Practical Activities - 1hb - (9.13 SQM)	● Student Space (4)	
B00F - R0003 - Home Base - (60.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0004 - Withdrawal Space - 1hb - (6.44 SQM)	● Student Space (2)	
B00F - R0009 - Home Base - (57.34 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0012 - Movement - (6.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0015 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0020 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0021 - Movement - (80 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Withdrawal Space - 2hb - (14.73 SQM)	● Student Space (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0001 - Movement - (44.13 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (33.71 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0006 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0001 - Home Base - (63.99 SQM) - Teaching Space: 1	● Student Space (29)	
B00I - R0005 - Home Base - (56.89 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0009 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0010 - Movement - (59.92 SQM)	Not Applicable	Circulation or storage space.
B00I - R0011 - Practical Activities - 1hb - (11.6 SQM)	● Student Space (5)	
B00J - R0002 - Home Base - (65.8 SQM) - Teaching Space: 1	● Student Space (30)	
B00J - R0003 - Practical Activities - 1hb - (11.36 SQM)	● Student Space (5)	
B00J - R0004 - Interview - (8.58 SQM)	● Office (2)	
B00J - R0007 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0010 - Movement - (6.64 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0013 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0015 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0019 - Movement - (79.83 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (46.69 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Home Base - (56.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00L - R0010 - Home Base - (85.78 SQM) - Teaching Space: 1	● Student Space (39)	
OS 621 18203 - OS 621 18203 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	