

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Endeavour Sports High School (8404)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Miranda</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

8404 - Endeavour Sports High School  
Site Plan (10963)



1:1,821

Printed: 04-Sep-2021



















## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Movement - (119.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Food Technology L.S. - (66.19 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0011 - Food/Research Space - (12.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Food Technology L.S. - (65.62 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0016 - Movement - (58.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Staff Study - (25.35 SQM)	● Office (6)	
B00A - R0024 - Laboratory L.S. - (86.12 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R0025 - Preparation - (28.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Laboratory L.S. - (86.06 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R0030 - Staff Study - (6.34 SQM)	● Office (1)	
B00A - R0032 - Gymnasium - (100.84 SQM)	● Student Space (46)	
B00A - R0036 - Food/Research Space - (37.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Staff Study - (34.76 SQM)	● Office (8)	
B00A - R1005 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Performance Workspace - (79.37 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R1008 - Performance Workspace - (52.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1009 - Senior Seminar - (52.65 SQM)	● Office (13)	
B00A - R1014 - Interview/Office - Type 1 - (11.33 SQM)	● Office (2)	
B00A - R1017 - Staff Study - (25.32 SQM)	● Office (6)	
B00A - R1018 - General Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1021 - General Learning Space - (65.72 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1022 - Laboratory L.S. - (79.09 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R1023 - Preparation - (8.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R1027 - Movement - (160.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R1028 - Staff Study - (12.52 SQM)	● Office (3)	
B00B - R0006 - Movement - (17.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Student Canteen - (40.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (16.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Movement - (321.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (138.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Movement - (9.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (122.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Materials Technology L.S. - (88.3 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0008 - Materials Technology L.S. - (79.26 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R0010 - Practice/Seminar - (24.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Materials Technology L.S. - (99.98 SQM) - Teaching Space: 1	● Student Space (46)	
B00C - R0018 - Materials Technology L.S. - (79.11 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R1001 - Movement - (16.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Movement - (80.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Design L.S. - (52.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1007 - Art Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1008 - Art Learning Space - (52.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1013 - Darkroom Space - (24.87 SQM)	● Office (6)	
B00C - R1015 - Movement - (15.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R1016 - Music Learning Space - (66.08 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1018 - Music Learning Space - (65.79 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1022 - General Learning Space - (93.12 SQM) - Teaching Space: 1	● Student Space (43)	
B00D - R0001 - Commonroom - (57.66 SQM)	● Office (14)	
B00D - R0002 - Interview - (14.89 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0003 - Movement - (14.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (47.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Workroom - (16.16 SQM)	Office (4)	
B00D - R0008 - Workroom - (9.17 SQM)	Office (2)	
B00D - R0010 - Workroom - (12.39 SQM)	Office (3)	
B00D - R0011 - Main Area - (254.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Duplicating Workroom - (26.03 SQM)	Office (6)	
B00D - R0014 - Movement - (62.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Deputy Principal Office - (18.85 SQM)	Office (4)	
B00D - R0023 - Administration - Clerical - (9.44 SQM)	Office (2)	
B00D - R0024 - Administration - Clerical - (9.6 SQM)	Office (2)	
B00D - R0025 - Ancillary Staff - (12.92 SQM)	Office (3)	
B00D - R0028 - Principal Office - (19.47 SQM)	Office (4)	
B00D - R0029 - Administration - Clerical - (19.53 SQM)	Office (4)	
B00D - R0031 - Movement - (63.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R0035 - Movement - (28.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0036 - Clerical Office - (24.91 SQM)	Office (6)	
B00D - R0039 - Interview/Meeting - (26.03 SQM)	Office (6)	
B00D - R0040 - Main Area - (324.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0041 - Movement - (29.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R0042 - Computer Room - (52.72 SQM)	Student Space (24)	
B00D - R0043 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1002 - Movement - (15.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - Art Learning Space - (66.08 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1006 - General Learning Space - (52.43 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1007 - General Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1008 - General Learning Space - (52.57 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1009 - General Learning Space - (52.57 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1010 - Movement - (106.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R1013 - Staff Study - (24.87 SQM)	Office (6)	
B00D - R1016 - General Learning Space - (66.15 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1017 - General Learning Space - (52.2 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1020 - General Learning Space - (52.64 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1021 - Staff Study - (25.85 SQM)	Office (6)	
B00E - R0001 - Laboratory L.S. - (92.98 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0002 - Movement - (128.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Staff Study - (24.93 SQM)	Office (6)	
B00E - R0007 - Staff Study - (52.57 SQM)	Office (13)	
B00E - R0008 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0009 - General Learning Space - (52.57 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0010 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0015 - Seminar - (25.92 SQM)	Office (6)	
B00E - R0017 - Laboratory L.S. - (92.7 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0019 - Preparation - (28.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Movement - (67.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - General Learning Space - (52.71 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1003 - Movement - (121.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R1006 - General Learning Space - (78.28 SQM) - Teaching Space: 1	Student Space (36)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1007 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1008 - General Learning Space - (52.06 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1012 - General Learning Space - (52.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1013 - Staff Study - (25.59 SQM)	● Office (6)	
B00E - R1017 - General Learning Space - (51.25 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1020 - Movement - (54.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R1021 - Movement - (6.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R1022 - General Learning Space - (58.84 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0001 - Movement - (71.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Staff Kitchen - (15.55 SQM)	● Office (3)	
B00F - R0007 - Multi-Purpose Space - (449.98 SQM)	● Student Space (208)	
B00F - R0009 - Stage - (116.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (14.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Staff Study - (52.65 SQM)	● Office (13)	
B00G - R0005 - General Learning Space - (51.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0006 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0008 - Administration - Clerical - (12.68 SQM)	● Office (3)	
B00G - R0012 - Staff Study - (52.58 SQM)	● Office (13)	
B00G - R0013 - General Assistants - (16.82 SQM)	● Office (4)	
B00G - R0014 - Laboratory L.S. - (92.93 SQM) - Teaching Space: 1	● Student Space (43)	
B00G - R0015 - Preparation - (28.68 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Growing/Breeding - (9.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Laboratory L.S. - (92.87 SQM) - Teaching Space: 1	● Student Space (43)	
B00G - R0019 - Computer Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0022 - Movement - (43.56 SQM)	Not Applicable	Circulation or storage space.
B00G - R0025 - Movement - (181.83 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Movement - (16.12 SQM)	Not Applicable	Circulation or storage space.
B00G - R1003 - General Learning Space - (52.42 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1006 - General Learning Space - (52.57 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1007 - General Learning Space - (52.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1013 - General Learning Space - (51.54 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R1014 - General Learning Space - (52.71 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1015 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1018 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1019 - Design L.S. - (66.02 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R1023 - Design L.S. - (65.86 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R1025 - Movement - (44.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R1026 - Movement - (181.54 SQM)	Not Applicable	Circulation or storage space.
B00J - M0002 - Tiered Learning Area - (46.9 SQM)	● Student Space (21)	
B00J - R0014 - Gymnasium - (636.07 SQM)	● Student Space (295)	
B00K - R0001 - Fitness Laboratory - (148.3 SQM)	● Student Space (68)	
B00K - R0008 - Movement - (18.54 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Staff Kitchen - (5 SQM)	● Office (1)	
B00L - R0001 - Public Reception - (30.3 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Administration - Clerical - (41.77 SQM)	● Office (10)	
B00L - R0005 - Student Reception - (35.34 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Deputy Principal Office - (12.75 SQM)	● Office (3)	
B00L - R0007 - Movement - (25.86 SQM)	Not Applicable	Circulation or storage space.
B00L - R0008 - Deputy Principal Office - (15.06 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0009 - Interview/Office - Type 1 - (12.11 SQM)	 Office (3)	
B00L - R0011 - Clinic - Boys - (12.76 SQM)	 Office (3)	
B00L - R0012 - Administration - Executive - (50.44 SQM)	 Office (12)	
B00L - R0013 - Principal Office - (20.18 SQM)	 Office (5)	
B00L - R0015 - Movement - (19.75 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Interview/Office - Type 2 - (14.29 SQM)	 Office (3)	
B00L - R0017 - Interview/Office - Type 2 - (13.47 SQM)	 Office (3)	
B00L - R0018 - Interview/Office - Type 2 - (16.37 SQM)	 Office (4)	
B00L - R0019 - Tea Room - (6.8 SQM)	Not Applicable	Circulation or storage space.
B00L - R0022 - Clinic - Girls - (12.47 SQM)	 Office (3)	
B00L - R0023 - Interview/Office - Type 1 - (12.43 SQM)	 Office (3)	
B00M - R0001 - Staff Lounge - (40.01 SQM)	 Office (10)	
B00M - R0002 - Staff Kitchen - (16.2 SQM)	 Office (4)	
OS 502 15427 - OS 502 15427 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	
OS 600 11134 - OS 600 11134 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 11934 - OS 600 11934 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 13380 - OS 600 13380 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19875 - OS 600 19875 - Learning Unit - Small - ( SQM)	 Student Space ( )	
OS 601 19860 - OS 601 19860 - Learning Unit - Standard/Withdrawal - ( SQM)	 Student Space ( )	
OS 710 14636 - OS 710 14636 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	