

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Enfield Public School (1844)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Strathfield</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Burwood</b>



1844 - Enfield Public School  
Site Plan (10365)



1:783

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (27.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (47.53 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0006 - Home Base - (47.39 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0007 - Home Base - (47.36 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0008 - Home Base - (47.35 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0009 - Staff Room - (47.54 SQM)	● Office (11)	
B00A - R0010 - Interview - (21.55 SQM)	● Office (5)	
B00A - R0011 - Duplicating Workroom - (24.93 SQM)	● Office (6)	
B00A - R0012 - Clerical Office/Workroom - (21.71 SQM)	● Office (5)	
B00A - R0013 - Movement - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Sick Bay - (9.65 SQM)	● Student Space (4)	
B00A - R0015 - Interview - (12.58 SQM)	● Office (3)	
B00A - R0019 - Deputy Principal - (15.39 SQM)	● Office (3)	
B00A - R0020 - Movement - (164.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Principal - (21.33 SQM)	● Office (5)	
B00A - R0023 - Entry Vestibule - (17.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Home Base - (51.08 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0030 - Practical Activities - 1hb - (13.26 SQM)	● Student Space (6)	
B00A - R0033 - Communal Space - (74.3 SQM)	● Student Space (34)	
B00A - R0036 - Movement - (12.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (49.1 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1002 - Home Base - (48.94 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1003 - Home Base - (48.94 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1004 - Home Base - (48.89 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1005 - Home Base - (48.89 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1006 - Home Base - (49.29 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1007 - Home Base - (49.02 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1008 - Reading Area - (49.16 SQM)	● Student Space (22)	
B00A - R1009 - Reading Area - (48.89 SQM)	● Student Space (22)	
B00A - R1010 - Reading Area - (17.06 SQM)	● Student Space (7)	
B00A - R1012 - Movement - (13.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - Staff Room Annexe - (23.49 SQM)	● Office (5)	
B00A - R1016 - Practical Activities - 1hb - (23.16 SQM)	● Student Space (10)	
B00A - R1017 - Communal Space - (91.94 SQM)	● Student Space (42)	
B00A - R1018 - Raised Platform - (22.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R1022 - Practical Activities - 1hb - (17.52 SQM)	● Student Space (8)	
B00A - R1023 - Movement - (113.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Communal Space - (145.26 SQM)	● Student Space (67)	
B00B - R0002 - Raised Platform - (60.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (12.99 SQM)	Not Applicable	Circulation or storage space.
OS 602 18323 - OS 602 18323 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 14777 - OS 603 14777 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	