

VENTILATION AUDIT REPORT

SCHOOL:	Engadine West Public School (4292)
AMU REGION:	Sydney
STATE ELECTORATE:	Heathcote
LOCAL GOVERNMENT AREA:	Sutherland

4292 - Engadine West Public School
Site Plan (12504)



1:1,058

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office - (13.14 SQM)	Office (3)	
B00A - R0003 - Clerical Office/Workroom - (33.07 SQM)	Office (8)	
B00A - R0004 - Interview - (12.83 SQM)	Office (3)	
B00A - R0005 - Staff Room Annexe - (12.87 SQM)	Office (3)	
B00A - R0007 - Movement - (14.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Duplicating Workroom - (24.16 SQM)	Office (6)	
B00A - R0013 - Staff Room - (67.83 SQM)	Office (16)	
B00A - R0014 - Movement - (61.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Principal - (21.04 SQM)	Office (5)	
B00A - R0016 - Deputy Principal - (13.64 SQM)	Office (3)	
B00A - R0020 - Entry Vestibule - (19.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (35.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Deputy Principal - (18.26 SQM)	Office (4)	
B00B - R0004 - Movement - (12.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (9.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Home Base - (55.11 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0011 - Home Base - (56.63 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0014 - Movement - (6.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Home Base - (55.03 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0020 - Home Base - (56.94 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0023 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (27.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Special Programs Room - (59.12 SQM)	Student Space (27)	
B00E - R0003 - Communal Space - (95.93 SQM)	Student Space (44)	
B00E - R0004 - Practical Activities - 1hb - (21.46 SQM)	Student Space (9)	
B00E - R0005 - Home Base - (58.88 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0014 - Practical Activities - 3hb - (91.37 SQM)	Student Space (42)	
B00E - R0015 - Movement - (91.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Movement - (11.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Home Base - (58.95 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1004 - Home Base - (58.96 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1005 - Home Base - (58.64 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1006 - Home Base - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1007 - Home Base - (58.23 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1009 - Movement - (13.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R1010 - Home Base - (59.05 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1011 - Home Base - (58.63 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1012 - Movement - (70.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Practical Activities - 1hb - (20.06 SQM)	Student Space (9)	
B00F - R0002 - Home Base - (47.58 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0003 - Movement - (43.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Movement - (10.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Staff Room Annexe - (13.09 SQM)	Office (3)	
B00F - R0009 - Home Base - (48.09 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0010 - Practical Activities - 1hb - (20.32 SQM)	Student Space (9)	
B00F - R0013 - Home Base - (47.22 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0014 - Practical Activities - 1hb - (20.59 SQM)	Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0016 - Practical Activities - 1hb - (21.05 SQM)	● Student Space (9)	
B00F - R0017 - Home Base - (47.8 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R0018 - Movement - (22.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Movement - (14.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R1015 - Home Base - (50.43 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R1016 - Practical Activities - (17.83 SQM)	● Student Space (8)	
B00F - R1018 - Practical Activities - (19.66 SQM)	● Student Space (9)	
B00F - R1019 - Home Base - (52.74 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R1020 - Movement - (42.31 SQM)	Not Applicable	Circulation or storage space.
B00F - R1021 - Special Programs Room - (11.56 SQM)	● Student Space (5)	
B00F - R1022 - Special Programs Room - (11.89 SQM)	● Student Space (5)	
B00F - R1023 - Practical Activities - (17.64 SQM)	● Student Space (8)	
B00F - R1024 - Home Base - (49.67 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R1027 - Movement - (6.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R1031 - Practical Activities - (18.23 SQM)	● Student Space (8)	
B00F - R1032 - Home Base - (50.19 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R1033 - Movement - (16.17 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Outdoor Learning Area - (66.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (10.66 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Home Base - (85.07 SQM) - Teaching Space: 1	● Student Space (39)	
B00G - R0007 - Home Base - (56.45 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0008 - Practical Activities - 1hb - (26.46 SQM)	● Student Space (12)	
B00G - R0009 - Movement - (15.71 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Movement - (5 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Practical Activities - 1hb - (26.34 SQM)	● Student Space (12)	
B00G - R0013 - Home Base - (56.53 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0015 - Movement - (6.05 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Home Base - (57.55 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0001 - Movement - (23.83 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Home Base - (52.34 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R0003 - Home Base - (52.48 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R0005 - Withdrawal Space - 1hb - (6.81 SQM)	● Student Space (3)	
B00K - R0002 - Movement - (13.52 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Staff Room Annexe - (17.17 SQM)	● Office (4)	
B00K - R0005 - Home Base - (57.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R0007 - Practical Activities - 1hb - (11.01 SQM)	● Student Space (5)	
B00K - R0008 - Movement - (5.82 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Home Base - (57.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00L - R0001 - Canteen - (49.4 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Movement - (27.82 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Movement - (99.13 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Movement - (15 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Communal Space - (219.52 SQM)	● Student Space (101)	
B00M - R0005 - Movement - (15.22 SQM)	Not Applicable	Circulation or storage space.
B00M - R0010 - Canteen - (26.65 SQM)	Not Applicable	Circulation or storage space.
B00M - R0016 - Raised Platform - (81.51 SQM)	Not Applicable	Circulation or storage space.
B00P - R0004 - Raised Platform - (109.78 SQM)	Not Applicable	Circulation or storage space.
B00P - R0006 - Reading Area - (232.32 SQM)	● Student Space (107)	
B00P - R0010 - Home Base - (59.24 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R0012 - Withdrawal Space - 1hb - (8.42 SQM)	● Student Space (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0013 - Practical Activities - (18.99 SQM)	● Student Space (8)	
OS 603 11114 - OS 603 11114 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	