


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Epping Boys High School (8884)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Ryde</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Ryde</b>

8884 - Epping Boys High School  
Site Plan (11679)



1:2,214

Printed: 07-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0020 - Interview/Meeting - (65.12 SQM)	Office (16)	
B001 - R0033 - Movement - (11.55 SQM)	Not Applicable	Circulation or storage space.
B001 - R0034 - Clinic - (12.27 SQM)	Office (3)	
B001 - R0040 - Movement - (23.24 SQM)	Not Applicable	Circulation or storage space.
B001 - R0041 - Administration - Clerical - (12.75 SQM)	Office (3)	
B001 - R0042 - Administration - Clerical - (13.39 SQM)	Office (3)	
B001 - R0043 - Principal Office - (20.48 SQM)	Office (5)	
B001 - R0046 - Administration - Executive - (10.1 SQM)	Office (2)	
B001 - R0047 - Deputy Principal Office - (11.72 SQM)	Office (2)	
B001 - R0048 - Deputy Principal Office - (11.76 SQM)	Office (2)	
B001 - R0049 - Administration - Clerical - (7.98 SQM)	Office (1)	
B001 - R0050 - Student Reception - (24.31 SQM)	Not Applicable	Circulation or storage space.
B001 - R0051 - Administration - Clerical - (54.95 SQM)	Office (13)	
B001 - R0052 - Public Reception - (28.95 SQM)	Not Applicable	Circulation or storage space.
B001 - R0054 - Interview/Meeting - (11.85 SQM)	Office (2)	
B002 - R0001 - General Learning Space - (64.19 SQM) - Teaching Space: 1	Student Space (29)	
B002 - R0002 - General Learning Space - (51.93 SQM) - Teaching Space: 1	Student Space (24)	
B002 - R0003 - General Learning Space - (65.13 SQM) - Teaching Space: 1	Student Space (30)	
B002 - R0004 - Computer Learning Space - (65.19 SQM) - Teaching Space: 1	Student Space (30)	
B002 - R0005 - Computer Learning Space - (51.93 SQM) - Teaching Space: 1	Student Space (24)	
B002 - R0008 - Staff Study - (19.11 SQM)	Office (4)	
B002 - R0009 - Computer Learning Space - (64.05 SQM) - Teaching Space: 1	Student Space (29)	
B002 - R0011 - Movement - (12.41 SQM)	Not Applicable	Circulation or storage space.
B002 - R0018 - Movement - (50.61 SQM)	Not Applicable	Circulation or storage space.
B003 - R0001 - General Learning Space - (64.05 SQM) - Teaching Space: 1	Student Space (29)	
B003 - R0002 - General Learning Space - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0003 - General Learning Space - (65.15 SQM) - Teaching Space: 1	Student Space (30)	
B003 - R0004 - General Learning Space - (65.21 SQM) - Teaching Space: 1	Student Space (30)	
B003 - R0005 - Special Learning Space - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0008 - Special Learning Space - (64.23 SQM) - Teaching Space: 1	Student Space (29)	
B003 - R0010 - Movement - (12.26 SQM)	Not Applicable	Circulation or storage space.
B003 - R0018 - Movement - (24.84 SQM)	Not Applicable	Circulation or storage space.
B003 - R0019 - Staff Study - (49.15 SQM)	Office (12)	
B004 - R0011 - Interview/Office - Type 1 - (22.43 SQM)	Office (5)	
B004 - R0013 - Staff Study - (64.05 SQM)	Office (16)	
B004 - R0019 - Movement - (20.8 SQM)	Not Applicable	Circulation or storage space.
B004 - R0022 - Commonroom - (121.76 SQM)	Office (30)	
B004 - R0023 - Staff Kitchen - (8.75 SQM)	Office (2)	
B005 - R0045 - Ancillary Staff - (25.61 SQM)	Office (6)	
B005 - R0046 - Interview/Meeting - (23.52 SQM)	Office (5)	
B005 - R0047 - Art Learning Space - (60.99 SQM) - Teaching Space: 1	Student Space (28)	
B005 - R0048 - Art Entry/Display - (24.34 SQM)	Not Applicable	Circulation or storage space.
B005 - R0050 - Art Learning Space - (62.71 SQM) - Teaching Space: 1	Student Space (29)	
B005 - R0051 - Art Learning Space - (64.65 SQM) - Teaching Space: 1	Student Space (29)	
B005 - R0052 - Art Learning Space - (83.95 SQM) - Teaching Space: 1	Student Space (38)	
B006 - R0001 - Laboratory L.S. - (92.02 SQM) - Teaching Space: 1	Student Space (42)	
B006 - R0005 - Laboratory L.S. - (86.4 SQM) - Teaching Space: 1	Student Space (40)	
B006 - R0007 - Preparation - Science - (28.53 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B006 - R0008 - Laboratory L.S. - (92.02 SQM) - Teaching Space: 1	● Student Space (42)	
B006 - R0009 - Staff Study - (59.64 SQM)	● Office (14)	
B006 - R0027 - Laboratory L.S. - (97.74 SQM) - Teaching Space: 1	● Student Space (45)	
B006 - R0031 - Laboratory L.S. - (86.45 SQM) - Teaching Space: 1	● Student Space (40)	
B006 - R0033 - Laboratory L.S. - (91.97 SQM) - Teaching Space: 1	● Student Space (42)	
B006 - R0037 - Preparation - Science - (37.32 SQM)	Not Applicable	Circulation or storage space.
B006 - R0039 - Outdoor Learning Space - Type 1 - (59.85 SQM)	Not Applicable	Circulation or storage space.
B006 - R1003 - General Learning Space - (51.71 SQM) - Teaching Space: 1	● Student Space (23)	
B006 - R1005 - Staff Study - (25.71 SQM)	● Office (6)	
B006 - R1014 - General Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B006 - R1016 - General Learning Space - (59.32 SQM) - Teaching Space: 1	● Student Space (27)	
B006 - R1020 - General Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B006 - R1021 - Staff Kitchen - (25.68 SQM)	● Office (6)	
B006 - R1024 - General Learning Space - (59.71 SQM) - Teaching Space: 1	● Student Space (27)	
B006 - R1026 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B006 - R1027 - General Learning Space - (51.42 SQM) - Teaching Space: 1	● Student Space (23)	
B006 - R1028 - General Learning Space - (51.79 SQM) - Teaching Space: 1	● Student Space (24)	
B006 - R1029 - General Learning Space - (59.4 SQM) - Teaching Space: 1	● Student Space (27)	
B006 - R1031 - Interview/Office - Type 1 - (25.75 SQM)	● Office (6)	
B006 - R1035 - Staff Study - (52.22 SQM)	● Office (13)	
B006 - R1036 - General Learning Space - (48.82 SQM) - Teaching Space: 1	● Student Space (22)	
B006 - R1037 - Computer Learning Space - (49.9 SQM) - Teaching Space: 1	● Student Space (23)	
B007 - M0002 - Study Space - (47.35 SQM)	Not Applicable	Circulation or storage space.
B007 - M0003 - Seminar - (14.82 SQM)	● Office (3)	
B007 - M0005 - Seminar - (14.89 SQM)	● Office (3)	
B007 - M0006 - Study Space - (96.06 SQM)	Not Applicable	Circulation or storage space.
B007 - R0011 - Main Area - (61.13 SQM)	Not Applicable	Circulation or storage space.
B007 - R0013 - Main Area - (176.7 SQM)	Not Applicable	Circulation or storage space.
B007 - R0016 - Tiered Learning Area - (9.18 SQM)	● Student Space (4)	
B007 - R0022 - Main Entry - (52.56 SQM)	Not Applicable	Circulation or storage space.
B007 - R1005 - Interview/Office - Type 1 - (15.53 SQM)	● Office (3)	
B007 - R1010 - Movement - (22.33 SQM)	Not Applicable	Circulation or storage space.
B008 - R0001 - General Learning Space - (83.95 SQM) - Teaching Space: 1	● Student Space (38)	
B008 - R0003 - Staff Study - (19.07 SQM)	● Office (4)	
B008 - R0005 - General Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B008 - R0006 - General Learning Space - (51.93 SQM) - Teaching Space: 1	● Student Space (24)	
B008 - R0012 - Performance Workshop - (90 SQM)	● Student Space (41)	
B008 - R0019 - Movement - (63.24 SQM)	Not Applicable	Circulation or storage space.
B009 - R0009 - Practice/Seminar - (19.14 SQM)	Not Applicable	Circulation or storage space.
B009 - R0010 - Movement - (41.28 SQM)	Not Applicable	Circulation or storage space.
B009 - R0019 - Practice/Seminar - (29.12 SQM)	Not Applicable	Circulation or storage space.
B009 - R0023 - Music Learning Space - (83.02 SQM) - Teaching Space: 1	● Student Space (38)	
B009 - R0025 - Music Learning Space - (80.93 SQM) - Teaching Space: 1	● Student Space (37)	
B009 - R0027 - Practice/Seminar - (74.86 SQM)	Not Applicable	Circulation or storage space.
B010 - R0004 - Movement - (16.09 SQM)	Not Applicable	Circulation or storage space.
B010 - R0006 - Movement - (13.15 SQM)	Not Applicable	Circulation or storage space.
B010 - R0016 - Multi-Purpose Space - (388.06 SQM)	● Student Space (180)	
B010 - R0017 - Stage - (104.76 SQM)	Not Applicable	Circulation or storage space.
B010 - R0022 - General Assistants - (10.59 SQM)	● Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B012 - R0002 - Wood Technology L.S. - (93 SQM) - Teaching Space: 1	Student Space (43)	
B012 - R0003 - Wood Technology L.S. - (89.76 SQM) - Teaching Space: 1	Student Space (41)	
B012 - R0006 - Wood Technology L.S. - (76.47 SQM) - Teaching Space: 1	Student Space (35)	
B012 - R0010 - Design L.S. - (66.22 SQM) - Teaching Space: 1	Student Space (30)	
B012 - R0012 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B012 - R0013 - Preparation - Materials - (52.8 SQM)	Not Applicable	Circulation or storage space.
B012 - R0016 - Design/Technology L.S. - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B012 - R0033 - Staff Study - (51.39 SQM)	Office (12)	
B012 - R0035 - Movement - (114.24 SQM)	Not Applicable	Circulation or storage space.
B012 - R0039 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B012 - R0040 - Design L.S. - (52.66 SQM) - Teaching Space: 1	Student Space (24)	
B012 - R0041 - Materials Workshop - Type 2 - (45.82 SQM)	Student Space (21)	
B013 - R0005 - Materials Workshop - Type 2 - (113.63 SQM)	Student Space (52)	
B013 - R0018 - General Assistants - (24.63 SQM)	Office (6)	
B013 - R0021 - Materials Workshop - Type 2 - (43.76 SQM)	Student Space (20)	
B013 - R0022 - Welding Area - (12.96 SQM)	Not Applicable	Circulation or storage space.
B013 - R0027 - Metal Technology L.S. - (168.76 SQM) - Teaching Space: 1	Student Space (78)	
B015 - R0001 - Multi-Purpose Space - (619.3 SQM)	Student Space (287)	
B017 - R0007 - General Learning Space - (48.6 SQM) - Teaching Space: 1	Student Space (22)	
B017 - R0008 - General Learning Space - (48.35 SQM) - Teaching Space: 1	Student Space (22)	
B017 - R0009 - General Learning Space - (51.59 SQM) - Teaching Space: 1	Student Space (23)	
B017 - R1003 - Staff Study - (45.59 SQM)	Office (11)	
B017 - R1004 - General Learning Space - (48.32 SQM) - Teaching Space: 1	Student Space (22)	
B017 - R1005 - General Learning Space - (48.27 SQM) - Teaching Space: 1	Student Space (22)	
B017 - R1006 - General Learning Space - (51.25 SQM) - Teaching Space: 1	Student Space (23)	
B017 - R1010 - Interview/Office - Type 1 - (18.98 SQM)	Office (4)	
B017 - R1012 - Computer Learning Space - (45.22 SQM) - Teaching Space: 1	Student Space (20)	
B018 - R0005 - Student Canteen - (52.72 SQM)	Not Applicable	Circulation or storage space.
B019 - R0001 - Fitness Laboratory - (82.92 SQM)	Student Space (38)	
B020 - R0011 - Staff Study - (39.71 SQM)	Office (9)	
B020 - R0012 - Multi-Purpose Space - (516.57 SQM)	Student Space (239)	
B020 - R0014 - Tea Room - (5.78 SQM)	Not Applicable	Circulation or storage space.
B021 - R0001 - Food Technology L.S. - (114.67 SQM) - Teaching Space: 1	Student Space (53)	
B021 - R0002 - Movement - (13.4 SQM)	Not Applicable	Circulation or storage space.
B021 - R0004 - Preparation - Materials - (15.27 SQM)	Not Applicable	Circulation or storage space.
OS 600 15310 - OS 600 15310 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 16246 - OS 600 16246 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 18144 - OS 600 18144 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 19550 - OS 600 19550 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 19653 - OS 600 19653 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 11535 - OS 601 11535 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13980 - OS 601 13980 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14497 - OS 601 14497 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 15021 - OS 601 15021 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 15466 - OS 601 15466 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 710 10812 - OS 710 10812 - Home Science/Pantry/Laundry - (95 SQM)	Office (23)	
OS 720 10914 - OS 720 10914 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 12842 - OS 720 12842 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.

