

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Epping North Public School (4165)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Epping</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Hornsby</b>

4165 - Epping North Public School  
Site Plan (11746)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Duplicating Workroom - (28.42 SQM)	Office (7)	
B00A - R0006 - Principal - (16.22 SQM)	Office (4)	
B00A - R0008 - Clerical Office - (14.46 SQM)	Office (3)	
B00A - R0014 - Entry Vestibule - (31.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (16.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (6.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Principal - (22.27 SQM)	Office (5)	
B00A - R0024 - Interview - (21.56 SQM)	Office (5)	
B00A - R0025 - Staff Kitchen - (15.14 SQM)	Office (3)	
B00A - R0026 - Staff Room - (40.97 SQM)	Office (10)	
B00A - R0027 - Movement - (11.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R9001 - Withdrawal Space - 1hb - (52.79 SQM)	Student Space (24)	
B00A - R9002 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (57.17 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0004 - Movement - (5.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (56.93 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0009 - Home Base - (57.33 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0012 - Movement - (6.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Home Base - (56.54 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0005 - Special Programs Room - (21.23 SQM)	Student Space (9)	
B00C - R0007 - Reading Area - (194.38 SQM)	Student Space (90)	
B00D - R0001 - Practical Activities - 1hb - (57.33 SQM)	Student Space (26)	
B00D - R0004 - Movement - (5.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Communal Space - (56.67 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0015 - Home Base - (57.09 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0016 - Movement - (14.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Home Base - (57.53 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0001 - Staff Room - (57.38 SQM) - Teaching Space: 1	Office (14)	
B00E - R0004 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Raised Platform - (8.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (56.93 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0004 - Withdrawal Space - 1hb - (21.1 SQM)	Student Space (9)	
B00F - R0005 - Movement - (13.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Movement - (8.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Practical Activities - 1hb - (10.15 SQM)	Student Space (4)	
B00F - R0010 - Home Base - (46.42 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0015 - Practical Activities - 1hb - (15.31 SQM)	Student Space (7)	
B00F - R0016 - Home Base - (69.99 SQM) - Teaching Space: 1	Student Space (32)	
B00G - R0002 - Interview - (17.44 SQM)	Office (4)	
B00G - R0006 - Staff Room Annexe - (15.81 SQM)	Office (3)	
B00G - R0008 - Movement - (18.55 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Practical Activities - 1hb - (13.83 SQM)	Student Space (6)	
B00G - R0011 - Home Base - (50.42 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0012 - Practical Activities - 1hb - (13.88 SQM)	Student Space (6)	
B00G - R0013 - Home Base - (76.33 SQM) - Teaching Space: 1	Student Space (35)	
B00G - R0015 - Movement - (11.4 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Movement - (12.36 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Special Programs Room - (64.83 SQM)	Student Space (30)	
B00G - R0020 - Home Base - (64.83 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R0025 - Movement - (39.98 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R9004 - Canteen - (14.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R9007 - Movement - (11.92 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Movement - (16 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Movement - (17.18 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Canteen - (26.59 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Communal Space - (145.32 SQM)	● Student Space (67)	
B00K - R0010 - Raised Platform - (60.08 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Movement - (13 SQM)	Not Applicable	Circulation or storage space.
OS 602 10584 - OS 602 10584 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15629 - OS 602 15629 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10362 - OS 603 10362 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 19601 - OS 606 19601 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	