

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Erina High School (8405)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Terrigal</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

Siteplan

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0010 - Senior Study - (85.41 SQM)	Office (21)	
B00A - R0011 - Seminar - (27.38 SQM)	Office (6)	
B00A - R0016 - Movement - (95.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (21.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (39.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Food/Research Space - (18.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Food Technology L.S. - (75.42 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R0026 - Seminar/Technology Space - (38.47 SQM)	Office (9)	
B00A - R0027 - General Learning Space - Type 13 - (72.56 SQM) - Teaching Space: 1	Student Space (33)	
B00A - R0028 - Staff Study - (39.2 SQM)	Office (9)	
B00A - R1003 - General Learning Space - (66.87 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1005 - General Learning Space - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1007 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1012 - General Learning Space - (52.78 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1014 - Seminar - (26.13 SQM)	Office (6)	
B00A - R1015 - Staff Study - (27.23 SQM)	Office (6)	
B00A - R1021 - Staff Study - (24.48 SQM)	Office (6)	
B00B - R0013 - Movement - (354.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Student Canteen - (52.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Gymnasium - (131.93 SQM)	Student Space (61)	
B00C - R0008 - Materials Technology L.S. - (93.42 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R0011 - Movement - (20.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Darkroom Space - (18.49 SQM)	Office (4)	
B00C - R0021 - Movement - (25.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Wood Technology L.S. - (128.26 SQM) - Teaching Space: 1	Student Space (59)	
B00C - R0024 - Outdoor Workshop - (77.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Staff Study - (27.08 SQM)	Office (6)	
B00C - R1013 - General Learning Space - (66.18 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1014 - Dark Room - (23.41 SQM)	Office (5)	
B00C - R1015 - General Learning Space - (68.85 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0003 - Movement - (20.85 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - General Learning Space - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0005 - General Learning Space - (65.94 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0006 - Commonroom - (139.14 SQM)	Office (34)	
B00D - R0008 - Duplicating Workroom - (31.29 SQM)	Office (7)	
B00D - R0009 - Staff Study - (26.9 SQM)	Office (6)	
B00D - R0010 - Movement - (81.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Movement - (40.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - General Learning Space - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1005 - General Learning Space - (53.22 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1007 - General Learning Space - (65.79 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1011 - General Learning Space - (65.79 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1013 - General Learning Space - (53.87 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0001 - Ancillary Staff - (18.73 SQM)	Office (4)	
B00E - R0005 - Principal Office - (18.22 SQM)	Office (4)	
B00E - R0009 - Deputy Principal Office - (18.73 SQM)	Office (4)	
B00E - R0010 - Interview/Office - Type 1 - (10.32 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0011 - Clinic - Boys - (10.28 SQM)	Office (2)	
B00E - R0013 - Administration - Clerical - (9.3 SQM)	Office (2)	
B00E - R0014 - Administration - Clerical - (19.5 SQM)	Office (4)	
B00E - R0015 - Administration - Clerical - (13.78 SQM)	Office (3)	
B00E - R0016 - Leading Teacher - (23.8 SQM)	Office (5)	
B00E - R0017 - Interview/Office - Type 1 - (14.19 SQM)	Office (3)	
B00E - R0018 - Interview/Office - Type 1 - (14.67 SQM)	Office (3)	
B00E - R0021 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Movement - (13.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Public Entry - (10.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Movement - (33.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Interview/Meeting - (9.43 SQM)	Office (2)	
B00E - R0026 - Movement - (30.8 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Movement - (21.3 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Laboratory L.S. - (93.29 SQM) - Teaching Space: 1	Student Space (43)	
B00F - R0007 - Laboratory L.S. - (92.27 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R0009 - Computer Learning Space - (65.24 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0010 - Staff Study - (26.86 SQM)	Office (6)	
B00F - R0014 - General Assistants - (29.78 SQM)	Office (7)	
B00F - R0015 - Movement - (44.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Preparation - Science - (39.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Art Learning Space - (60.08 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R1006 - General Learning Space - (65.85 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R1007 - General Learning Space - (65.99 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R1010 - Computer Learning Space - (52.85 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1012 - Staff Study - (26.72 SQM)	Office (6)	
B00G - M0007 - Multi-Purpose Space - (77.08 SQM)	Student Space (35)	
B00G - R0003 - Stage - (94.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (17.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Student Canteen - (11.19 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Multi-Purpose Space - (469.81 SQM)	Student Space (217)	
B00H - R0003 - Movement - (20.65 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Staff Study - (39.71 SQM)	Office (9)	
B00H - R0006 - Food Technology L.S. - (65.35 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0007 - Seminar - (12.67 SQM)	Office (3)	
B00H - R0009 - Food/Research Space - (12.67 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Study Space - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Design L.S. - (65.94 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0015 - General Learning Space - (54.02 SQM) - Teaching Space: 1	Student Space (25)	
B00H - R0017 - Movement - (84.99 SQM)	Not Applicable	Circulation or storage space.
B00H - R0021 - Movement - (44.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R1003 - Staff Study - (26.9 SQM)	Office (6)	
B00H - R1004 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1005 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1006 - General Learning Space - (52.62 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1008 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1009 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1011 - Staff Study - (13.36 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0005 - Materials Technology L.S. - (84.72 SQM) - Teaching Space: 1	● Student Space (39)	
B00J - R0008 - Seminar/Technology Space - (45.74 SQM)	● Office (11)	
B00J - R0009 - Design/Technology L.S. - (52.46 SQM)	● Student Space (24)	
B00J - R0014 - Movement - (55.74 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Movement - (9.99 SQM)	Not Applicable	Circulation or storage space.
B00J - R0023 - Metal Technology Bay - (14.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R0027 - General Learning Space - (59.65 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0028 - Staff Study - (38.86 SQM)	● Office (9)	
B00J - R1003 - Music Learning Space - (66.36 SQM) - Teaching Space: 1	● Student Space (30)	
B00J - R1005 - Practice/Seminar - (30.17 SQM)	Not Applicable	Circulation or storage space.
B00J - R1006 - Music Learning Space - (63.09 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R1007 - Staff Study - (23.67 SQM)	● Office (5)	
B00K - R0002 - Performance Workspace - (97.27 SQM) - Teaching Space: 1	● Student Space (45)	
B00L - R0001 - Staff Study - (5.7 SQM)	● Office (1)	
B00N - M1001 - Main Area - (143.24 SQM)	Not Applicable	Circulation or storage space.
B00N - M1002 - Seminar - (19.19 SQM)	● Office (4)	
B00N - M1003 - Teachers Aides - (20.59 SQM)	● Office (5)	
B00N - M1007 - Seminar - (62.45 SQM)	● Office (15)	
B00N - R0001 - Laboratory L.S. - (90.73 SQM) - Teaching Space: 1	● Student Space (42)	
B00N - R0002 - Laboratory L.S. - (91 SQM) - Teaching Space: 1	● Student Space (42)	
B00N - R0003 - Preparation - (48.47 SQM)	Not Applicable	Circulation or storage space.
B00N - R0004 - Laboratory L.S. - (90.64 SQM) - Teaching Space: 1	● Student Space (42)	
B00N - R0006 - Laboratory L.S. - (90.46 SQM) - Teaching Space: 1	● Student Space (41)	
B00N - R0008 - Preparation - (48.06 SQM)	Not Applicable	Circulation or storage space.
B00N - R0009 - Movement - (40.37 SQM)	Not Applicable	Circulation or storage space.
B00N - R1001 - Main Area - (387.59 SQM)	Not Applicable	Circulation or storage space.
B00N - R1003 - Seminar - (12.29 SQM)	● Office (3)	
B00N - R1004 - Seminar - (12.29 SQM)	● Office (3)	
B00N - R1007 - Teachers Aides - (11.94 SQM)	● Office (2)	
B00N - R1009 - Seminar - (12.28 SQM)	● Office (3)	
B00N - R1010 - Seminar - (12.28 SQM)	● Office (3)	
B00N - R1011 - Audio Visual Workroom - (29.04 SQM)	● Student Space (13)	
B00N - R1013 - Workroom - (20.01 SQM)	● Office (5)	
B00O - R0007 - Staff Kitchen - (18 SQM)	● Office (4)	