


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Ermington West Public School (4125)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Parramatta</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Parramatta</b>

4125 - Ermington West Public School  
Site Plan (10977)



1:917

Printed: 28-Nov-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (53.45 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0003 - Home Base - (53.45 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0009 - Home Base - (53.02 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0010 - Home Base - (53.23 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0012 - Communal Space - (108.01 SQM)	 Student Space (50)	
B00B - R0001 - Clerical Office - (17.48 SQM)	 Office (4)	
B00B - R0002 - Duplicating Workroom - (17.41 SQM)	 Office (4)	
B00B - R0006 - Interview - (11.44 SQM)	 Office (2)	
B00B - R0007 - Sick Bay - (11.91 SQM)	 Student Space (5)	
B00B - R0009 - Movement - (20.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Principal - (17.34 SQM)	 Office (4)	
B00B - R0016 - Deputy Principal - (12.43 SQM)	 Office (3)	
B00C - R0005 - Home Base - (56.47 SQM) - Teaching Space: 1	 Student Space (26)	
B00C - R0006 - Home Base - (57.07 SQM) - Teaching Space: 1	 Student Space (26)	
B00D - R0002 - Practical Activities - 1hb - (12.74 SQM)	 Student Space (5)	
B00D - R0004 - Home Base - (98.17 SQM) - Teaching Space: 1	 Student Space (45)	
B00D - R0005 - Home Base - (64.73 SQM) - Teaching Space: 1	 Student Space (30)	
B00D - R0007 - Practical Activities - 1hb - (12.67 SQM)	 Student Space (5)	
B00D - R0008 - Staff Room - (50.43 SQM)	 Office (12)	
B00D - R0013 - Movement - (16.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Reading Area - (94.15 SQM)	 Student Space (43)	
B00E - R0002 - Home Base - (65.38 SQM) - Teaching Space: 1	 Student Space (30)	
B00E - R0005 - Movement - (22.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (65.38 SQM) - Teaching Space: 1	 Student Space (30)	
B00E - R0009 - Home Base - (61.1 SQM) - Teaching Space: 1	 Student Space (28)	
B00F - R0002 - Home Base - (65.08 SQM)	 Student Space (30)	
B00F - R0003 - Home Base - (64.66 SQM)	 Student Space (29)	
B00F - R0010 - Home Base - (62.99 SQM) - Teaching Space: 1	 Student Space (29)	
B00F - R0012 - Breakout Area - (23.51 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Home Base - (52.65 SQM) - Teaching Space: 1	 Student Space (24)	
B00F - R0014 - Practical Activities - 2hb - (9.94 SQM)	 Student Space (4)	
B00G - R0001 - Movement - (13.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Canteen - (18.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Canteen - (31.29 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (144.25 SQM)	 Student Space (66)	
B00H - R0002 - Raised Platform - (62.11 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (14.3 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.