


VENTILATION AUDIT REPORT

SCHOOL:	Erskineville Public School (4147)
AMU REGION:	Sydney
STATE ELECTORATE:	Heffron
LOCAL GOVERNMENT AREA:	Sydney

4147 - Erskineville Public School
Site Plan (13212)










1:632

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (63.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Principal - (20.77 SQM)	Office (5)	
B00A - R0005 - Duplicating Workroom - (13.02 SQM)	Office (3)	
B00A - R0007 - Clerical Office/Workroom - (18.52 SQM)	Office (4)	
B00A - R0009 - Movement - (64.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (33.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Communal Space - (97.41 SQM)	Student Space (45)	
B00A - R0012 - Raised Platform - (17.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Canteen - (21.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (23.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (6.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Movement - (12.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Home Base - (53.32 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1011 - Practical Activities - 1hb - (20.64 SQM)	Student Space (9)	
B00A - R1012 - Home Base - (42.97 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R1013 - Practical Activities - 1hb - (30.57 SQM)	Student Space (14)	
B00A - R1014 - Home Base - (42.92 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R1015 - Special Programs Room - (30.54 SQM)	Student Space (14)	
B00A - R1016 - Special Programs Room - (36.6 SQM)	Student Space (16)	
B00A - R1019 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Movement - (79.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R2001 - Home Base - (49.04 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R2002 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R2003 - Movement - (6.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R2004 - Home Base - (43.08 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R2005 - Practical Activities - 1hb - (31 SQM)	Student Space (14)	
B00A - R2007 - Home Base - (42.91 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R2008 - Practical Activities - 1hb - (30.53 SQM)	Student Space (14)	
B00A - R2013 - Staff Room - (8.33 SQM)	Office (2)	
B00A - R2015 - Movement - (79.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R2018 - Home Base - (73.65 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R2019 - Home Base - (75.6 SQM) - Teaching Space: 1	Student Space (35)	
B00B - R0001 - Home Base - (50.09 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0002 - Home Base - (51.11 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0007 - Movement - (5.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (19.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (39.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Duplicating Workroom - (14.97 SQM)	Office (3)	
B00B - R0014 - Staff Kitchen - (12.97 SQM)	Office (3)	
B00B - R0018 - Movement - (5.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Interview - (48.07 SQM)	Office (12)	
B00B - R0021 - Movement - (38.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Movement - (19.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Home Base - (74.47 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0028 - Home Base - (79.71 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0029 - Home Base - (61.03 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0030 - Home Base - (61.03 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0031 - Home Base - (101.38 SQM) - Teaching Space: 1	Student Space (47)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0001 - Home Base - (56.31 SQM) - Teaching Space: 1	 Student Space (26)	
B00C - R0003 - Movement - (27.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (60.07 SQM) - Teaching Space: 1	 Student Space (27)	
B00C - R0008 - Movement - (24.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (5.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Staff Room Annexe - (129.57 SQM)	 Office (32)	
B00C - R1005 - Special Programs Room - (61.17 SQM)	 Student Space (28)	
B00C - R1006 - Reading Area - (17.43 SQM)	 Student Space (8)	
B00C - R1008 - Movement - (32.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R1009 - Reading Area - (23.45 SQM)	 Student Space (10)	
B00D - R0001 - Movement - (138.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Communal Space - (146.65 SQM)	 Student Space (68)	
B00E - R0002 - Raised Platform - (60.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (6.36 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (11.71 SQM)	Not Applicable	Circulation or storage space.