

VENTILATION AUDIT REPORT

SCHOOL:	Eschol Park Public School (4558)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Macquarie Fields
LOCAL GOVERNMENT AREA:	Campbelltown

4558 - Eschol Park Public School
Site Plan (10371)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (55.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (20.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Interview - (11.72 SQM)	Office (2)	
B00A - R0004 - Interview - (12.23 SQM)	Office (3)	
B00A - R0005 - Principal - (17.14 SQM)	Office (4)	
B00A - R0007 - Clerical Office - (11 SQM)	Office (2)	
B00A - R0008 - Duplicating Workroom - (35.36 SQM)	Office (8)	
B00A - R0011 - Interview - (16.46 SQM)	Office (4)	
B00A - R0012 - Sick Bay - (9.47 SQM)	Student Space (4)	
B00A - R0013 - Movement - (25.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Staff Room Annexe - (25.9 SQM)	Office (6)	
B00A - R0015 - Staff Room - (52.86 SQM)	Office (13)	
B00A - R0019 - Movement - (5.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (40.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Clerical Office - (10 SQM)	Office (2)	
B00A - R0024 - Movement - (14.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (57.76 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0006 - Withdrawal Space - 1hb - (12.15 SQM)	Student Space (5)	
B00B - R0007 - Home Base - (58.68 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0012 - Movement - (9.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Home Base - (58.51 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0016 - Withdrawal Space - 1hb - (12.15 SQM)	Student Space (5)	
B00B - R0017 - Home Base - (58.51 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0026 - Movement - (130.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Practical Activities/Movement - 2hb - (47.75 SQM)	Student Space (22)	
B00B - R0031 - Practical Activities/Movement - 2hb - (47.75 SQM)	Student Space (22)	
B00C - R0006 - Special Programs Room - (44.84 SQM)	Student Space (20)	
B00C - R0008 - Special Programs Room - (15.69 SQM)	Student Space (7)	
B00C - R0021 - Home Base - (58.93 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0022 - Movement - (18.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Withdrawal Space - 1hb - (12.22 SQM)	Student Space (5)	
B00C - R0024 - Movement - (18.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Home Base - (58.6 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0030 - Movement - (65.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0035 - Home Base - (58.6 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0036 - Movement - (18.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0037 - Withdrawal Space - 1hb - (12.18 SQM)	Student Space (5)	
B00C - R0038 - Movement - (18.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0039 - Home Base - (58.93 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0045 - Movement - (5.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0047 - Movement - (111.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0049 - Reading Area - (211.68 SQM)	Student Space (98)	
B00C - R0050 - Seminar/Study - (45.85 SQM)	Office (11)	
B00C - R0053 - Practical Activities/Movement - 2hb - (47.77 SQM)	Student Space (22)	
B00C - R0056 - Practical Activities/Movement - 2hb - (47.79 SQM)	Student Space (22)	
B00D - R0003 - Home Base - (57.92 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0004 - Withdrawal Space - 1hb - (12.21 SQM)	Student Space (5)	
B00D - R0005 - Home Base - (58.41 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0008 - Practical Activities - 1hb - (48.99 SQM)	● Student Space (22)	
B00D - R0015 - Home Base - (58.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0016 - Withdrawal Space - 1hb - (12.21 SQM)	● Student Space (5)	
B00D - R0017 - Home Base - (58.59 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0020 - Practical Activities - 1hb - (47.96 SQM)	● Student Space (22)	
B00D - R0025 - Home Base - (58.75 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0026 - Withdrawal Space - 1hb - (12.21 SQM)	● Student Space (5)	
B00D - R0027 - Home Base - (58.68 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0030 - Practical Activities - 1hb - (48.06 SQM)	● Student Space (22)	
B00D - R0033 - Movement - (17.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0034 - Movement - (18.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0035 - Movement - (18.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0036 - Movement - (18.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0037 - Movement - (18.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0038 - Movement - (18.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R0039 - Movement - (5.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0040 - Movement - (65.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0041 - Movement - (32.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0042 - Movement - (170.2 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Raised Platform - (52.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Canteen - (40.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0027 - Movement - (62.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0037 - Communal Space - (201.54 SQM)	● Student Space (93)	
B00E - R0039 - Movement - (6.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0041 - Movement - (123.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities/Movement - 1hb - (19.14 SQM)	● Student Space (8)	
B00H - R0004 - Home Base - (61.04 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0005 - Withdrawal Space - 2hb - (11.74 SQM)	● Student Space (5)	
B00H - R0006 - Home Base - (61.04 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0008 - Practical Activities/Movement - 1hb - (18.63 SQM)	● Student Space (8)	