


VENTILATION AUDIT REPORT

SCHOOL:	Estella Public School (4674)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Wagga Wagga
LOCAL GOVERNMENT AREA:	Wagga Wagga

4674 - Estella Public School
Site Plan (15728)























1:890

Printed: 13-Feb-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (21.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Interview - (14.2 SQM)	Office (3)	
B00A - R0003 - Interview/Office - Type 3 - (17.56 SQM)	Office (4)	
B00A - R0011 - Deputy Principal - (14.6 SQM)	Office (3)	
B00A - R0016 - Movement - (68.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Sick Bay - (12.04 SQM)	Student Space (5)	
B00A - R0018 - Deputy Principal - (27.3 SQM)	Office (6)	
B00A - R0019 - Principal - (17.45 SQM)	Office (4)	
B00A - R0020 - Clerical Office/Workroom - (22.89 SQM)	Office (5)	
B00A - R0021 - Clerical Office/Workroom - (24.95 SQM)	Office (6)	
B00A - R0022 - Clerical Office/Workroom - (14.89 SQM)	Office (3)	
B00B - R0001 - Communal Space - (126.87 SQM)	Student Space (58)	
B00B - R0002 - Interview - (17.04 SQM)	Office (4)	
B00B - R0015 - Movement - (10.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Communal Space - (78.61 SQM)	Student Space (36)	
B00B - R1005 - Staff Room - (68.49 SQM)	Office (17)	
B00B - R1006 - Interview - (23.24 SQM)	Office (5)	
B00B - R1010 - Movement - (12.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R1016 - Staff Kitchen - (23.98 SQM)	Office (5)	
B00C - R0001 - Communal Space - (228.74 SQM)	Student Space (106)	
B00C - R0003 - Movement - (33.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Staff Kitchen - (19.68 SQM)	Office (4)	
B00C - R0011 - Movement - (17.7 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (37.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Raised Platform - (67.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Canteen - (45.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Seminar/Study - (91.49 SQM)	Office (22)	
B00D - R1002 - Special Programs Room - Type 1 - (34.74 SQM)	Student Space (16)	
B00D - R1003 - Special Programs Room - Type 1 - (34.87 SQM)	Student Space (16)	
B00D - R1011 - Seminar/Study - (98.78 SQM)	Office (24)	
B00D - R1012 - Seminar/Study - (67.77 SQM)	Office (16)	
B00D - R1013 - Practical Activities - (10.91 SQM)	Student Space (5)	
B00D - R1014 - Practical Activities - (10.23 SQM)	Student Space (4)	
B00E - R0001 - Home Base - (56.99 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0002 - Home Base - (59.18 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0003 - Home Base - (59.18 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0004 - Home Base - (56.99 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0005 - Withdrawal Space - 2hb - (23.44 SQM)	Student Space (10)	
B00E - R0006 - Withdrawal Space - 2hb - (23.44 SQM)	Student Space (10)	
B00E - R0007 - Practical Activities - (24.39 SQM)	Student Space (11)	
B00E - R0015 - Home Base - (103.16 SQM) - Teaching Space: 1	Student Space (47)	
B00E - R1001 - Home Base - (56.99 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1002 - Home Base - (59.18 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1003 - Home Base - (59.18 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1004 - Home Base - (56.99 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1005 - Withdrawal Space - 2hb - (23.44 SQM)	Student Space (10)	
B00E - R1006 - Withdrawal Space - 2hb - (23.44 SQM)	Student Space (10)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1007 - Practical Activities - (24.28 SQM)	 Student Space (11)	
B00E - R1015 - Home Base - (103.16 SQM) - Teaching Space: 1	 Student Space (47)	
B00F - R0001 - Home Base - (57 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0002 - Home Base - (59.18 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0003 - Home Base - (59.19 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0004 - Home Base - (57 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0005 - Withdrawal Space - 2hb - (23.44 SQM)	 Student Space (10)	
B00F - R0006 - Withdrawal Space - 2hb - (23.37 SQM)	 Student Space (10)	
B00F - R0007 - Practical Activities - (24.23 SQM)	 Student Space (11)	
B00F - R0017 - Home Base - (102.89 SQM) - Teaching Space: 1	 Student Space (47)	
B00F - R0032 - Tiered Learning Space - (21 SQM)	 Student Space (9)	
B00F - R1001 - Home Base - (57 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R1002 - Home Base - (59.18 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R1003 - Home Base - (59.19 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R1004 - Home Base - (57 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R1005 - Withdrawal Space - 2hb - (23.44 SQM)	 Student Space (10)	
B00F - R1006 - Withdrawal Space - 2hb - (23.37 SQM)	 Student Space (10)	
B00F - R1007 - Practical Activities - (24.23 SQM)	 Student Space (11)	
B00F - R1017 - Home Base - (102.89 SQM) - Teaching Space: 1	 Student Space (47)	
B00F - R1025 - Tiered Learning Space - (29.01 SQM)	 Student Space (13)	