

VENTILATION AUDIT REPORT

SCHOOL:	Ettalong Public School (1864)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Gosford
LOCAL GOVERNMENT AREA:	Central Coast

1864 - Ettalong Public School
Site Plan (13144)



1.792

Printed: 07-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Practical Activities - 1hb - (13.69 SQM)	● Student Space (6)	
B00A - R0003 - Home Base - (88.26 SQM) - Teaching Space: 1	● Student Space (40)	
B00A - R0004 - Home Base - (88.47 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R0005 - Practical Activities - 1hb - (13.86 SQM)	● Student Space (6)	
B00A - R0009 - Movement - (8.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (6.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (54.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (55.4 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1002 - Practical Activities - 1hb - (14.6 SQM)	● Student Space (6)	
B00A - R1003 - Home Base - (55.24 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1004 - Practical Activities - 1hb - (14.56 SQM)	● Student Space (6)	
B00A - R1005 - Home Base - (55.47 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1006 - Practical Activities - 1hb - (14.62 SQM)	● Student Space (6)	
B00A - R1010 - Interview - (13.76 SQM)	● Office (3)	
B00A - R1011 - Special Programs Room - (9.44 SQM)	● Student Space (4)	
B00A - R1015 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Movement - (54.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Special Programs Room - (17 SQM)	● Student Space (7)	
B00B - R0001 - Practical Activities - 1hb - (14.6 SQM)	● Student Space (6)	
B00B - R0002 - Home Base - (55.35 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0003 - Practical Activities - M - 1hb - (14.56 SQM)	● Student Space (6)	
B00B - R0004 - Home Base - M - (54.96 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0005 - Practical Activities - 1hb - (14.64 SQM)	● Student Space (6)	
B00B - R0006 - Home Base - (55.27 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0012 - Movement - (81.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Home Base - (47.84 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1002 - Practical Activities - 1hb - (26.42 SQM)	● Student Space (12)	
B00B - R1003 - Home Base - (59.71 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1004 - Practical Activities - 1hb - (14.55 SQM)	● Student Space (6)	
B00B - R1005 - Home Base - (60.05 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1006 - Practical Activities - 1hb - (14.64 SQM)	● Student Space (6)	
B00B - R1007 - Seminar/Study - (13.38 SQM)	● Office (3)	
B00B - R1008 - Withdrawal Space - 1hb - (18.53 SQM)	● Student Space (8)	
B00B - R1010 - Movement - (6.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Movement - (79.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Practical Activities - 1hb - (14.32 SQM)	● Student Space (6)	
B00C - R0002 - Home Base - (55.42 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0003 - Practical Activities - 1hb - (14.24 SQM)	● Student Space (6)	
B00C - R0004 - Home Base - (55.1 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0005 - Practical Activities - 1hb - (14.3 SQM)	● Student Space (6)	
B00C - R0006 - Home Base - (55.35 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0011 - Movement - (55.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Practical Activities - 1hb - (14.63 SQM)	● Student Space (6)	
B00C - R1002 - Home Base - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1003 - Practical Activities - 1hb - (14.56 SQM)	● Student Space (6)	
B00C - R1004 - Home Base - (53.25 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1005 - Practical Activities - 1hb - (14.63 SQM)	● Student Space (6)	
B00C - R1006 - Home Base - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1013 - Movement - (54.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R1014 - Withdrawal Space - 1hb - (41.85 SQM)	● Student Space (19)	
B00D - R0010 - Movement - (7.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Raised Platform - (53.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (8.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Canteen - (44 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Movement - (75.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Communal Space - (64.62 SQM)	● Student Space (29)	
B00D - R0024 - Communal Space - (203.75 SQM)	● Student Space (94)	
B00E - R0001 - Principal - (18.96 SQM)	● Office (4)	
B00E - R0002 - Staff Room Annexe - (12.04 SQM)	● Office (3)	
B00E - R0003 - Clerical Office - (13.21 SQM)	● Office (3)	
B00E - R0004 - Staff Room - (71.2 SQM)	● Office (17)	
B00E - R0005 - Seminar/Study - (16.02 SQM)	● Office (4)	
B00E - R0009 - Duplicating Workroom - (27.9 SQM)	● Office (6)	
B00E - R0010 - Sick Bay - (12.18 SQM)	● Student Space (5)	
B00E - R0012 - Staff Room Annexe - (12.39 SQM)	● Office (3)	
B00E - R0013 - Entry Vestibule - (9.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Clerical Office - (12.03 SQM)	● Office (3)	
B00E - R0017 - Movement - (11.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (5.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Movement - (18.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Movement - (57.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R1006 - Movement - (17.13 SQM)	Not Applicable	Circulation or storage space.
B00E - R1011 - Reading Area - (234.11 SQM)	● Student Space (108)	
B00E - R1012 - Movement - (7.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Home Base - P - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0011 - Home Base - P - (71.07 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R0005 - Home Base - (47.27 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0009 - Practical Activities - 1hb - (17.54 SQM)	● Student Space (8)	
B00G - R0010 - Special Programs Room - (94.49 SQM)	● Student Space (43)	
B00G - R0011 - Movement - (43.52 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (23.7 SQM)	● Student Space (10)	
B00H - R0003 - Movement - (33.75 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Staff Kitchen - (9.94 SQM)	● Office (2)	
B00H - R0005 - Movement - (9.55 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (38.47 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Practical Activities - 1hb - (19.39 SQM)	● Student Space (8)	
B00J - R0004 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00J - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00K - R0001 - Practical Activities - 1hb - (15.67 SQM)	● Student Space (7)	
B00K - R0003 - Home Base - (58.06 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R0005 - Withdrawal Space - 1hb - (9.17 SQM)	● Student Space (4)	
B00K - R0006 - Practical Activities - 1hb - (15.04 SQM)	● Student Space (6)	
B00K - R0009 - Home Base - (60.47 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0010 - Withdrawal Space - 2hb - (11.12 SQM)	● Student Space (5)	
B00K - R0011 - Practical Activities - 1hb - (14.93 SQM)	● Student Space (6)	
B00K - R0014 - Home Base - (60.33 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R1001 - Practical Activities - 1hb - (14.95 SQM)	● Student Space (6)	
B00K - R1004 - Home Base - (60.52 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R1005 - Withdrawal Space - 2hb - (11.12 SQM)	● Student Space (5)	
B00K - R1006 - Practical Activities - 1hb - (14.95 SQM)	● Student Space (6)	
B00K - R1009 - Home Base - (60.37 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R1010 - Practical Activities - 1hb - (17.12 SQM)	● Student Space (7)	
B00K - R1012 - Home Base - (58.55 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1013 - Withdrawal Space - 1hb - (9.07 SQM)	● Student Space (4)	
OH 060 17040 - OH 060 17040 - OSHC Hub 60 - (SQM)	● Student Space ()	