

# VENTILATION AUDIT REPORT

SCHOOL:	Eumungerie Public School (1873)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Dubbo

1873 - Eumungerie Public School  
Site Plan (10981)











1:560

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0003 - Withdrawal Space - 1hb - (12.72 SQM)	 Student Space (5)	
B00D - R0001 - Reading Area - (59.86 SQM)	 Student Space (27)	
B00F - R0003 - Canteen - (17.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Practical Activities - 1hb - (19.63 SQM)	 Student Space (9)	
B00F - R0006 - Home Base - (58.97 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0009 - Special Programs Room - (10.65 SQM)	 Student Space (4)	
B00F - R0010 - Home Base - (58.78 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0011 - Practical Activities - 1hb - (19.29 SQM)	 Student Space (8)	
OS 505 13426 - OS 505 13426 - Admin Staff/Principal/Secure Store - (76 SQM)	 Office (19)	