

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Fairfield Heights Public School (3632)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Fairfield</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Fairfield</b>

3632 - Fairfield Heights Public School  
Site Plan (10374)



































1:827

Printed: 15-Dec-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Home Base - (66.8 SQM) - Teaching Space: 1	 Student Space (30)	
B001 - R0004 - Movement - (10.63 SQM)	Not Applicable	Circulation or storage space.
B001 - R0007 - Home Base - (66.98 SQM) - Teaching Space: 1	 Student Space (31)	
B001 - R0010 - Home Base - (66.89 SQM) - Teaching Space: 1	 Student Space (31)	
B001 - R0015 - Movement - (10.55 SQM)	Not Applicable	Circulation or storage space.
B001 - R0018 - Home Base - (67.26 SQM) - Teaching Space: 1	 Student Space (31)	
B001 - R0021 - Raised Platform - (25.24 SQM)	Not Applicable	Circulation or storage space.
B002 - R0001 - Home Base - (53.58 SQM) - Teaching Space: 1	 Student Space (24)	
B002 - R0002 - Home Base - (53.51 SQM) - Teaching Space: 1	 Student Space (24)	
B002 - R0006 - Staff Room Annexe - (10.4 SQM)	 Office (2)	
B002 - R0008 - Home Base - (53.36 SQM) - Teaching Space: 1	 Student Space (24)	
B002 - R0009 - Home Base - (53.51 SQM) - Teaching Space: 1	 Student Space (24)	
B002 - R0010 - Movement - (71.73 SQM)	Not Applicable	Circulation or storage space.
B003 - R0001 - Home Base - (66.73 SQM) - Teaching Space: 1	 Student Space (30)	
B003 - R0004 - Withdrawal Space - 1hb - (22.5 SQM)	 Student Space (10)	
B003 - R0006 - Movement - (21.15 SQM)	Not Applicable	Circulation or storage space.
B003 - R0007 - Movement - (6.31 SQM)	Not Applicable	Circulation or storage space.
B003 - R0009 - Home Base - (67.86 SQM) - Teaching Space: 1	 Student Space (31)	
B003 - R0010 - Home Base - (68.06 SQM) - Teaching Space: 1	 Student Space (31)	
B003 - R0015 - Home Base - (66.74 SQM) - Teaching Space: 1	 Student Space (30)	
B003 - R0016 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B004 - R0003 - Home Base - (67.37 SQM) - Teaching Space: 1	 Student Space (31)	
B004 - R0008 - Interview - (16.11 SQM)	 Office (4)	
B004 - R0011 - Movement - (15.43 SQM)	Not Applicable	Circulation or storage space.
B004 - R0012 - Home Base - (65.91 SQM) - Teaching Space: 1	 Student Space (30)	
B004 - R0014 - Home Base - (65.74 SQM) - Teaching Space: 1	 Student Space (30)	
B004 - R0021 - Movement - (15.12 SQM)	Not Applicable	Circulation or storage space.
B004 - R0023 - Home Base - (67.75 SQM) - Teaching Space: 1	 Student Space (31)	
B006 - R0001 - Special Programs Room - (18.51 SQM)	 Student Space (8)	
B006 - R0002 - Movement - (17.1 SQM)	Not Applicable	Circulation or storage space.
B006 - R0006 - Home Base - (94.41 SQM) - Teaching Space: 1	 Student Space (43)	
B006 - R0007 - Home Base - (64.95 SQM) - Teaching Space: 1	 Student Space (30)	
B006 - R0010 - Home Base - (65.42 SQM) - Teaching Space: 1	 Student Space (30)	
B006 - R0011 - Home Base - (64.96 SQM) - Teaching Space: 1	 Student Space (30)	
B006 - R0015 - Home Base - (65.41 SQM) - Teaching Space: 1	 Student Space (30)	
B006 - R0016 - Movement - (5.47 SQM)	Not Applicable	Circulation or storage space.
B006 - R0017 - Movement - (5.01 SQM)	Not Applicable	Circulation or storage space.
B006 - R0018 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.
B007 - R0005 - Home Base - (85.75 SQM) - Teaching Space: 1	 Student Space (39)	
B008 - R0001 - Movement - (60.3 SQM)	Not Applicable	Circulation or storage space.
B008 - R0004 - Clerical Office - (8.32 SQM)	 Office (2)	
B008 - R0005 - Entry Vestibule - (12.13 SQM)	Not Applicable	Circulation or storage space.
B008 - R0006 - Clerical Office/Workroom - (12.38 SQM)	 Office (3)	
B008 - R0007 - Duplicating Workroom - (14.69 SQM)	 Office (3)	
B008 - R0009 - Principal - (20.23 SQM)	 Office (5)	
B008 - R0012 - Deputy Principal - (12.87 SQM)	 Office (3)	
B008 - R0016 - Movement - (8.73 SQM)	Not Applicable	Circulation or storage space.
B008 - R0017 - Staff Kitchen - (20.26 SQM)	 Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B008 - R0018 - Staff Room - (69.8 SQM)	Office (17)	
B008 - R0019 - Sick Bay - (13.88 SQM)	Student Space (6)	
B009 - R0002 - Home Base - (53.72 SQM) - Teaching Space: 1	Student Space (24)	
B009 - R0003 - Home Base - (53.87 SQM) - Teaching Space: 1	Student Space (24)	
B009 - R0005 - Movement - (23.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (31.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (13.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Raised Platform - (64.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Movement - (27.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Communal Space - (198.92 SQM)	Student Space (92)	
B00E - R0023 - Canteen - (41.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Movement - (17.7 SQM)	Not Applicable	Circulation or storage space.
B013 - R0002 - Movement - (8.32 SQM)	Not Applicable	Circulation or storage space.
B015 - R0001 - Reading Area - (231.43 SQM)	Student Space (107)	
B015 - R0004 - Movement - (14.18 SQM)	Not Applicable	Circulation or storage space.
B016 - R0001 - Movement - (34.73 SQM)	Not Applicable	Circulation or storage space.
B016 - R0002 - Practical Activities - 1hb - (19.98 SQM)	Student Space (9)	
B016 - R0004 - Home Base - (59.02 SQM) - Teaching Space: 1	Student Space (27)	
B016 - R0005 - Withdrawal Space - 2hb - (11.64 SQM)	Student Space (5)	
B016 - R0006 - Home Base - (59.03 SQM) - Teaching Space: 1	Student Space (27)	
B016 - R0008 - Practical Activities - 1hb - (19.97 SQM)	Student Space (9)	
B017 - R0002 - Practical Activities - (19.12 SQM)	Student Space (8)	
B017 - R0004 - Home Base - (61.12 SQM) - Teaching Space: 1	Student Space (28)	
B017 - R0005 - Withdrawal Space - 2hb - (11.74 SQM)	Student Space (5)	
B017 - R0006 - Home Base - (61.22 SQM) - Teaching Space: 1	Student Space (28)	
B017 - R0008 - Practical Activities - (18.68 SQM)	Student Space (8)	
B017 - R0010 - Practical Activities - (19.01 SQM)	Student Space (8)	
B017 - R0011 - Withdrawal Space - 1hb - (7.66 SQM)	Student Space (3)	
B017 - R0013 - Home Base - (59.81 SQM) - Teaching Space: 1	Student Space (27)	
B017 - R1002 - Practical Activities - (19.22 SQM)	Student Space (8)	
B017 - R1004 - Home Base - (61.07 SQM) - Teaching Space: 1	Student Space (28)	
B017 - R1005 - Withdrawal Space - 2hb - (11.85 SQM)	Student Space (5)	
B017 - R1006 - Home Base - (61.19 SQM) - Teaching Space: 1	Student Space (28)	
B017 - R1008 - Practical Activities - (19.43 SQM)	Student Space (9)	
B017 - R1009 - Practical Activities - (19.08 SQM)	Student Space (8)	
B017 - R1010 - Withdrawal Space - 1hb - (7.66 SQM)	Student Space (3)	
B017 - R1012 - Home Base - (59.51 SQM) - Teaching Space: 1	Student Space (27)	
OS 601 11052 - OS 601 11052 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11240 - OS 601 11240 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11575 - OS 601 11575 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11642 - OS 601 11642 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13086 - OS 601 13086 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 15611 - OS 601 15611 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 11243 - OS 602 11243 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12869 - OS 602 12869 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 13029 - OS 603 13029 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 751 11602 - OS 751 11602 - Learning Unit - ESL - (76 SQM)	Student Space (35)	