


VENTILATION AUDIT REPORT

SCHOOL:	Fairvale High School (8456)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Fairfield
LOCAL GOVERNMENT AREA:	Fairfield

8456 - Fairvale High School
Site Plan (11993)



1:1,536

Printed: 03-Oct-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Senior Learning Centre - (37.72 SQM)	● Student Space (17)	
B00A - R0006 - Ancillary Staff - (23.92 SQM)	● Office (5)	
B00A - R0026 - General Learning Space - (51.19 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0030 - Laboratory L.S. - (91.88 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0031 - Preparation - Science - (29.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Laboratory L.S. - (84.06 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R0035 - Public Reception - (25.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Administration - Clerical - (8.25 SQM)	● Office (2)	
B00A - R0037 - Administration - Clerical - (12.64 SQM)	● Office (3)	
B00A - R0038 - Principal Office - (23.52 SQM)	● Office (5)	
B00A - R0040 - Administration - Clerical - (43.19 SQM)	● Office (10)	
B00A - R0041 - Administration - Clerical - (11.58 SQM)	● Office (2)	
B00A - R0042 - Pupil Entry - (7.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Interview/Office - Type 1 - (14.32 SQM)	● Office (3)	
B00A - R0045 - Interview/Office - Type 1 - (14.77 SQM)	● Office (3)	
B00A - R0047 - Movement - (9.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Administration - Clerical - (8.61 SQM)	● Office (2)	
B00A - R0049 - Deputy Principal Office - (19.38 SQM)	● Office (4)	
B00A - R0057 - Movement - (5.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0059 - Administration - Clerical - (61.56 SQM)	● Office (15)	
B00A - R0060 - Pupil Entry - (8.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - Deputy Principal Office - (16.59 SQM)	● Office (4)	
B00A - R0062 - Deputy Principal Office - (13.11 SQM)	● Office (3)	
B00A - R0063 - Deputy Principal Office - (13.14 SQM)	● Office (3)	
B00A - R0065 - Movement - (13.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Computer Learning Space - (51.26 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1006 - Computer Learning Space - (57.62 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1009 - General Learning Space - (52.2 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1010 - Materials Learning Space - Type 1 - (65.21 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1014 - Materials Learning Space - Type 1 - (70.68 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R1018 - General Learning Space - (50.97 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1022 - General Learning Space - (52.13 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1023 - General Learning Space - (51.98 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1029 - Staff Study - (26.06 SQM)	● Office (6)	
B00A - R1030 - Computer Learning Space - (51.05 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1031 - Staff Study - (46.68 SQM)	● Office (11)	
B00A - R1032 - Tea Room - (11.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R1036 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Kitchen - Type 2 - (78.63 SQM)	● Student Space (36)	
B00B - R0021 - Music Learning Space - (51.04 SQM)	● Student Space (23)	
B00B - R0029 - Welding Area - (8.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Metal Technology Bay - (38.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Food Technology L.S. - (37.83 SQM)	● Student Space (17)	
B00B - R0035 - Materials Learning Space - Type 1 - (62.88 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0036 - Welding/Hot Metals Area - (6.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0037 - Welding/Hot Metals Area - (7.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Materials Learning Space - Type 1 - (63.81 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0043 - Kitchen - Type 2 - (64.78 SQM)	● Student Space (30)	
B00B - R0045 - Food Technology L.S. - (38.92 SQM) - Teaching Space: 1	● Student Space (18)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0048 - Preparation - (16.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0050 - General Learning Space - (56.69 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0052 - General Learning Space - (49.74 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0056 - Food Technology L.S. - (44.95 SQM) - Teaching Space: 1	● Student Space (20)	
B00B - R0057 - Music Learning Space - (62.4 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R1004 - Art Learning Space - (61.14 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R1008 - Art Learning Space - (52.06 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1009 - Art Learning Space - (51.98 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1015 - Music Learning Space - (51.11 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1019 - Computer Learning Space - (57.25 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1021 - Wood Technology Bay - (17.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R1023 - Materials Learning Space - Type 1 - (83.86 SQM) - Teaching Space: 1	● Student Space (38)	
B00B - R1026 - Music Learning Space - (51.11 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1029 - Materials Learning Space - Type 1 - (71.71 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R1032 - Staff Study - (44.25 SQM)	● Office (11)	
B00C - R0004 - Student Canteen - (56.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - General Assistants - (11.09 SQM)	● Office (2)	
B00C - R0019 - Multi-Purpose Space - (315.14 SQM)	● Student Space (146)	
B00C - R0022 - Movement - (24.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (7.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Movement - (6.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - General Assistants - (13.98 SQM)	● Office (3)	
B00C - R1003 - Movement - (12.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - Movement - (12.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Staff Study - (38.99 SQM)	● Office (9)	
B00D - R0005 - Preparation - Science - (19.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Laboratory L.S. - (92.04 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0010 - Special Learning Space - (50.39 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0014 - Laboratory L.S. - (84.19 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0017 - Laboratory L.S. - (92.13 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0018 - Special Learning Space - (57.5 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0019 - Interview/Office - Type 1 - (13.21 SQM)	● Office (3)	
B00D - R0021 - General Learning Space - (50.76 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0027 - Dark Room - (24.18 SQM)	● Office (6)	
B00D - R0029 - Preparation - Science - (38.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0032 - Movement - (5.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - (57.33 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1006 - General Learning Space - (51.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1007 - General Learning Space - (52.42 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1008 - Seminar - (24.9 SQM)	● Office (6)	
B00D - R1014 - General Learning Space - (51.19 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1019 - Computer Learning Space - (57.32 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1022 - Seminar - (25.56 SQM)	● Office (6)	
B00D - R1025 - General Learning Space - (51.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1026 - General Learning Space - (52.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1027 - General Learning Space - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1030 - General Learning Space - (51.04 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1032 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1033 - Staff Study - (24.12 SQM)	Office (6)	
B00D - R1035 - Staff Study - (37.63 SQM)	Office (9)	
B00D - R1036 - Tea Room - (5.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R1038 - Movement - (5.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R1039 - General Learning Space - (52.15 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0001 - Computer Learning Space - (32.25 SQM) - Teaching Space: 1	Student Space (14)	
B00E - R0003 - Administration - Clerical - (13.1 SQM)	Office (3)	
B00E - R0004 - Deputy Principal Office - (19.37 SQM)	Office (4)	
B00E - R0005 - Student Waiting - (6.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Student Waiting - (6.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Deputy Principal Office - (19.44 SQM)	Office (4)	
B00E - R0008 - Administration - Clerical - (12.92 SQM)	Office (3)	
B00E - R0009 - Staff Study - (44.7 SQM)	Office (11)	
B00E - R0011 - Staff Study - (32.53 SQM)	Office (8)	
B00E - R0018 - Dark Room - (29.03 SQM)	Office (7)	
B00E - R0022 - General Learning Space - (52.7 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0030 - Staff Study - (6.42 SQM)	Office (1)	
B00E - R0034 - Leading Teacher - (19.42 SQM)	Office (4)	
B00E - R0038 - Movement Studio - (133.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0039 - Movement - (12.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R0041 - Staff Study - (45.34 SQM)	Office (11)	
B00E - R0042 - Tea Room - (6.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R0043 - Staff Study - (25.96 SQM)	Office (6)	
B00E - R0046 - Movement - (5.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0048 - Staff Kitchen - (8.66 SQM)	Office (2)	
B00E - R0049 - Interview/Office - Type 1 - (6.78 SQM)	Office (1)	
B00E - R0050 - Interview/Office - Type 1 - (6.81 SQM)	Office (1)	
B00E - R0051 - Movement - (7.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Laboratory L.S. - (86.09 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R1002 - Preparation - Science - (22.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R1005 - Laboratory L.S. - (92.6 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R1006 - Computer Learning Space - (32.59 SQM) - Teaching Space: 1	Student Space (15)	
B00E - R1009 - General Learning Space - (51.54 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1014 - Staff Study - (59.35 SQM)	Office (14)	
B00E - R1016 - General Learning Space - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1017 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1018 - General Learning Space - (59.41 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1019 - Interview/Office - Type 1 - (12.88 SQM)	Office (3)	
B00E - R1021 - General Learning Space - (51.39 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1028 - Movement - (5.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R1029 - Preparation - (30.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Seminar - (14.33 SQM)	Office (3)	
B00F - R0002 - Seminar - (14.73 SQM)	Office (3)	
B00F - R0003 - Seminar/Study - (14.66 SQM)	Office (3)	
B00F - R0004 - Main Entry - (17.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Audio Visual Workroom - (26.47 SQM)	Student Space (12)	
B00F - R0011 - Main Area - (403.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Senior Study - (58.42 SQM)	Office (14)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0019 - General Learning Space - (63.55 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R0006 - Fitness Laboratory - (52 SQM)	● Student Space (24)	
B00G - R0008 - Staff Kitchen - (19.91 SQM)	● Office (4)	
B00G - R0019 - Stage - (72.26 SQM)	Not Applicable	Circulation or storage space.
B00G - R0023 - Multi-Purpose Space - (596.02 SQM)	● Student Space (276)	
B00H - R0001 - Computer Learning Space - (91.88 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0002 - Seminar - Type 2 - (18.73 SQM)	● Office (4)	
B00I - R0001 - General Assistants - (28.1 SQM)	● Office (7)	
B00I - R0002 - General Assistants - (85.5 SQM)	● Office (21)	
B0WS - R0002 - Wood Technology Bay - (168.59 SQM)	Not Applicable	Circulation or storage space.
B0WS - R0004 - Movement - (66.74 SQM)	Not Applicable	Circulation or storage space.
NS 200 11728 - NS 200 11728 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
NS 200 13067 - NS 200 13067 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
NS 200 13345 - NS 200 13345 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 600 11038 - OS 600 11038 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 18341 - OS 600 18341 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 18343 - OS 600 18343 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19754 - OS 600 19754 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 11015 - OS 601 11015 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11734 - OS 601 11734 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11781 - OS 601 11781 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11853 - OS 601 11853 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12427 - OS 601 12427 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12900 - OS 601 12900 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13611 - OS 601 13611 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14171 - OS 601 14171 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14228 - OS 601 14228 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14342 - OS 601 14342 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14654 - OS 601 14654 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14890 - OS 601 14890 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 751 11903 - OS 751 11903 - Learning Unit - ESL - (76 SQM)	● Student Space (35)	
OS 751 16098 - OS 751 16098 - Learning Unit - ESL - (76 SQM)	● Student Space (35)	
OS 801 13485 - OS 801 13485 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.