

VENTILATION AUDIT REPORT

SCHOOL:	Fairvale Public School (4009)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Fairfield
LOCAL GOVERNMENT AREA:	Fairfield

4009 - Fairvale Public School
Site Plan (11677)



1:923

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0010 - Principal - (18.27 SQM)	Office (4)	
B00A - R0012 - Deputy Principal - (10.35 SQM)	Office (2)	
B00A - R0018 - Movement - (58.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Staff Kitchen - (21.72 SQM)	Office (5)	
B00A - R0027 - Movement - (10.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Clerical Office - (27.24 SQM)	Office (6)	
B00A - R0030 - Movement - (5.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Sick Bay - (7.2 SQM)	Student Space (3)	
B00A - R0038 - Entry Vestibule - (18.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Clerical/Printing - (21.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Staff Room - (58.75 SQM)	Office (14)	
B00A - R0042 - Staff Room Annexe - (10.52 SQM)	Office (2)	
B00B - R0007 - Interview - (14.3 SQM)	Office (3)	
B00B - R0008 - Movement - (12.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Home Base - (57.37 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0014 - Home Base - (57.2 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0018 - Movement - (14.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Withdrawal Space - 1hb - (19.12 SQM)	Student Space (8)	
B00B - R0023 - Home Base - (57.2 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0024 - Home Base - (57.04 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0027 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Home Base - (58.63 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0032 - Movement - (43.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Movement - (38.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Movement - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Special Programs Room - (58.63 SQM)	Student Space (27)	
B00C - R0003 - Special Programs Room - (39.94 SQM)	Student Space (18)	
B00C - R0009 - Movement - (11.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Movement - (140.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Reading Area - (222.36 SQM)	Student Space (103)	
B00D - R0007 - Interview - (13.76 SQM)	Office (3)	
B00D - R0011 - Movement - (94.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Practical Activities - (7.92 SQM)	Student Space (3)	
B00D - R0013 - Practical Activities - (7.92 SQM)	Student Space (3)	
B00D - R0014 - Practical Activities - (7.92 SQM)	Student Space (3)	
B00D - R0015 - Practical Activities - (7.92 SQM)	Student Space (3)	
B00D - R0016 - Practical Activities - (7.53 SQM)	Student Space (3)	
B00D - R0017 - Practical Activities - (6.8 SQM)	Student Space (3)	
B00D - R0018 - Home Base - (46.18 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0019 - Home Base - (45.26 SQM) - Teaching Space: 1	Student Space (20)	
B00D - R0020 - Home Base - (44.84 SQM) - Teaching Space: 1	Student Space (20)	
B00D - R0021 - Home Base - (44.99 SQM) - Teaching Space: 1	Student Space (20)	
B00D - R0022 - Home Base - (45 SQM) - Teaching Space: 1	Student Space (20)	
B00D - R0023 - Home Base - (45.06 SQM) - Teaching Space: 1	Student Space (20)	
B00E - R0001 - Home Base - (57.12 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0003 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (56.94 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0011 - Practical Activities - (6.33 SQM)	Student Space (2)	
B00E - R0012 - Practical Activities - (6.37 SQM)	Student Space (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0004 - Movement - (6.33 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Practical Activities - 1hb - (6.41 SQM)	● Student Space (2)	
B00F - R0014 - Outdoor Learning Area - (94.58 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Home Base - (65.58 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0017 - Practical Activities - (10.51 SQM)	● Student Space (4)	
B00F - R0018 - Isolation Space - (15.85 SQM)	● Office (3)	
B00F - R0021 - Practical Activities - (6.7 SQM)	● Student Space (3)	
B00F - R0022 - Home Base - (65.02 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R0001 - Home Base - (58.64 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0003 - Movement - (12.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Home Base - (58.64 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0011 - Practical Activities - (6.88 SQM)	● Student Space (3)	
B00G - R0012 - Practical Activities - (6.89 SQM)	● Student Space (3)	
B00H - R0005 - Movement - (18.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Interview - (17.89 SQM)	● Office (4)	
B00H - R0012 - Outdoor Learning Area - (132.16 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Practical Activities - (6.69 SQM)	● Student Space (3)	
B00H - R0015 - Practical Activities - (6.6 SQM)	● Student Space (3)	
B00H - R0017 - Home Base - (67.93 SQM) - Teaching Space: 1	● Student Space (31)	
B00H - R0018 - Home Base - (67.75 SQM) - Teaching Space: 1	● Student Space (31)	
B00I - R0013 - Practical Activities - (7.42 SQM)	● Student Space (3)	
B00I - R0014 - Practical Activities - (6.6 SQM)	● Student Space (3)	
B00I - R0016 - Home Base - (67.59 SQM) - Teaching Space: 1	● Student Space (31)	
B00I - R0017 - Home Base - (67.4 SQM) - Teaching Space: 1	● Student Space (31)	
B00J - R0005 - Canteen - (30.52 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Home Base - (47.08 SQM) - Teaching Space: 1	● Student Space (21)	
B00L - R0002 - Movement - (11.96 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00M - R0007 - Movement - (10.24 SQM)	Not Applicable	Circulation or storage space.
B00R - R0001 - Movement - (34.75 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Practical Activities - 1hb - (19.98 SQM)	● Student Space (9)	
B00R - R0004 - Home Base - (59.04 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R0005 - Withdrawal Space - 2hb - (11.65 SQM)	● Student Space (5)	
B00R - R0006 - Home Base - (59.05 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R0008 - Practical Activities - 1hb - (19.99 SQM)	● Student Space (9)	
B00S - R0014 - Communal Space - (204.99 SQM)	● Student Space (95)	
B00S - R0015 - Movement - (17.72 SQM)	Not Applicable	Circulation or storage space.
B00S - R0016 - Raised Platform - (57.77 SQM)	Not Applicable	Circulation or storage space.
B00S - R0017 - Movement - (12.72 SQM)	Not Applicable	Circulation or storage space.
OS 601 10377 - OS 601 10377 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10372 - OS 602 10372 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 751 11494 - OS 751 11494 - Learning Unit - ESL - (76 SQM)	● Student Space (35)	