


VENTILATION AUDIT REPORT

SCHOOL:	Fairy Meadow Public School (1898)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Keira
LOCAL GOVERNMENT AREA:	Wollongong

1898 - Fairy Meadow Public School
Site Plan (12514)



1:992

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0012 - Home Base - (67.63 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0014 - Home Base - (66.09 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0016 - Withdrawal Space - 1hb - (17.75 SQM)	● Student Space (8)	
B00A - R0018 - Home Base - M - (67.31 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0019 - Movement - (5.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (9.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (62.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Movement - (178.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Movement - (43.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Staff Room - (75.58 SQM)	● Office (18)	
B00A - R0039 - Sick Bay - (25.72 SQM)	● Student Space (11)	
B00A - R0040 - Duplicating Workroom - (40.76 SQM)	● Office (10)	
B00A - R0044 - Movement - (11.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Interview - (13.25 SQM)	● Office (3)	
B00A - R0049 - Seminar/Study - (14.95 SQM)	● Office (3)	
B00A - R0050 - Interview - (6.83 SQM)	● Office (1)	
B00A - R0056 - Raised Platform - (46.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0062 - Communal Space - (222.8 SQM)	● Student Space (103)	
B00A - R0065 - Movement - (8.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0067 - Clerical Office - (13.93 SQM)	● Office (3)	
B00A - R0068 - Deputy Principal - (14.68 SQM)	● Office (3)	
B00A - R0072 - Principal - (24.44 SQM)	● Office (6)	
B00A - R0073 - Deputy Principal - (14.96 SQM)	● Office (3)	
B00A - R0074 - Entry Vestibule - (76.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0077 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0083 - Reading Area - (201.98 SQM)	● Student Space (93)	
B00A - R0086 - Movement - (81.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0087 - Canteen - (29.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - Movement - (80.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Home Base - (67.88 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1009 - Home Base - (65.77 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1011 - Practical Activities - 1hb - (17.61 SQM)	● Student Space (8)	
B00A - R1013 - Home Base - (67.31 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1017 - Home Base - (66.26 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1018 - Movement - (39.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R1019 - Movement - (117.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Home Base - (65.69 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1024 - Home Base - (67.8 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1026 - Home Base - M - (65.85 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1029 - Home Base - (67.56 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1031 - Home Base - (65.93 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1033 - Withdrawal Space - 1hb - (17.67 SQM)	● Student Space (8)	
B00A - R1034 - Home Base - (66.91 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1041 - Home Base - (144.99 SQM) - Teaching Space: 1	● Student Space (67)	
B00A - R1044 - Home Base - (65.53 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0004 - Communal Space - (81.66 SQM)	● Student Space (37)	
B00B - R0005 - Movement - (5.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (151.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (13.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Communal Space - (135.98 SQM)	● Student Space (63)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0019 - Raised Platform - (26.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Withdrawal Space - 1hb - (11.93 SQM)	● Student Space (5)	
B00B - R0021 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R0039 - Movement - (63.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0045 - Movement - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0046 - Movement - (8.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0048 - Movement - (16.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0052 - Home Base - (80.17 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R0053 - Practical Activities - 1hb - (20.58 SQM)	● Student Space (9)	
B00B - R0056 - Withdrawal Space - 2hb - (12.71 SQM)	● Student Space (5)	
B00B - R0057 - Practical Activities - 1hb - (20.54 SQM)	● Student Space (9)	
B00B - R0058 - Home Base - (80.27 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R0060 - Home Base - (60.47 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0061 - Practical Activities - 1hb - (18.13 SQM)	● Student Space (8)	
B00B - R0062 - Withdrawal Space - 1hb - (8.97 SQM)	● Student Space (4)	
B00B - R0063 - Home Base - (60.18 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0064 - Practical Activities - 1hb - (15.6 SQM)	● Student Space (7)	
B00B - R0066 - Special Programs Room - (29.63 SQM)	● Student Space (13)	
B00B - R0067 - Withdrawal Space - 2hb - (33.28 SQM)	● Student Space (15)	
B00B - R0070 - Home Base - (59.78 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0071 - Practical Activities - 1hb - (15.4 SQM)	● Student Space (7)	
B00B - R0073 - Withdrawal Space - 1hb - (8.98 SQM)	● Student Space (4)	
B00B - R0074 - Practical Activities - 1hb - (19.2 SQM)	● Student Space (8)	
B00B - R0075 - Home Base - (60.39 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0079 - Practical Activities - (22.33 SQM)	● Student Space (10)	
B00B - R0081 - Withdrawal Space - 1hb - (32.68 SQM)	● Student Space (15)	
B00B - R0083 - Withdrawal Space - 1hb - (22.71 SQM)	● Student Space (10)	
B00B - R0085 - Home Base - (50.31 SQM) - Teaching Space: 1	● Student Space (23)	
B00I - R0001 - Movement - (31.02 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Home Base - Pre - (84.79 SQM) - Teaching Space: 1	● Student Space (39)	
B00I - R0007 - Withdrawal - Pre - (12.14 SQM)	● Student Space (5)	
B00I - R0010 - Entry Vestibule - (8.09 SQM)	Not Applicable	Circulation or storage space.
B00I - R0018 - Movement - (20.02 SQM)	Not Applicable	Circulation or storage space.