


VENTILATION AUDIT REPORT

SCHOOL:	Farmborough Road Public School (3976)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Wollongong
LOCAL GOVERNMENT AREA:	Wollongong

3976 - Farmborough Road Public School
Site Plan (11837)























1:1,334

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Deputy Principal - (12.92 SQM)	Office (3)	
B00A - R0004 - Deputy Principal - (12.6 SQM)	Office (3)	
B00A - R0008 - Sick Bay - (12.64 SQM)	Student Space (5)	
B00A - R0009 - Clerical Office - (12.6 SQM)	Office (3)	
B00A - R0010 - Entry Vestibule - (19.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Interview - (11.7 SQM)	Office (2)	
B00A - R0012 - Principal - (20.31 SQM)	Office (5)	
B00A - R0013 - Movement - (5.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Clerical Office/Workroom - (31.56 SQM)	Office (7)	
B00A - R0018 - Movement - (26.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Staff Room - (48.39 SQM)	Office (12)	
B00A - R0023 - Staff Kitchen - (22.21 SQM)	Office (5)	
B00B - R0001 - Communal Space - (237.17 SQM)	Student Space (110)	
B00B - R0006 - Movement - (53.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Canteen - (46.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Raised Platform - (32.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Special Programs Room - (12.15 SQM)	Student Space (5)	
B00C - R0014 - Reading Area - (221.26 SQM)	Student Space (102)	
B00C - R0015 - Special Programs Room - (23.28 SQM)	Student Space (10)	
B00D - R0001 - Home Base - (58.17 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0004 - Practical Activities - 1hb - (39.41 SQM)	Student Space (18)	
B00D - R0007 - Home Base - (55.93 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0009 - Withdrawal Space - 1hb - (12.28 SQM)	Student Space (5)	
B00E - R0001 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0002 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0003 - Home Base - (56 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0005 - Staff Room Annexe - (16.02 SQM)	Office (4)	
B00E - R0006 - Movement - (20.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Interview - (17.26 SQM)	Office (4)	
B00E - R0010 - Movement - (10.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0013 - Movement - (76.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (17.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Home Base - (53.29 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R9007 - Special Programs Room - (62.12 SQM)	Student Space (28)	
B00F - R0007 - Movement - (73.26 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0009 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0010 - Withdrawal Space - 1hb - (12.63 SQM)	Student Space (5)	
B00F - R0011 - Staff Room Annexe - (9.43 SQM)	Office (2)	
B00F - R0012 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0013 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0002 - Home Base - (58.45 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0003 - Home Base - (77.42 SQM) - Teaching Space: 1	Student Space (35)	
B00H - R0001 - Home Base - (60.48 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0004 - Withdrawal Space - 1hb - (12.53 SQM)	Student Space (5)	
B00H - R0005 - Home Base - (56.2 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0008 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
B00H - R0010 - Practical Activities - 1hb - (40.4 SQM)	 Student Space (18)	
B00H - R0012 - Special Programs Room - (28.71 SQM)	 Student Space (13)	
B00H - R0013 - Movement - (38.85 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Practical Activities - 1hb - (45.6 SQM)	 Student Space (21)	
B00H - R0021 - Home Base - (57.6 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R0022 - Staff Room Annexe - (11.9 SQM)	 Office (2)	
B00H - R0023 - Home Base - (59.39 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0025 - Practical Activities - 1hb - (25.07 SQM)	 Student Space (11)	
B00H - R0026 - Withdrawal Space - 1hb - (10.87 SQM)	 Student Space (5)	
B00H - R0027 - Practical Activities - 1hb - (13.66 SQM)	 Student Space (6)	
B00H - R0033 - Special Programs Room - (7.78 SQM)	 Student Space (3)	
B00H - R9001 - Special Programs Room - (56.9 SQM)	 Student Space (26)	
B00H - R9004 - Practical Activities - 1hb - (9.95 SQM)	 Student Space (4)	
B00H - R9005 - Staff Room Annexe - (10.89 SQM)	 Office (2)	
B00H - R9006 - Home Base - (54.35 SQM) - Teaching Space: 1	 Student Space (25)	
B00H - R9009 - Home Base - (58.57 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R9012 - Practical Activities - 1hb - (13.38 SQM)	 Student Space (6)	
B00H - R9014 - Withdrawal Space - 1hb - (11.39 SQM)	 Student Space (5)	
B00H - R9015 - Home Base - (56.24 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R9017 - Practical Activities - 1hb - (26.08 SQM)	 Student Space (12)	