


VENTILATION AUDIT REPORT

SCHOOL:	Falconbridge Public School (4354)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blue Mountains
LOCAL GOVERNMENT AREA:	Blue Mountains

4354 - Falconbridge Public School
Site Plan (12982)






1.984

Printed: 17-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (10.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office - (10.61 SQM)	Office (2)	
B00A - R0003 - Principal - (20.75 SQM)	Office (5)	
B00A - R0004 - Sick Bay - (13.57 SQM)	Student Space (6)	
B00A - R0006 - Movement - (29.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Duplicating Workroom - (20.19 SQM)	Office (5)	
B00A - R0009 - Staff Room - (36.31 SQM)	Office (9)	
B00A - R0012 - Clerical Office - (11.65 SQM)	Office (2)	
B00A - R0017 - Home Base - (56.65 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0020 - Movement - (5.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Home Base - (55.4 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0025 - Staff Room Annexe - (27.9 SQM)	Office (6)	
B00A - R0026 - Movement - (19.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Interview - (19.15 SQM)	Office (4)	
B00A - R0028 - Principal - (19.05 SQM)	Office (4)	
B00A - R0029 - Entry Vestibule - (25.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Clerical Office - (21.47 SQM)	Office (5)	
B00A - R0032 - Clerical Office - (14.47 SQM)	Office (3)	
B00B - R0002 - Movement - (29.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Home Base - (67.01 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0005 - Home Base - (67.01 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0001 - Movement - (73.87 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (65.13 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0004 - Practical Activities - 1hb - (15.84 SQM)	Student Space (7)	
B00C - R0005 - Special Programs Room - (55.04 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0006 - Home Base - (54.65 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0007 - Practical Activities - 1hb - (15.84 SQM)	Student Space (7)	
B00C - R0008 - Practical Activities - 1hb - (15.84 SQM)	Student Space (7)	
B00C - R0009 - Home Base - (54.88 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R9001 - Raised Platform - (26.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R9002 - Practical Activities - (147.87 SQM)	Student Space (68)	
B00D - R0005 - Home Base - (80.96 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R0008 - Home Base - (56.59 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0013 - Interview - (14.05 SQM)	Office (3)	
B00D - R0014 - Practical Activities - 1hb - (15.74 SQM)	Student Space (7)	
B00D - R0015 - Home Base - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0016 - Movement - (93.71 SQM)	Not Applicable	Circulation or storage space.
B00D - R9002 - Practical Activities - (128.24 SQM)	Student Space (59)	
B00D - R9007 - Movement - (9.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Communal Space - (148.92 SQM)	Student Space (69)	
B00E - R0002 - Raised Platform - (58.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (6.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (12.41 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Reading Area - (167.3 SQM)	Student Space (77)	
B00W - R0006 - Canteen - (29.63 SQM)	Not Applicable	Circulation or storage space.
B00Y - R0001 - Outdoor Learning Area - (44.94 SQM)	Not Applicable	Circulation or storage space.
B00Y - R0005 - Movement - (82.04 SQM)	Not Applicable	Circulation or storage space.
B00Y - R0006 - Home Base - (85.45 SQM) - Teaching Space: 1	Student Space (39)	
B00Y - R0007 - Home Base - (57.34 SQM) - Teaching Space: 1	Student Space (26)	
B00Y - R0010 - Movement - (26.67 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Y - R0011 - Interview - (19.43 SQM)	 Office (4)	
B00Y - R0020 - Special Programs Room - (57.35 SQM)	 Student Space (26)	
B00Z - R0002 - Movement - (41.21 SQM)	Not Applicable	Circulation or storage space.
OS 602 16374 - OS 602 16374 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	