

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Fernhill School (5768)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Mulgoa</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Penrith</b>

5768 - Fernhill School  
Site Plan (13612)



















1:979

Printed: 15-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (19.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Interview - (12.9 SQM)	Office (3)	
B00A - R0004 - Movement - (59.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Interview - (12.75 SQM)	Office (3)	
B00A - R0006 - Principal - (16.77 SQM)	Office (4)	
B00A - R0012 - Staff Room - (101.37 SQM)	Office (25)	
B00A - R0013 - Staff Kitchen - (10.32 SQM)	Office (2)	
B00A - R0016 - Special Programs Room - (55.38 SQM)	Student Space (25)	
B00A - R0017 - Reading Area - (91.34 SQM)	Student Space (42)	
B00A - R0020 - Interview - (13.05 SQM)	Office (3)	
B00A - R0021 - Deputy Principal - (12.89 SQM)	Office (3)	
B00A - R0024 - Sick Bay - (10.94 SQM)	Student Space (5)	
B00A - R0025 - Clerical Office - (52.85 SQM)	Office (13)	
B00A - R0027 - Movement - (8.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Communal Space - (116.22 SQM)	Student Space (53)	
B00B - R0003 - Special Programs Room - (39.29 SQM)	Student Space (18)	
B00B - R0011 - Seminar/Study - (28.75 SQM)	Office (7)	
B00C - R0002 - Movement - (9.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (98.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Clerical Office - (11.4 SQM)	Office (2)	
B00C - R0013 - Hydrotherapy - Pool - (99.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities/Movement - 2hb - (25.48 SQM)	Student Space (11)	
B00D - R0003 - Practical Activities/Movement - 2hb - (41.96 SQM)	Student Space (19)	
B00D - R0004 - Home Base - M - (58.75 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0005 - Withdrawal - M - (12.83 SQM)	Student Space (5)	
B00D - R0009 - Home Base - M - (59.86 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0010 - Withdrawal - M - (12.78 SQM)	Student Space (5)	
B00D - R0012 - Home Base - M - (59.8 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0013 - Withdrawal - M - (12.75 SQM)	Student Space (5)	
B00D - R0017 - Home Base - M - (58.97 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0019 - Withdrawal - M - (12.72 SQM)	Student Space (5)	
B00E - R0002 - Practical Activities/Movement - 2hb - (25.48 SQM)	Student Space (11)	
B00E - R0003 - Practical Activities/Movement - 2hb - (41.96 SQM)	Student Space (19)	
B00E - R0004 - Home Base - M - (58.91 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0005 - Withdrawal - M - (12.77 SQM)	Student Space (5)	
B00E - R0009 - Home Base - M - (59.7 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0010 - Withdrawal - M - (12.77 SQM)	Student Space (5)	
B00E - R0012 - Home Base - M - (59.7 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0013 - Withdrawal - M - (12.78 SQM)	Student Space (5)	
B00E - R0017 - Home Base - M - (58.92 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0019 - Withdrawal - M - (12.78 SQM)	Student Space (5)	
B00E - R0026 - Communal Space - (309.91 SQM)	Student Space (143)	
B00F - R0002 - Practical Activities/Movement - 4hb - (67.85 SQM)	Student Space (31)	
B00F - R0003 - Home Base - M - (59.8 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0004 - Withdrawal - M - (12.78 SQM)	Student Space (5)	
B00F - R0008 - Home Base - M - (59.7 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0010 - Withdrawal - M - (12.78 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0012 - Home Base - M - (59.73 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0013 - Withdrawal - M - (12.7 SQM)	 Student Space (5)	
B00F - R0017 - Home Base - M - (59.73 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0019 - Withdrawal - M - (12.75 SQM)	 Student Space (5)	
B00F - R0020 - Communal Space - (334.66 SQM)	 Student Space (155)	
B00G - R0002 - Practical Activities/Movement - 4hb - (84.18 SQM)	 Student Space (39)	
B00G - R0003 - Home Base - M - (60.76 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0004 - Withdrawal - M - (11.51 SQM)	 Student Space (5)	
B00G - R0006 - Withdrawal - M - (11.51 SQM)	 Student Space (5)	
B00G - R0007 - Home Base - M - (61.03 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0016 - Home Base - M - (60.76 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0017 - Withdrawal - M - (11.49 SQM)	 Student Space (5)	
B00G - R0019 - Withdrawal - M - (11.49 SQM)	 Student Space (5)	
B00G - R0020 - Home Base - M - (60.76 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0021 - Outdoor Learning Area - (14.45 SQM)	Not Applicable	Circulation or storage space.
OS 621 19450 - OS 621 19450 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	
OS 621 19535 - OS 621 19535 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	