


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Fingal Head Public School (1915)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Tweed</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Tweed</b>



1915 - Fingal Head Public School  
Site Plan (12518)











1:661

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Practical Activities - 1hb - (21.16 SQM)	 Student Space (9)	
B00A - R0002 - Home Base - (47.97 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0003 - Home Base - (48.14 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0005 - Practical Activities - 1hb - (21.24 SQM)	 Student Space (9)	
B00A - R0006 - Canteen - (12.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (6.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Staff Kitchen - (10.49 SQM)	 Office (2)	
B00C - R0008 - Principal - (10.48 SQM)	 Office (2)	
B00G - R0001 - Communal Space - (76.22 SQM)	 Student Space (35)	
B00G - R0002 - Movement - (7.44 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Canteen - (7.81 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Reading Area - (91.82 SQM)	 Student Space (42)	