

VENTILATION AUDIT REPORT

SCHOOL:	Finigan School of Distance Education (4661)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Monaro
LOCAL GOVERNMENT AREA:	Queanbeyan-Palerang

4661 - Finigan School of Distance Education
Site Plan (10519)



1:1,495

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B0F1 - R0001 - Home Base - (34.07 SQM) - Teaching Space: 1	● Student Space (15)	
B0F1 - R0002 - Interview - (13.85 SQM)	● Office (3)	
B0F1 - R0003 - Interview - (14.08 SQM)	● Office (3)	
B0F1 - R0005 - Entry Vestibule - (20.07 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R0008 - Movement - (37.41 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R0011 - Teachers Aide Special Ed - (11.73 SQM)	● Office (2)	
B0F1 - R0012 - Principal - (21.89 SQM)	● Office (5)	
B0F1 - R0013 - Deputy Principal - Type 1 - (11.79 SQM)	● Office (2)	
B0F1 - R0014 - Deputy Principal - Type 1 - (11.79 SQM)	● Office (2)	
B0F1 - R0015 - Deputy Principal - Type 1 - (11.79 SQM)	● Office (2)	
B0F1 - R0016 - Sick Bay - (6.26 SQM)	● Student Space (2)	
B0F1 - R0017 - Entry Vestibule - (12.88 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R0019 - Movement - (15.85 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R0025 - Home Base - (61.5 SQM) - Teaching Space: 1	● Student Space (28)	
B0F1 - R0026 - Home Base - (56.76 SQM) - Teaching Space: 1	● Student Space (26)	
B0F1 - R0039 - Movement - (11.74 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R0040 - Clerical Office - (84.34 SQM)	● Office (21)	
B0F1 - R0043 - Staff Room - (23.03 SQM)	● Office (5)	
B0F1 - R0044 - Clerical Office/Workroom - (33.37 SQM)	● Office (8)	
B0F1 - R0045 - Clerical Office - (13.03 SQM)	● Office (3)	
B0F1 - R0046 - Clerical Office - (25.09 SQM)	● Office (6)	
B0F1 - R0048 - Clerical Office - (22.23 SQM)	● Office (5)	
B0F1 - R0049 - Movement - (156.43 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R0050 - Communal Space - (114.09 SQM)	● Student Space (52)	
B0F1 - R0051 - Entry Vestibule - (32.55 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R0060 - Movement - (33.2 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R1002 - Movement - (16.12 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R1003 - Home Base - (30.01 SQM) - Teaching Space: 1	● Student Space (13)	
B0F1 - R1004 - Home Base - (32.16 SQM) - Teaching Space: 1	● Student Space (14)	
B0F1 - R1005 - Movement - (43.77 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R1006 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R1007 - Movement - (25.11 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R1009 - Movement - (154.84 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R1017 - Staff Kitchen - (19.06 SQM)	● Office (4)	
B0F1 - R1020 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R1023 - Movement - (8.33 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R1027 - Home Base - (42.99 SQM) - Teaching Space: 1	● Student Space (19)	
B0F1 - R1029 - Staff Room - (45.33 SQM)	● Office (11)	
B0F1 - R1038 - Movement - (23.14 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R2002 - Movement - (40.88 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R2010 - Staff Kitchen - (24.26 SQM)	● Office (6)	
B0F1 - R2011 - Movement - (231.66 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R2015 - Movement - (6.7 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R2033 - Staff Kitchen - (19.78 SQM)	● Office (4)	
B0F1 - R2042 - Movement - (61.9 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R9001 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.