

VENTILATION AUDIT REPORT

SCHOOL:	Fisher Road School (5405)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Wakehurst
LOCAL GOVERNMENT AREA:	Northern Beaches

5405 - Fisher Road School
Site Plan (10379)



1:692

Printed: 20-May-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Staff Room - (32.03 SQM)	Office (8)	
B00A - R0006 - Entry Vestibule - (27.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Clerical Office - (12.89 SQM)	Office (3)	
B00A - R0010 - Duplicating Workroom - (12.62 SQM)	Office (3)	
B00A - R0014 - Deputy Principal - (15.65 SQM)	Office (3)	
B00A - R0015 - Principal - (15.74 SQM)	Office (3)	
B00A - R0016 - Home Base - M - (46.02 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0017 - Practical Activities - M - 1hb - (7.87 SQM)	Student Space (3)	
B00A - R0024 - Practical Activities - M - 1hb - (6.61 SQM)	Student Space (3)	
B00A - R0025 - Home Base - M - (45.82 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0030 - Home Base - M - (44.09 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0038 - Home Base - M - (46.02 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0042 - Staff Room - (7.67 SQM)	Office (1)	
B00A - R0053 - Staff Room - (18.83 SQM)	Office (4)	
B00B - R0001 - Hydrotherapy - Pool - (235.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Special Programs Room - (61.23 SQM)	Student Space (28)	
B00C - R0014 - Practical Activities - P - 1hb - (68.71 SQM)	Student Space (31)	
B00D - R0002 - Home Base - M - (46.13 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0004 - Practical Activities - M - 1hb - (8.39 SQM)	Student Space (3)	
B00D - R0010 - Movement - (14.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Practical Activities - M - 1hb - (8.39 SQM)	Student Space (3)	
B00D - R0013 - Home Base - M - (46.57 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0014 - Withdrawal - M - (12.89 SQM)	Student Space (5)	
B00D - R0016 - Home Base - M - (65.9 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0021 - Communal Space - (79.6 SQM)	Student Space (36)	
B00D - R0023 - Canteen - (19.76 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities - 1hb - (19.37 SQM)	Student Space (8)	
B00H - R0004 - Home Base - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	Student Space (4)	
B00H - R0006 - Home Base - (58.69 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.37 SQM)	Student Space (8)	
OS 601 13995 - OS 601 13995 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14906 - OS 601 14906 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 16309 - OS 601 16309 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	