

VENTILATION AUDIT REPORT

SCHOOL:	Five Dock Public School (1920)
AMU REGION:	Sydney
STATE ELECTORATE:	Drummoyne
LOCAL GOVERNMENT AREA:	Canada Bay

1920 - Five Dock Public School
Site Plan (12519)



1:713

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Entry Vestibule - (20.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Movement - (22.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Clerical Office - (13.83 SQM)	Office (3)	
B00A - R0006 - Interview - (14.7 SQM)	Office (3)	
B00A - R0007 - Duplicating Workroom - (26.04 SQM)	Office (6)	
B00A - R0008 - Interview - (8.52 SQM)	Office (2)	
B00A - R0009 - Principal - (16.84 SQM)	Office (4)	
B00A - R0011 - Staff Room - (47.08 SQM)	Office (11)	
B00A - R0012 - Home Base - (46.81 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0013 - Home Base - (47.13 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0015 - Movement - (22.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Interview - (13.23 SQM)	Office (3)	
B00A - R0031 - Home Base - (61 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0032 - Movement - (66.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Home Base - (41 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R1003 - Home Base - (48.29 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1004 - Home Base - (47.97 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1005 - Home Base - (48.16 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1006 - Home Base - (48.34 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1007 - Home Base - (48.29 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1010 - Movement - (7.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Movement - (15.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Movement - (47.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Home Base - (79.92 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R1015 - Practical Activities - 1hb - (11.14 SQM)	Student Space (5)	
B00A - R1016 - Staff Room Annexe - (9.16 SQM)	Office (2)	
B00A - R1018 - Withdrawal Space - 1hb - (19.47 SQM)	Student Space (9)	
B00A - R1019 - Movement - (23.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R9003 - Movement - (6.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (47.22 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0003 - Home Base - (47.16 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0004 - Home Base - (47.04 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0005 - Home Base - (46.91 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0006 - Home Base - (47.03 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0007 - Home Base - (47.23 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0016 - Movement - (24.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (23.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (56.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Canteen - (32.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Reading Area - (226.45 SQM)	Student Space (105)	
B00E - R0007 - Home Base - (52.91 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0009 - Clerical Office - (19.79 SQM)	Office (4)	
B00E - R0015 - Home Base - (54.41 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0019 - Home Base - (46.72 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0020 - Home Base - (52.16 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0022 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Movement - (53.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Home Base - (47.19 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0027 - Home Base - (94.18 SQM) - Teaching Space: 1	Student Space (43)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0013 - Practical Activities - Pre - (43.35 SQM)	● Student Space (20)	
B00F - R0014 - Practical Activities - Pre - (28.8 SQM)	● Student Space (13)	
B00F - R0017 - Withdrawal - Pre - (7.65 SQM)	● Student Space (3)	
B00J - R0001 - Communal Space - (145.21 SQM)	● Student Space (67)	
B00J - R0002 - Raised Platform - (59.08 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Movement - (7.07 SQM)	Not Applicable	Circulation or storage space.
B00J - R0017 - Movement - (12.43 SQM)	Not Applicable	Circulation or storage space.
B00J - R0019 - Movement - (13 SQM)	Not Applicable	Circulation or storage space.