

VENTILATION AUDIT REPORT

| | |
|-------------------------------|--|
| SCHOOL: | Five Islands Secondary College (8373) |
| AMU REGION: | Southern NSW |
| STATE ELECTORATE: | Wollongong |
| LOCAL GOVERNMENT AREA: | Wollongong |

8373 - Five Islands Secondary College
Site Plan (11665)



1:1,473

Printed: 31-Jul-2021

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0025 - Movement - (54.92 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0028 - Preparation - Materials - (18.53 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0029 - Kitchen - Type 1 - (103.87 SQM) | ● Student Space (48) | |
| B00A - R0031 - Kitchen - Type 1 - (65.36 SQM) | ● Student Space (30) | |
| B00A - R0032 - Staff Study - (46.99 SQM) | ● Office (11) | |
| B00A - R0033 - Movement - (67.65 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0035 - Practical Activities - (76.17 SQM) | ● Student Space (35) | |
| B00A - R0036 - General Learning Space - (151.02 SQM) - Teaching Space: 1 | ● Student Space (70) | |
| B00A - R0037 - General Learning Space - (34.63 SQM) - Teaching Space: 1 | ● Student Space (16) | |
| B00A - R0039 - General Learning Space - (46.66 SQM) - Teaching Space: 1 | ● Student Space (21) | |
| B00A - R1001 - Movement - (33.43 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1004 - Seminar - (13.27 SQM) | ● Office (3) | |
| B00A - R1005 - Seminar - (13.27 SQM) | ● Office (3) | |
| B00A - R1007 - Seminar - (12.89 SQM) | ● Office (3) | |
| B00A - R1008 - Seminar - (12.78 SQM) | ● Office (3) | |
| B00A - R1009 - Main Area - (407.27 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1011 - Workroom - (24.6 SQM) | ● Office (6) | |
| B00A - R1013 - Duplicating Workroom - (51.25 SQM) | ● Office (12) | |
| B00A - R1014 - Seminar - (52.78 SQM) | ● Office (13) | |
| B00A - R1015 - Movement - (25.49 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1017 - Movement - (47.99 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1019 - Staff Study - (19.97 SQM) | ● Office (4) | |
| B00B - R0001 - Commonroom - (75.37 SQM) | ● Office (18) | |
| B00B - R0002 - Movement - (15.76 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0003 - Laboratory L.S. - (87.43 SQM) - Teaching Space: 1 | ● Student Space (40) | |
| B00B - R0004 - Staff Study - (28.36 SQM) | ● Office (7) | |
| B00B - R0005 - Staff Study - (18.62 SQM) | ● Office (4) | |
| B00B - R0008 - Movement - (108.6 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0010 - Staff Study - (13.48 SQM) | ● Office (3) | |
| B00B - R0014 - Tiered Learning Area - (52.15 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00B - R0015 - Preparation - (22.95 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0017 - Laboratory L.S. - (90.82 SQM) - Teaching Space: 1 | ● Student Space (42) | |
| B00B - R1002 - General Learning Space - (52.27 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00B - R1003 - General Learning Space - (51.7 SQM) - Teaching Space: 1 | ● Student Space (23) | |
| B00B - R1004 - General Learning Space - (51.63 SQM) - Teaching Space: 1 | ● Student Space (23) | |
| B00B - R1005 - Staff Study - (25.97 SQM) | ● Office (6) | |
| B00B - R1008 - Movement - (133.39 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1010 - General Learning Space - (52.57 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00B - R1011 - Staff Study - (20.87 SQM) | ● Office (5) | |
| B00B - R1012 - General Learning Space - (51.77 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00B - R1013 - General Learning Space - (65.03 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00B - R1014 - Staff Study - (19.59 SQM) | ● Office (4) | |
| B00C - R0001 - Movement - (36.43 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0003 - Clinic - Girls - (15.7 SQM) | ● Office (3) | |
| B00C - R0005 - Staff Study - (10.34 SQM) | ● Office (2) | |
| B00C - R0006 - Interview/Office - Type 1 - (10.4 SQM) | ● Office (2) | |
| B00C - R0007 - Interview/Office - Type 1 - (10.34 SQM) | ● Office (2) | |
| B00C - R0008 - Movement - (34.34 SQM) | Not Applicable | Circulation or storage space. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00C - R0011 - Teachers Aides - (8.11 SQM) | Office (2) | |
| B00C - R0012 - Movement - (53.37 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0013 - Interview/Office - Type 1 - (17.5 SQM) | Office (4) | |
| B00C - R0014 - Deputy Principal Office - (17.25 SQM) | Office (4) | |
| B00C - R0015 - Deputy Principal Office - (17.25 SQM) | Office (4) | |
| B00C - R0017 - Administration - Clerical - (25.37 SQM) | Office (6) | |
| B00C - R0018 - Administration - Clerical - (56.17 SQM) | Office (14) | |
| B00C - R0019 - Movement - (19.78 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0021 - Duplicating Workroom - (21.99 SQM) | Office (5) | |
| B00C - R0022 - Principal Office - (24.26 SQM) | Office (6) | |
| B00C - R0025 - Interview/Office - Type 1 - (16.85 SQM) | Office (4) | |
| B00C - R0030 - Clinic - Boys - (7.96 SQM) | Office (1) | |
| B00C - R0031 - Movement - (87.88 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R1001 - General Learning Space - (52.57 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00C - R1002 - General Learning Space - (51.78 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00C - R1003 - General Learning Space - (52.13 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00C - R1004 - General Learning Space - (65.04 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00C - R1007 - Staff Study - (29.33 SQM) | Office (7) | |
| B00C - R1010 - Movement - (125.62 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R1011 - Performance Workspace - (52.5 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00C - R1014 - General Learning Space - (51.85 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00C - R1017 - Staff Study - (25.25 SQM) | Office (6) | |
| B00C - R1019 - Performance Workspace - (65.03 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00C - R1020 - General Learning Space - (52.78 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00D - R0007 - Staff Study - (31.09 SQM) | Office (7) | |
| B00D - R0008 - Design L.S. - (65.87 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00D - R0011 - Materials Technology L.S. - (77.22 SQM) - Teaching Space: 1 | Student Space (35) | |
| B00D - R0021 - Materials Technology L.S. - (166.93 SQM) - Teaching Space: 1 | Student Space (77) | |
| B00D - R0026 - Materials Technology L.S. - (196.62 SQM) - Teaching Space: 1 | Student Space (91) | |
| B00D - R0027 - Movement - (27.48 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R9006 - Staff Study - (6.02 SQM) | Office (1) | |
| B00E - R0004 - Student Canteen - (236.01 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0005 - Student Canteen - (34.76 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0006 - Student Canteen - (7.04 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0008 - Student Canteen - (5.09 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0001 - Multi-Purpose Space - (411.77 SQM) | Student Space (191) | |
| B00F - R0003 - Pupil Entry - (6.62 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0004 - Stage - (91.44 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0005 - Movement - (20.32 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R9003 - General Assistants - (27.87 SQM) | Office (6) | |
| B00G - R0001 - Practice/Seminar - (24.49 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0006 - General Learning Space - (53.52 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00G - R0007 - Movement - (14.59 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0008 - Movement - (17.66 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0009 - Music Learning Space - (53.65 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00H - R0001 - Movement - (290.24 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0005 - Art Learning Space - (51.99 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00H - R0006 - Art Learning Space - (58.59 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00H - R0009 - Staff Study - (25.6 SQM) | Office (6) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00H - R0013 - Design L.S. - (60.39 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00H - R0020 - Laboratory L.S. - (91.74 SQM) - Teaching Space: 1 | ● Student Space (42) | |
| B00H - R0026 - General Learning Space - (39.07 SQM) - Teaching Space: 1 | ● Student Space (18) | |
| B00H - R0027 - General Learning Space - (52.2 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00H - R0028 - Preparation - Science - (28.41 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R1001 - Movement - (271.84 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R1003 - General Learning Space - (39.1 SQM) - Teaching Space: 1 | ● Student Space (18) | |
| B00H - R1004 - Senior Seminar - (12.53 SQM) | ● Office (3) | |
| B00H - R1005 - Senior Seminar - (12.7 SQM) | ● Office (3) | |
| B00H - R1006 - General Learning Space - (65.67 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00H - R1007 - Staff Study - (12.74 SQM) | ● Office (3) | |
| B00H - R1008 - Staff Study - (25.6 SQM) | ● Office (6) | |
| B00H - R1009 - Staff Study - (12.39 SQM) | ● Office (3) | |
| B00H - R1013 - General Learning Space - (60.48 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00H - R1015 - Staff Study - (12.74 SQM) | ● Office (3) | |
| B00H - R1017 - General Learning Space - (52.13 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00H - R1018 - General Learning Space - (52.43 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00H - R1019 - Computer Learning Space - (52.14 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00H - R1021 - Computer Learning Space - (51.99 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00H - R9001 - Movement - (44.66 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R9002 - Art Learning Space - (108.99 SQM) - Teaching Space: 1 | ● Student Space (50) | |
| B00H - R9004 - Darkroom Space - (16.03 SQM) | ● Office (4) | |
| B00H - R9006 - Darkroom Space - (16.79 SQM) | ● Office (4) | |
| B00I - R0014 - Materials Technology L.S. - (219.54 SQM) - Teaching Space: 1 | ● Student Space (101) | |