

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Forbes High School (8194)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Orange</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Forbes</b>

8194 - Forbes High School  
Site Plan (10381)



1:1,697

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Special Learning Space - (53.07 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R0004 - Special Learning Space - (53.36 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R0010 - Staff Study - (14.95 SQM)	Office (3)	
B001 - R0013 - Clinic - Boys - (16.92 SQM)	Office (4)	
B001 - R0014 - Administration - Clerical - (8.39 SQM)	Office (2)	
B001 - R0015 - Interview/Office - Type 1 - (9.88 SQM)	Office (2)	
B001 - R0022 - Principal Office - (19.18 SQM)	Office (4)	
B001 - R0023 - Administration - Clerical - (19.18 SQM)	Office (4)	
B001 - R0024 - Duplicating Workroom - (12.85 SQM)	Office (3)	
B001 - R0027 - Deputy Principal Office - (15.1 SQM)	Office (3)	
B001 - R0028 - Administration - Clerical - (19.11 SQM)	Office (4)	
B001 - R0031 - Commonroom - (49.63 SQM)	Office (12)	
B001 - R0036 - Movement - (10.47 SQM)	Not Applicable	Circulation or storage space.
B001 - R0040 - Practical Activities - (38.03 SQM)	Student Space (17)	
B001 - R0041 - Movement - (86.7 SQM)	Not Applicable	Circulation or storage space.
B001 - R0045 - Entry - (17.67 SQM)	Not Applicable	Circulation or storage space.
B001 - R0046 - Entry - (27.28 SQM)	Not Applicable	Circulation or storage space.
B001 - R0047 - Movement - (44.5 SQM)	Not Applicable	Circulation or storage space.
B001 - R1001 - Senior Study - (26.65 SQM)	Office (6)	
B001 - R1002 - Senior Study - (44.53 SQM)	Office (11)	
B001 - R1004 - Interview/Office - Type 1 - (44.34 SQM)	Office (11)	
B001 - R1005 - Staff Study - (25.41 SQM)	Office (6)	
B001 - R1007 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R1008 - General Learning Space - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R1009 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R1010 - General Learning Space - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R1011 - Staff Study - (9.47 SQM)	Office (2)	
B001 - R1012 - Staff Study - (9.37 SQM)	Office (2)	
B001 - R1013 - Staff Study - (10.32 SQM)	Office (2)	
B001 - R1014 - Staff Study - (10.18 SQM)	Office (2)	
B001 - R1017 - Movement - (89.47 SQM)	Not Applicable	Circulation or storage space.
B001 - R1018 - Movement - (15.32 SQM)	Not Applicable	Circulation or storage space.
B001 - R1019 - General Learning Space - (126.74 SQM) - Teaching Space: 1	Student Space (58)	
B002 - R0007 - Food Technology L.S. - (65.6 SQM) - Teaching Space: 1	Student Space (30)	
B002 - R0018 - Movement - (110.87 SQM)	Not Applicable	Circulation or storage space.
B002 - R0019 - General Learning Space - Type 10 - (35.59 SQM) - Teaching Space: 0.5	Student Space (16)	
B002 - R0022 - Science Laboratory - (55.85 SQM)	Student Space (25)	
B002 - R0023 - General Learning Space - Type 10 - (36.45 SQM) - Teaching Space: 0.5	Student Space (16)	
B002 - R0024 - Science Laboratory - (44.16 SQM)	Student Space (20)	
B002 - R0025 - Preparation - (35.43 SQM)	Not Applicable	Circulation or storage space.
B002 - R0026 - Science Laboratory - (38.45 SQM)	Student Space (17)	
B002 - R0027 - General Learning Space - Type 10 - (43.38 SQM) - Teaching Space: 0.5	Student Space (20)	
B002 - R0029 - Preparation - Materials - (16.95 SQM)	Not Applicable	Circulation or storage space.
B002 - R0030 - Kitchen - Type 1 - (86.58 SQM)	Student Space (40)	
B002 - R1001 - Music Learning Space - (53 SQM) - Teaching Space: 1	Student Space (24)	
B002 - R1004 - Music Learning Space - (52.11 SQM) - Teaching Space: 1	Student Space (24)	
B002 - R1006 - General Learning Space - (52.78 SQM) - Teaching Space: 1	Student Space (24)	
B002 - R1007 - General Learning Space - (52.7 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B002 - R1008 - General Learning Space - (52.7 SQM) - Teaching Space: 1	● Student Space (24)	
B002 - R1009 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B002 - R1011 - General Learning Space - (52.34 SQM) - Teaching Space: 1	● Student Space (24)	
B002 - R1012 - General Learning Space - (52.78 SQM) - Teaching Space: 1	● Student Space (24)	
B002 - R1014 - Staff Study - (39.69 SQM)	● Office (9)	
B002 - R1016 - Movement - (121.9 SQM)	Not Applicable	Circulation or storage space.
B003 - R0001 - Movement - (11.67 SQM)	Not Applicable	Circulation or storage space.
B003 - R0011 - Materials Technology L.S. - (107.87 SQM) - Teaching Space: 1	● Student Space (50)	
B003 - R0014 - Movement - (13.01 SQM)	Not Applicable	Circulation or storage space.
B003 - R0019 - Staff Study - (40.24 SQM)	● Office (10)	
B003 - R0024 - Welding Area - (11.84 SQM)	Not Applicable	Circulation or storage space.
B003 - R0025 - Welding Area - (11.78 SQM)	Not Applicable	Circulation or storage space.
B003 - R0027 - Welding Area - (9.91 SQM)	Not Applicable	Circulation or storage space.
B003 - R0028 - Materials Technology L.S. - (111.76 SQM) - Teaching Space: 1	● Student Space (51)	
B003 - R1002 - Computer Learning Space - (66.47 SQM) - Teaching Space: 1	● Student Space (30)	
B003 - R1003 - Art Learning Space - (65.58 SQM) - Teaching Space: 1	● Student Space (30)	
B003 - R1008 - General Learning Space - (66.03 SQM) - Teaching Space: 1	● Student Space (30)	
B003 - R1010 - Movement - (76 SQM)	Not Applicable	Circulation or storage space.
B004 - R0004 - Preparation - (51.1 SQM)	Not Applicable	Circulation or storage space.
B004 - R0005 - Laboratory L.S. - (92.82 SQM) - Teaching Space: 1	● Student Space (43)	
B004 - R0006 - Movement - (12.98 SQM)	Not Applicable	Circulation or storage space.
B004 - R0007 - General Learning Space - (59.54 SQM) - Teaching Space: 1	● Student Space (27)	
B004 - R0010 - General Learning Space - Type 10 - (68.24 SQM) - Teaching Space: 0.5	● Student Space (31)	
B004 - R0011 - Science Laboratory - (20.43 SQM)	● Student Space (9)	
B004 - R1001 - Workroom - (12.89 SQM)	● Office (3)	
B004 - R1002 - Workroom - (12.82 SQM)	● Office (3)	
B004 - R1003 - Audio Visual Workroom - (12.96 SQM)	● Student Space (6)	
B004 - R1004 - Audio Visual Workroom - (12.71 SQM)	● Student Space (5)	
B004 - R1005 - Main Area - (215.56 SQM)	Not Applicable	Circulation or storage space.
B004 - R1007 - Entry - (29.46 SQM)	Not Applicable	Circulation or storage space.
B005 - R0007 - Student Canteen - (49.98 SQM)	Not Applicable	Circulation or storage space.
B005 - R0009 - Movement - (6.8 SQM)	Not Applicable	Circulation or storage space.
B005 - R0010 - Movement - (197.01 SQM)	Not Applicable	Circulation or storage space.
B005 - R0012 - Darkroom Space - (37.25 SQM)	● Office (9)	
B005 - R0016 - Movement - (159.12 SQM)	Not Applicable	Circulation or storage space.
B006 - R0004 - Staff Kitchen - (14.46 SQM)	● Office (3)	
B006 - R0005 - Staff Study - (9.15 SQM)	● Office (2)	
B006 - R0006 - Staff Study - (9.15 SQM)	● Office (2)	
B006 - R0015 - Multi-Purpose Space - (515.55 SQM)	● Student Space (239)	
B006 - R0016 - Stage - (70.99 SQM)	Not Applicable	Circulation or storage space.
B006 - R0017 - Movement - (67.08 SQM)	Not Applicable	Circulation or storage space.
B006 - R0018 - Movement - (186.77 SQM)	Not Applicable	Circulation or storage space.
B008 - R0001 - Wood Technology Bay - (100.17 SQM)	Not Applicable	Circulation or storage space.
B008 - R0004 - Staff Study - (12.32 SQM)	● Office (3)	
B009 - R0001 - Computer Learning Space - (91.97 SQM) - Teaching Space: 1	● Student Space (42)	
B009 - R0002 - Seminar - Type 2 - (19.03 SQM)	● Office (4)	
OS 502 13953 - OS 502 13953 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 510 13954 - OS 510 13954 - Staff Common Room - (114 SQM)	● Office (28)	
OS 601 13959 - OS 601 13959 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 730 10764 - OS 730 10764 - Needlework Textile Learning/Str/Fitting - (95 SQM)	Not Applicable	Circulation or storage space.

