


VENTILATION AUDIT REPORT

SCHOOL:	Forbes North Public School (4100)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Orange
LOCAL GOVERNMENT AREA:	Forbes

4100 - Forbes North Public School
Site Plan (12521)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Interview - (31.32 SQM)	Office (7)	
B00A - R0005 - Duplicating Workroom - (11.69 SQM)	Office (2)	
B00A - R0006 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Sick Bay - (11.55 SQM)	Student Space (5)	
B00A - R0009 - Entry Vestibule - (20.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Principal - (17.46 SQM)	Office (4)	
B00A - R0014 - Clerical Office/Workroom - (15.32 SQM)	Office (3)	
B00A - R0017 - Clerical Office - (11.1 SQM)	Office (2)	
B00A - R0020 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Staff Room - (64.67 SQM)	Office (16)	
B00B - R0004 - Home Base - (57.34 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0005 - Home Base - (57.27 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0009 - Reading Area - (149.15 SQM)	Student Space (69)	
B00C - R0005 - Practical Activities - 1hb - (12.49 SQM)	Student Space (5)	
B00C - R0006 - Home Base - (67.08 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0007 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0008 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0010 - Staff Room Annexe - (12.67 SQM)	Office (3)	
B00C - R0011 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0018 - Movement - (6.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (5.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (86.33 SQM) - Teaching Space: 1	Student Space (40)	
B00D - R0007 - Home Base - (57.25 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0008 - Practical Activities - 1hb - (6.12 SQM)	Student Space (2)	
B00D - R0011 - Home Base - (57.02 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0017 - Home Base - (57.08 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0019 - Interview - (21.73 SQM)	Office (5)	
B00E - R0001 - Withdrawal Space - 1hb - (14.42 SQM)	Student Space (6)	
B00E - R0004 - Home Base - (47.17 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0008 - Movement - (8.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Staff Room Annexe - (14.39 SQM)	Office (3)	
B00F - R0002 - Home Base - (57.88 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0006 - Home Base - (86.45 SQM) - Teaching Space: 1	Student Space (40)	
B00G - R0003 - Movement - (48.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Canteen - (23.08 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Special Programs Room - (39.38 SQM)	Student Space (18)	
B00M - R0001 - Special Programs Room - (49.25 SQM)	Student Space (22)	
B00N - R0012 - Communal Space - (206.67 SQM)	Student Space (95)	