

VENTILATION AUDIT REPORT

SCHOOL:	Forbes Public School (1926)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Orange
LOCAL GOVERNMENT AREA:	Forbes

1926 - Forbes Public School
Site Plan (11978)



1:1,498

Printed: 03-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.05 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0006 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0008 - Movement - (42.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (87.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Hydrotherapy - Pool - (13.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - M - (41.32 SQM) - Teaching Space: 1	● Student Space (19)	
B00B - R0003 - Practical Activities - 1hb - (15.57 SQM)	● Student Space (7)	
B00B - R0006 - Movement - (7.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - M - (56.8 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0009 - Movement - (64.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Withdrawal Space - 1hb - (20.66 SQM)	● Student Space (9)	
B00C - R0009 - Home Base - (71.97 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R0011 - Withdrawal Space - 1hb - (21.72 SQM)	● Student Space (10)	
B00C - R0014 - Staff Room Annexe - (18.98 SQM)	○ Office (4)	
B00C - R0015 - Home Base - (72.51 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R0016 - Practical Activities - 1hb - (10.96 SQM)	● Student Space (5)	
B00C - R0017 - Movement - (26.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Staff Room Annexe - (14.35 SQM)	○ Office (3)	
B00D - R0003 - Home Base - (83.55 SQM) - Teaching Space: 1	● Student Space (38)	
B00D - R0008 - Home Base - (79.08 SQM) - Teaching Space: 1	● Student Space (36)	
B00D - R0009 - Withdrawal Space - 1hb - (29.77 SQM)	● Student Space (13)	
B00E - R0001 - Reading Area - (143.73 SQM)	● Student Space (66)	
B00E - R0005 - Movement - (15.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Special Programs Room - (42.12 SQM)	● Student Space (19)	
B00F - R0004 - Home Base - (59.6 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0005 - Home Base - (57.48 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0009 - Home Base - (57.07 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0010 - Home Base - (57.31 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0014 - Movement - (14.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Staff Study - (16.68 SQM)	○ Office (4)	
B00F - R0018 - Movement - (93.06 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (46.57 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0003 - Home Base - (46.67 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0004 - Home Base - (46.63 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0007 - Home Base - (55.67 SQM) - Teaching Space: 1	● Student Space (25)	
B00G - R0009 - Home Base - (46.6 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0010 - Special Programs Room - (46.69 SQM)	● Student Space (21)	
B00G - R0012 - Movement - (99.48 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Darkroom Space - (9.09 SQM)	○ Office (2)	
B00G - R0017 - Home Base - (58.14 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0018 - Practical Activities - 1hb - (16.84 SQM)	● Student Space (7)	
B00G - R0019 - Staff Room Annexe - (9.28 SQM)	○ Office (2)	
B00G - R0020 - Interview - (9 SQM)	○ Office (2)	
B00H - R0001 - Movement - (40.61 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Interview - (14.84 SQM)	○ Office (3)	
B00H - R0003 - Sick Bay - (10.15 SQM)	● Student Space (4)	
B00H - R0004 - Movement - (27.83 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Principal - (21.04 SQM)	○ Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0010 - Clerical Office - (14.04 SQM)	Office (3)	
B00H - R0012 - Clerical Office/Workroom - (12.19 SQM)	Office (3)	
B00H - R0013 - Staff Study - (49.65 SQM)	Office (12)	
B00H - R0014 - Movement - (40.61 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Home Base - (50.33 SQM) - Teaching Space: 1	Student Space (23)	
B00R - R0013 - Communal Space - (295.18 SQM)	Student Space (136)	
OS 520 10752 - OS 520 10752 - Staff Study - (57 SQM)	Office (14)	