


VENTILATION AUDIT REPORT

SCHOOL:	Forest Lodge Public School (1932)
AMU REGION:	Sydney
STATE ELECTORATE:	Balmain
LOCAL GOVERNMENT AREA:	Sydney

1932 - Forest Lodge Public School
Site Plan (11877)















1:566

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Deputy Principal - (12.82 SQM)	Office (3)	
B00A - R0005 - Movement - (7.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Movement - (16.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (18.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (21.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Withdrawal Space - 1hb - (16.74 SQM)	Student Space (7)	
B00A - R0017 - Home Base - (46.92 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0018 - Practical Activities - 1hb - (14.53 SQM)	Student Space (6)	
B00A - R0022 - Duplicating Workroom - (10.73 SQM)	Office (2)	
B00A - R0023 - Clerical Office - (13.32 SQM)	Office (3)	
B00A - R0026 - Entry Vestibule - (21.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Clerical Office - (10.47 SQM)	Office (2)	
B00A - R0028 - Principal - (18.3 SQM)	Office (4)	
B00A - R0030 - Movement - (10.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Interview - (11.98 SQM)	Office (2)	
B00A - R0033 - Movement - (7.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (14.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Practical Activities - 1hb - (14.59 SQM)	Student Space (6)	
B00A - R0038 - Withdrawal Space - 1hb - (7.97 SQM)	Student Space (3)	
B00A - R0039 - Home Base - (48.57 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0044 - Withdrawal Space - 1hb - (31.21 SQM)	Student Space (14)	
B00A - R0045 - Practical Activities - 1hb - (15.63 SQM)	Student Space (7)	
B00A - R0046 - Home Base - (48.54 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0048 - Raised Platform - (32.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0049 - Movement - (24.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0050 - Communal Space - (127.6 SQM)	Student Space (59)	
B00A - R0057 - Staff Room - (47.99 SQM)	Office (11)	
B00A - R0058 - Movement - (39.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0063 - Movement - (11.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0065 - Home Base/Practical Activities - (69.81 SQM) - Teaching Space: 1	Student Space (32)	
B00A - R1002 - Home Base - (47.56 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1003 - Home Base - (47.63 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1006 - Special Programs Room - (8.19 SQM)	Student Space (3)	
B00A - R1008 - Movement - (8.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Movement - (29.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Deputy Principal - (12.57 SQM)	Office (3)	
B00A - R1016 - Movement - (47.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Withdrawal Space - 1hb - (15.7 SQM)	Student Space (7)	
B00A - R1018 - Home Base - (47.52 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1019 - Practical Activities - 1hb - (15.57 SQM)	Student Space (7)	
B00A - R1022 - Practical Activities - 1hb - (15.49 SQM)	Student Space (7)	
B00A - R1023 - Home Base - (48.33 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1024 - Withdrawal Space - 1hb - (13.77 SQM)	Student Space (6)	
B00A - R1025 - Practical Activities - 1hb - (19.6 SQM)	Student Space (9)	
B00A - R1026 - Home Base - (53.64 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1027 - Home Base - (54.03 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1028 - Practical Activities - 1hb - (18.41 SQM)	Student Space (8)	
B00A - R1032 - Reading Area - (8.88 SQM)	Student Space (4)	
B00A - R1033 - Reading Area - (93.88 SQM)	Student Space (43)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1034 - Movement - (16.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R1035 - Movement - (9.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R1036 - Movement - (12.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R1038 - Withdrawal Space - 1hb - (11.71 SQM)	 Student Space (5)	
B00A - R1039 - Home Base - (48.22 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R1040 - Practical Activities - 1hb - (14.67 SQM)	 Student Space (6)	
B00A - R1041 - Movement - (11.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R1045 - Special Programs Room - (19.31 SQM)	 Student Space (8)	
B00A - R1046 - Shared Study Space - (37.46 SQM)	 Office (9)	
B00A - R1048 - Practical Activities - (5.03 SQM)	 Student Space (2)	
B00B - R0004 - Home Base - (48.84 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R0006 - Home Base - (48.7 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R0026 - Practical Activities - 1hb - (13.68 SQM)	 Student Space (6)	
B00B - R0027 - Practical Activities - 1hb - (13.58 SQM)	 Student Space (6)	
B00B - R0029 - Practical Activities - 1hb - (14 SQM)	 Student Space (6)	
B00C - R0012 - Movement - (10.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Special Programs Room - (70.27 SQM)	 Student Space (32)	