


VENTILATION AUDIT REPORT

SCHOOL:	Fort Street High School (8504)
AMU REGION:	Sydney
STATE ELECTORATE:	Newtown
LOCAL GOVERNMENT AREA:	Inner West

8504 - Fort Street High School
Site Plan (13595)



1:195

Printed: 08-Aug-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0009 - Staff Study - (20.18 SQM)	Office (5)	
B00A - R0010 - General Learning Space - (48.24 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0011 - General Learning Space - (48.92 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0013 - Movement - (39.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Deputy Principal Office - (20.52 SQM)	Office (5)	
B00A - R0015 - Movement - (5.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Commonroom - (72.16 SQM)	Office (18)	
B00A - R0017 - Commonroom - (8.1 SQM)	Office (2)	
B00A - R0018 - Duplicating Workroom - (24.61 SQM)	Office (6)	
B00A - R0019 - Movement - (22.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Public Entry - (24.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (83.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (23.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Public Entry - (18.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Principal Office - (18.73 SQM)	Office (4)	
B00A - R0035 - General Learning Space - (44.3 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0037 - General Learning Space - (45.06 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0038 - Movement - (73.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Movement - (12.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - General Learning Space - (39.35 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R0042 - Staff Study - (19.38 SQM)	Office (4)	
B00A - R0046 - Movement - (10.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (48.33 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1002 - General Learning Space - (45.57 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1006 - General Learning Space - (50.5 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1007 - General Learning Space - (50.56 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1008 - Movement - (77.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Staff Study - (21.02 SQM)	Office (5)	
B00A - R1010 - Movement - (45.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - General Learning Space - (48.43 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1013 - Staff Study - (35.62 SQM)	Office (8)	
B00A - R1014 - General Learning Space - (47.75 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1015 - Movement - (24.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Movement - (88.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R1018 - General Learning Space - (45.27 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1021 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R1022 - General Learning Space - (45.44 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1023 - Movement - (24 SQM)	Not Applicable	Circulation or storage space.
B00A - R1027 - General Learning Space - (78.4 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R2001 - General Learning Space - (49.21 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R2002 - General Learning Space - (45.64 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R2005 - Staff Study - (21.08 SQM)	Office (5)	
B00A - R2006 - General Learning Space - (50.96 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R2007 - General Learning Space - (50.82 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R2008 - Movement - (76.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R2011 - Movement - (45.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R2012 - General Learning Space - (33.76 SQM) - Teaching Space: 1	Student Space (15)	
B00A - R2013 - General Learning Space - (49.37 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R2014 - Computer Learning Space - (50.53 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R2015 - Movement - (24.2 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R2017 - Movement - (92.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R2018 - General Learning Space - (45.7 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R2020 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R2023 - Movement - (23.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R2027 - Computer Learning Space - (45.84 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R2028 - General Learning Space - (80.12 SQM) - Teaching Space: 1	● Student Space (37)	
B00A - R9001 - Art Entry/Display - (7.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R9002 - Art Learning Space - (47.42 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R9003 - Workshop - (76.32 SQM)	● Student Space (35)	
B00A - R9006 - Workshop - (17.38 SQM)	● Student Space (8)	
B00A - R9014 - Movement - (5.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Stage - (10.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Stage - (57.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Stage - (13.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Multi-Purpose Space - (590.51 SQM)	● Student Space (273)	
B00B - R0008 - Staff Kitchen - (7.07 SQM)	○ Office (1)	
B00B - R0009 - Movement - (8.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R9004 - Movement - (8.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R9005 - General Assistants - (153.65 SQM)	○ Office (38)	
B00B - R9009 - Movement - (5.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R9010 - Movement - (10.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R9011 - Movement - (15.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R9015 - Staff Kitchen - (23.49 SQM)	○ Office (5)	
B00B - R9016 - Commonroom - (45.25 SQM)	○ Office (11)	
B00C - M0006 - Movement - (13.72 SQM)	Not Applicable	Circulation or storage space.
B00C - M0008 - General Learning Space - (55.83 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - M1005 - Movement - (13.72 SQM)	Not Applicable	Circulation or storage space.
B00C - M1007 - General Learning Space - (55.83 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - M2006 - Movement - (12.19 SQM)	Not Applicable	Circulation or storage space.
B00C - M2008 - General Learning Space - (55.74 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - M9010 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B00C - M9011 - General Learning Space - (52.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0001 - Movement - (8.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Wood Technology L.S. - (102.93 SQM) - Teaching Space: 1	● Student Space (47)	
B00C - R0006 - Metal Technology L.S. - (102.81 SQM) - Teaching Space: 1	● Student Space (47)	
B00C - R0012 - Laboratory L.S. - (92.47 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0015 - Laboratory L.S. - (92.75 SQM) - Teaching Space: 1	● Student Space (43)	
B00C - R0021 - Laboratory L.S. - (92.68 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0024 - Laboratory L.S. - (92.59 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0027 - Music Learning Space - (67.03 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0034 - Movement - (281.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0035 - Preparation - (29.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0037 - Movement - (17.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R0038 - Preparation - (39.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Design L.S. - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1007 - Design L.S. - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1010 - Wood Technology L.S. - (80.08 SQM) - Teaching Space: 1	● Student Space (37)	
B00C - R1015 - Laboratory L.S. - (92.67 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R1016 - Preparation - (28.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R1018 - Laboratory L.S. - (91.13 SQM) - Teaching Space: 1	● Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1026 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1027 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1028 - General Learning Space - (52.95 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1029 - Staff Study - (17.21 SQM)	● Office (4)	
B00C - R1035 - Music Learning Space - (67.03 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R1036 - Music Learning Space - (72.48 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R1041 - Movement - (296.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R2004 - Staff Study - (19.92 SQM)	● Office (4)	
B00C - R2007 - Art Learning Space - (52.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R2008 - Art Learning Space - (62.68 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R2011 - General Learning Space - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R2013 - General Learning Space - (51.63 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R2015 - General Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R2016 - Staff Study - (20.3 SQM)	● Office (5)	
B00C - R2019 - Food Technology L.S. - (111.09 SQM) - Teaching Space: 1	● Student Space (51)	
B00C - R2022 - Staff Study - (5.16 SQM)	● Office (1)	
B00C - R2025 - Movement - (195.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R9016 - Movement - (21.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R9018 - Movement - (21.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R9024 - General Learning Space - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R9028 - Movement - (10.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R9030 - Dark Room - (10.06 SQM)	● Office (2)	
B00D - R0001 - Pupil Entry - (106.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Student Canteen - (61.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (7.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Tiered Learning Area - (16.45 SQM)	● Student Space (7)	
B00D - R0016 - Outdoor Learning Area - (109.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (44.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Movement - (21.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - Ancillary Staff - (21.5 SQM)	● Office (5)	
B00D - R1004 - Workroom - (58.44 SQM)	● Office (14)	
B00D - R1006 - Audio Visual Workroom - (40.99 SQM)	● Student Space (19)	
B00D - R1011 - Main Area - (610.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R1012 - Seminar - (12.33 SQM)	● Office (3)	
B00D - R1013 - Seminar - (12.16 SQM)	● Office (3)	
B00D - R1014 - Computer Learning Space - (66.18 SQM)	● Student Space (30)	
B00D - R1015 - Seminar - (12.33 SQM)	● Office (3)	
B00D - R1016 - Seminar - (12.16 SQM)	● Office (3)	
B00D - R1017 - Movement - (19.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R1018 - Movement - (38.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R1020 - Main Area - (517.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R1021 - Staff Kitchen - (6.92 SQM)	● Office (1)	
B00D - R1022 - Commonroom - (38.15 SQM)	● Office (9)	
B00D - R1024 - Computer Learning Space - (33.24 SQM) - Teaching Space: 1	● Student Space (15)	
B00D - R1025 - Interview/Meeting - (6.48 SQM)	● Office (1)	
B00D - R1026 - Seminar - Type 3 - (24.02 SQM)	● Office (6)	
B00D - R1027 - Seminar - Type 3 - (23.89 SQM)	● Office (5)	
B00D - R1028 - Seminar - Type 3 - (24.15 SQM)	● Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1029 - Seminar - Type 3 - (24.77 SQM)	Office (6)	
B00D - R1031 - Study Space - (96.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R1032 - Interview/Meeting - (11.46 SQM)	Office (2)	
B00D - R1034 - Movement - (5.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R9011 - Movement - (13.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R9013 - Staff Study - (13.22 SQM)	Office (3)	
B00D - R9015 - Gymnasium - (468.54 SQM)	Student Space (217)	
B00D - R9017 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R9018 - Staff Study - (10.79 SQM)	Office (2)	
B00D - R9021 - Tiered Learning Area - (37.17 SQM)	Student Space (17)	
B00E - R0001 - Music Learning Space - (67.11 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R0003 - Movement - (12.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Public Entry - (41.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Interview/Office - Type 1 - (13 SQM)	Office (3)	
B00F - R0003 - Principal Office - (12.75 SQM)	Office (3)	
B00F - R0004 - Principal Office - (19.94 SQM)	Office (4)	
B00F - R0006 - Deputy Principal Office - (12.48 SQM)	Office (3)	
B00F - R0007 - Administration - Clerical - (15.82 SQM)	Office (3)	
B00F - R0008 - Staff Kitchen - (13.76 SQM)	Office (3)	
B00F - R0012 - Duplicating Workroom - (16.43 SQM)	Office (4)	
B00F - R0013 - Administration - Clerical - (47.57 SQM)	Office (11)	
B00F - R0014 - Clinic-Waiting - (12.37 SQM)	Office (3)	
B00F - R0015 - Clinic - Boys - (12.38 SQM)	Office (3)	
B00F - R0018 - Clinic - Girls - (11.43 SQM)	Office (2)	
B00F - R0019 - Pupil Entry - (24.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Leading Teacher - (12.79 SQM)	Office (3)	
B00F - R0021 - Leading Teacher - (12.83 SQM)	Office (3)	
B00F - R0022 - Movement - (17.77 SQM)	Not Applicable	Circulation or storage space.
B00F - R0023 - Movement - (24.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R0024 - Movement - (37.94 SQM)	Not Applicable	Circulation or storage space.
B00F - R0026 - Movement - (5.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R0031 - Movement - (179.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R0032 - Movement - (15.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Interview/Office - Type 1 - (21.03 SQM)	Office (5)	
B00F - R1003 - Staff Study - (173.69 SQM)	Office (43)	
B00F - R1004 - General Learning Space - (60.51 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R1005 - General Learning Space - (58.98 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R1006 - General Learning Space - (60.02 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R1007 - General Learning Space - (59.79 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R1010 - Pupil Entry - (15.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R1011 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R1012 - Movement - (97.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R1018 - Movement - (15.33 SQM)	Not Applicable	Circulation or storage space.
B00F - R2002 - Movement - (6.49 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (67.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (14.33 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Music Learning Space - (99.52 SQM) - Teaching Space: 1	Student Space (46)	
B00G - R1004 - Performance Workspace - (99.88 SQM) - Teaching Space: 1	Student Space (46)	
B00G - R1006 - Movement - (111.91 SQM)	Not Applicable	Circulation or storage space.
B00G - R1007 - Movement - (13.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R2001 - Movement - (10.57 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R2002 - Interview/Office - Type 1 - (19.41 SQM)	Office (4)	
B00G - R2004 - Staff Kitchen - (6.22 SQM)	Office (1)	
B00G - R2005 - Staff Study - (175.88 SQM)	Office (43)	
B00G - R2009 - Movement - (80.81 SQM)	Not Applicable	Circulation or storage space.