

VENTILATION AUDIT REPORT
















SCHOOL:	Fowler Road School (5562)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Granville
LOCAL GOVERNMENT AREA:	Cumberland

5562 - Fowler Road School
Site Plan (10679)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office/Workroom - (11.99 SQM)	 Office (2)	
B00A - R0004 - Withdrawal Space - 1hb - (53.58 SQM)	 Student Space (24)	
B00A - R0006 - Staff Room - (53.58 SQM)	 Office (13)	
B00A - R0009 - Entry Vestibule - (16.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Clerical Office/Workroom - (15.56 SQM)	 Office (3)	
B00A - R0011 - Principal - (20.05 SQM)	 Office (5)	
B00B - R0002 - Home Base - (53.43 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0003 - Home Base - (53.36 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0004 - Home Base - (42.77 SQM) - Teaching Space: 1	 Student Space (19)	
B00B - R0005 - Practical Activities - 1hb - (10 SQM)	 Student Space (4)	
B00B - R9001 - Movement - (10.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - Bd/Cd/Ed - (58.4 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0003 - Practical Activities - 1hb - (6.74 SQM)	 Student Space (3)	
OS 600 14217 - OS 600 14217 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 11941 - OS 601 11941 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14772 - OS 601 14772 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14985 - OS 601 14985 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	